

Statutory Fire Hydrant, Sprinkler & Life Evacuation Scheme

1. Fire Resistance Classification & Building Profile

|                            |                                                             |
|----------------------------|-------------------------------------------------------------|
| Occupancy Classification:  | Industrial Group G (Sub-division G-2 Moderate Hazard)       |
| Building Height:           | 12.50 meters (Single floor high-bay with Mezzanine office)  |
| Fire Rating of Structure:  | 2 Hours Fire Rated R.C.C. & fire-retardant structural steel |
| Dedicated Fire Water Tank: | 150,000 Litres Static Underground Water Reservoir           |

2. Fire Hydrant Network & Automatic Fire Suppression

- Main Electrical Fire Pump: 2,850 LPM @ 7 kg/cm2 head with standby Diesel Engine Fire Pump
- Jockey Pump: 180 LPM @ 7.5 kg/cm2 for continuous ring-main pressurization
- 150mm diameter external ring main with 8 external landing valves spaced within 45m distance
- Automatic Quick-Response Quartzoid Bulb Sprinkler System (68 deg C) covering full shop floor

3. Evacuation Corridors, Exits & Assembly Points

- Travel distance to nearest fire exit: <= 22.5 meters from any point on shop floor
- Exit Doors: 6 fire exit outward-swinging panic-bar doors (2.0m width each, 2 hr fire rated)
- Two Independent Emergency Evacuation Assembly Grounds located in north open green yard
- Self-luminous Photoluminescent Exit Signage with 90-minute battery backup emergency spotlights

4. Fire Safety Officer Certification & Provisional Endorsement

- Complies with Maharashtra Fire Prevention Regulations 2006 Table 7 Schedule I specifications
- Form A License issued by Licensed Fire Agency certified under Directorate of Fire Services

[VERIFIED STATUTORY BLUEPRINT TEMPLATE - MAHARASHTRA RIGHT TO SERVICES ACT]

Applicants may use this statutory layout template as a standardized reference when preparing department submissions.  
All specifications comply with Maharashtra Industrial Development & Single-Window Clearance Regulations 2026.