QUALITY OBERVATION REPORT

Project : VTP BELLISSIMO		**Report No.**	68
Client : VTP REALTY		**Date of Issue**	18-Jun-25
Contractor : Karan Builders		**Date Of Closure**	

Sr No	Date	Tower	Location	Activity	Building Incharge	Description of observation	Before Photos	Corrective action	After Photos	Date Of Closure	Ageing	Status	Remark
1	18-Jun-25	Tower-08	Podium - 3 Level / Pour - 3	Post Pour	Mr. Sandip / Mr. Rajeev	Major honeycomb observed on wall, reinforcement steel exposed						Open	
2	18-Jun-25	Tower-08	Podium - 3 Level / Pour - 3	Post Pour	Mr. Sandip / Mr. Rajeev	Major honeycomb observed on wall, reinforcement steel exposed						Open	
3	18-Jun-25	Tower-08	Podium - 3 Level / Pour - 3	Post Pour	Mr. Sandip / Mr. Rajeev	Major Cavity observed at S/wall & beam junction, reinforcement steel exposed.						Open	
4	18-Jun-25	Tower-08	Podium - 3 Level / Pour - 3	Post Pour	Mr. Sandip / Mr. Rajeev	Major honeycomb observed, reinforcement steel exposed						Open	
5	18-Jun-25	Tower-08	Podium - 3 Level / Pour - 3	Post Pour	Mr. Sandip / Mr. Rajeev	Major honeycomb observed at beam bottom, reinforcement steel exposed.						Open	
6	18-Jun-25	Tower-08	Podium - 3 Level / Pour - 3	Post Pour	Mr. Sandip / Mr. Rajeev	Major cavity observed at beam and slab junction.						Open	

QUALITY OBERVATION REPORT

Project : VTP BELLISSIMO		**Report No.**	68
Client : VTP REALTY		**Date of Issue**	18-Jun-25
Contractor : Karan Builders		**Date Of Closure**	

Sr No	Date	Tower	Location	Activity	Building Incharge	Description of observation	Before Photos	Corrective action	After Photos	Date Of Closure	Ageing	Status	Remark
7	18-Jun-25	Tower-08	Podium - 3 Level / Pour - 3	Post Pour	Mr. Sandip / Mr. Rajeev	Major cavity observed at beam and s/wall junction.						Open	
8	18-Jun-25	Tower-08	Podium - 3 Level / Pour - 3	Post Pour	Mr. Sandip / Mr. Rajeev	Major undulations observed on column beam junction.						Open	
9	18-Jun-25	Tower-08	Podium - 3 Level / Pour - 3	Post Pour	Mr. Sandip / Mr. Rajeev	Major offset observede at slab sofit.						Open	
10	18-Jun-25	Tower-08	Podium - 3 Level / Pour - 3	Post Pour	Mr. Sandip / Mr. Rajeev	Major offset observed at S/wall & cap junction.						Open	
11	18-Jun-25	Tower-08	Podium - 3 Level / Pour - 3	Post Pour	Mr. Sandip / Mr. Rajeev	Major hoeycomb observed at waist slab of main staircase.						Open	
12	18-Jun-25	Tower-08	Podium - 3 Level / Pour - 3	Post Pour	Mr. Sandip / Mr. Rajeev	Major offset observed at S/wall & cap junction.						Open	

QUALITY OBERVATION REPORT

Project : VTP BELLISSIMO		**Report No.**	68
Client : VTP REALTY		**Date of Issue**	18-Jun-25
Contractor : Karan Builders		**Date Of Closure**	

Sr No	Date	Tower	Location	Activity	Building Incharge	Description of observation	Before Photos	Corrective action	After Photos	Date Of Closure	Ageing	Status	Remark
13	18-Jun-25	Tower-08	Podium - 3 Level / Pour - 3	Post Pour	Mr. Sandip / Mr. Rajeev	Major honeycomb observed, reinforcement steel exposed						Open	