

BANGLADESH GAS FIELDS COMPANY LIMITED

Power Cable Schedule



CONSORTIUM OF SINOPEC PETROLEUM ENGINEERING CORPORATION AND ZICOM EQUIPMENT PTE. LTD.



LOCATION PROJECT JOB NO.

BANGLADESH GAS FIELDS COMPANY LIMITED

TITAS GAS FIELD, BRAHMANBARIA, BANGLADESH
2 X 75 MMSCFD GLYCOL DEHYDRATION TYPE GAS PROCESS PLANT
252 - I

252-0201-EMEL-CL00-0001 DOC NO.: Rev : A SERVICE : TAG NO. : N/A QUANTITY: N/A

SI.No	TAG NO.	DISCRIPTION	SOURCE	DESTINATION	CABLE SIZE (sqmm)	CABLE LENGTH (Meter)	CABLE VOLTAGE	Power Factor (p.f)	CABLE TYPE	CONDUCTOR	LOAD	
						ļ						
1	G-01	GENERATOR 01	G1	MCC	0/1C V 150mm2)	240	600V	0.85	PVC ARMOURED	COPPER	276 KW	
	G-02	GENERATOR 01 GENERATOR 02	G2	MCC	8(1C X 150mm2)	240 300	600V	0.85	PVC ARMOURED	COPPER	276 KW	
	G-02	NATIONAL GRID LINE	GRID LINE	MCC	8(1C X 150mm2)			 	PVC ARMOURED	COPPER		
3	P-300A-I	CONDENSATE TRANSFER PUMP	MCC	P-300A-I	4C X 300mm2 4C X 6mm2	90	600V	0.85 0.85	PVC ARMOURED	COPPER		
		CONDENSATE TRANSFER PUMP					600V		PVC ARMOURED			
	P-300B-I	CONDENSATE TRANSFER PUMP-LCS	MCC	P-300B-I	4C X 6mm2	230	600V	0.85	PVC ARMOURED	COPPER	11 KW	
<u> </u>	P-300A-I-LCS	CONDENSATE TRANSFER PUMP-LCS	MCC	P-300A-I-LCS	12CX1.5mm2	230	600V	0.85	PVC ARMOURED	COPPER		
	P-300B-I-LCS		MCC	P-300B-I-LCS	12CX1.5mm2	230	600V	0.85		COPPER		
	P-200A-I	CONDENSATE RECYCLE PUMP	MCC	P-200A-I	4CX 2.5mm2	200	600V	0.85	PVC ARMOURED	COPPER	1.5 KW	
	P-200B-I	CONDENSATE RECYCLE PUMP	MCC	P-200B-I	4CX 2.5mm2	200	600V	0.85	PVC ARMOURED	COPPER		
	P-200A-I-LCS	CONDENSATE RECYCLE PUMP-LCS	MCC	P-200A-I	12CX1.5mm2	200	600V	0.85	PVC ARMOURED	COPPER		
	P-200B-I-LCS	CONDENSATE RECYCLE PUMP-LCS	MCC	P-200B-I	12CX1.5mm2	200	600V	0.85	PVC ARMOURED	COPPER		
	AC-100A-I	INLET AIR COOLER	MCC	AC-100A-I	4C X10mm2	300	600V	0.85	PVC ARMOURED	COPPER	15 KW	
13	AC-100B-I	INLET AIR COOLER	MCC	AC-100B-I	4C X10mm2	300	600V	0.85	PVC ARMOURED	COPPER		
14	AC-100A-I-LCS	INLET AIR COOLER-LCS	MCC	AC-100A-I-LCS	12CX1.5mm2	300	600V	0.85	PVC ARMOURED	COPPER		
15	AC-100B-I-LCS	INLET AIR COOLER-LCS	MCC	AC-100B-I-LCS	12CX1.5mm2	300	600V	0.85	PVC ARMOURED	COPPER		
	E-300-I	OVERHEAD GAS COOLER	MCC	E-300-I	4CX 2.5mm2	340	600V	0.85	PVC ARMOURED	COPPER	3 KW	
	E-300-I-LCS	OVERHEAD GAS COOLER-LCS	MCC	E-300-I-LCS	12CX1.5mm2	340	600V	0.85	PVC ARMOURED	COPPER		
	P-400-I	KOD PUMP	MCC	P-400-I	4CX 2.5mm2	200	600V	0.85	PVC ARMOURED	COPPER	1.1 KW	
19	P-400-I-LCS	KOD PUMP-LCS	MCC	P-400-I-LCS	12CX1.5mm2	200	600V	0.85	PVC ARMOURED	COPPER		
	P-700-I	DEEP WELL PUMP	MCC	P-700-I	4C X 4mm2	110	600V	0.85	PVC ARMOURED	COPPER	7.5 KW	
21	P-700-I-LCS	DEEP WELL PUMP -LCS	MCC	P-700-I-LCS	12CX1.5mm2	110	600V	0.85	PVC ARMOURED	COPPER		
22	P-700-I	PUMP TO CONTROL PANEL(Flat Cable)	PUMP CONTROL PANEL	PUMP	2 (3C x 4 mm2)	500	600V	0.85	PVC ARMOURED	COPPER		
23	P-800-I	DEEP WELL PUMP	MCC	P-800-I	4C X 4mm2	110	600V	0.85	PVC ARMOURED	COPPER	7.5 KW	
24	P-800-I-LCS	DEEP WELL PUMP -LCS	MCC	P-800-I-LCS	12CX1.5mm2	110	600V	0.85	PVC ARMOURED	COPPER		
25	P-800-I	PUMP TO CONTROL PANEL(Flat Cable)	PUMP CONTROL PANEL	PUMP	2 (3C x 4 mm2)	500	600V	0.85	PVC ARMOURED	COPPER		
26	P-500A-I	ELECTRIC FIRE WATER PUMP	MCC	P-500A-I	4C X 185mm2 12CX1.5mm2	150 150	600V 600V	0.85 0.85	PVC ARMOURED	COPPER COPPER	134 KW	
27	P-500A-I-LCS	ELECTRIC FIRE WATER PUMP-LCS	MCC	P-500A-I-LCS					PVC ARMOURED			
28	P-500B-I	CONTROL PANEL DIESEL FIRE PUMP	MCC	P-500B-I	4CX 2.5mm2	150	600V	0.85	PVC ARMOURED	COPPER	0.5 KW	
29	P-600-I	JOCKEY PUMP CONTROL PANEL	MCC	P-600-I	4CX 6mm2	150	600V	0.85	PVC ARMOURED	COPPER	11 KW	
30	G-1201-P-I	GENERATOR-1 COOLING TOWER PUMP	MCC	G-1201-P-I	4CX 4mm2	20	600V	0.85	PVC ARMOURED	COPPER	5.5 KW	
31	G-1201-P-I-LCS	GENERATOR-1 COOLING TOWER PUMP-LCS	MCC	G-1201-P-I-LCS	12CX1.5mm2	20	600V	0.85	PVC ARMOURED	COPPER		
32	G-1201-F-I	GENERATOR-1 COOLING TOWER FAN	MCC	G-1201-F-I	4CX 4mm2	35	600V	0.85	PVC ARMOURED	COPPER	5.5 KW	
33	G-1201-F-I-LCS	GENERATOR-1 COOLING TOWER FAN-LCS	MCC	G-1201-F-I-LCS	12CX1.5mm2	20	600V	0.85	PVC ARMOURED	COPPER		
34	G-1202-P-I	GENERATOR-2 COOLING TOWER PUMP	MCC	G-1202-P-I	4CX 4mm2	20	600V	0.85	PVC ARMOURED	COPPER	E E IZ\NI	
35	G-1202-P-I-LCS	GENERATOR-2 COOLING TOWER PUMP-LCS	MCC	G-1202-P-I-LCS	12CX1.5mm2	20	600V	0.85	PVC ARMOURED	COPPER	5.5 KW	
36	G-1202-F-I	GENERATOR-2 COOLING TOWER FAN	MCC	G-1202-F-I	4CX 4mm2	35	600V	0.85	PVC ARMOURED	COPPER	E E IZ\NI	
37	G-1202-F-I-LCS	GENERATOR-2 COOLING TOWER FAN-LCS	MCC	G-1202-F-I-LCS	12CX1.5mm2	20	600V	0.85	PVC ARMOURED	COPPER	5.5 KW	
38		GENERATOR BATTERY CHARGER	MCC	BATTERY CHARGER	3CX 2.5mm2	30	600V	0.85	PVC ARMOURED	COPPER		
39		UTILITY POWER OPERATION BULDING	MCC	UTILITY POWER OPERATION BULDING	4CX 16mm2	180	600V	0.85	PVC ARMOURED	COPPER	22 KW	
40		UTILITY POWER WORKSHOP BULDING	MCC	UTILITY POWER WORKSHOP BULDING	4CX 6mm2	160	600V	0.85	PVC ARMOURED	COPPER	10 KW	
41		UTILITY POWER GENERATOR BULDING	MCC	UTILITY POWER GENERATOR BULDING	4CX 10mm2	20	600V	0.85	PVC ARMOURED	COPPER	15 KW	
42		FLARE & BURN PIT CONTROL PANEL	MCC	CONTROL PANEL	4CX 2.5mm2	200	600V	0.85	PVC ARMOURED	COPPER	3 KW	
	LCP-0701-I	FLARE PANEL	CONTROL PANEL	FLARE PANEL	3CX 2.5mm2	30	600V	0.85	PVC ARMOURED	COPPER	3	
44		BURN PIT PANEL	CONTROL PANEL	BURN PIT PANEL	3CX 2.5mm2	60	600V	0.85	PVC ARMOURED	COPPER		

45		LIGHTING DISTRIBUTION PAN	NFI	MCC	LIGHT PANEL	5CX 10mm2	20	600V	0.85	PVC ARMOURED	COPPER	15 KW
46		TOWER LIGHT-1 (3 No. 200W light each pole)		LIGHT PANEL	TOWER LIGHT-1	3CX 2.5mm2	340	600V	0.85	PVC ARMOURED	COPPER	0.6 KW
47		TOWER LIGHT-1 (3 No. 200W light each pole)		LIGHT PANEL	TOWER LIGHT-2	3CX 2.5mm2	290	600V	0.85	PVC ARMOURED	COPPER	0.6 KW
		,		LIGHT PANEL LIGHT PANEL	TOWER LIGHT-3	3CX 2.5mm2	230	600V	0.85	PVC ARMOURED	COPPER	
48		`	OWER LIGHT-3 (3 No. 200W light each pole)		TOWER LIGHT-4					PVC ARMOURED	COPPER	0.6 KW
49		TOWER LIGHT-4 (3 No. 200W light each pole) TOWER LIGHT-5 (3 No. 200W light each pole) TOWER LIGHT-6 (3 No. 200W light each pole) PIPE RACK LIGHT-1 (8 No. 100W light) PIPE RACK LIGHT-2(8 No. 100W light)		LIGHT PANEL		3CX 2.5mm2	180	600V	0.85			0.6 KW
50				LIGHT PANEL	TOWER LIGHT-5	3CX 2.5mm2	220	600V	0.85	PVC ARMOURED	COPPER	0.6 KW
51				LIGHT PANEL	TOWER LIGHT-6	3CX 2.5mm2	70	600V	0.85	PVC ARMOURED	COPPER	0.6 KW
52				LIGHT PANEL	PIPE RACK LIGHT-1	3CX 2.5mm2	280	600V	0.85	PVC ARMOURED	COPPER	0.8 KW
53				LIGHT PANEL	PIPE RACK LIGHT-2	3CX 2.5mm2	280	600V	0.85	PVC ARMOURED	COPPER	0.8 KW
54	LDP-1401-I	TRANSFER PUMP SHED LIGHT (2 No.36W each light)		LIGHT PANEL	TRANSFER PUMP SHED	3CX 2.5mm2	230	600V	0.85	PVC ARMOURED	COPPER	0.072 KW
		RECYCLE PUMP SHED LIGHT (2 No.36W each light)			LIGHT	3CX 2.5mm2	200	600V	0.85	DVO ADMOUDED		
55				LIGHT PANEL	RECYCLE PUMP SHED LIGHT					PVC ARMOURED	COPPER	0.072 KW
		DELLIGE VALVE & FOAM TANK CHED LIGHT (2 No. 20M		LICHT DANIEL	DELUGE VALVE & FOAM				 	PVC ARMOURED		
56		DELUGE VALVE & FOAM TANK SHED LIGHT (2 No.36W each light)		LIGHT PANEL	TANK SHED LIGHT	3CX 2.5mm2	200	600V	0.85	PVC ARMOURED	COPPER	0.072 KW
F.7		TEG TOWER LIGHT (2 No. 100W light)		PIPE RACK LIGHT-2	TEG TOWER	20V 2 F2	20	0001/	0.85	PVC ARMOURED	COPPER	0.2 KW
57		TEG TOWER LIGITI (2 No. 100	ovv light)			3CX 2.5mm2	20	600V	0.85	I VC ARWOORLD	COPPER	U.Z KVV
58		AIR-CRAFT WARNING LIGHT	(50W)	LIGHT PANEL	AIR-CRAFT WARNING	3CX 2.5mm2	250	600V	0.85	PVC ARMOURED	COPPER	0.05 KW
		, , ,		LIQUE DANIEL	LIGHT					PVC ARMOURED		
59		LOADING AREA SHED LIGHT (3 No. 200W each light)		LIGHT PANEL	LOADING AREA SHED	3CX 2.5mm2	120	600V	0.85	I VO AKINIOUKED	COPPER	0.4 KW
	D 400 I			1400	LIGHT					DVC ADMOUDED	00000	5104
	R-100-I	GLYCOL REBOILER		MCC	GLYCOL REBOILER	4CX 2.5mm2	260	600V	0.85	PVC ARMOURED	COPPER	5 KW
61	H-100-I	WATER BATH HEATER		MCC	WBH PANEL	4CX 2.5mm2	120	600V	0.85	PVC ARMOURED	COPPER	6 KW
62	02-UPS-1201-I	UPS SYSTEM 1		MCC	UPS-1	3CX 4mm2	130	600V	0.85	PVC ARMOURED	COPPER	6 KVA
	02-UPS-1202-I	UPS SYSTEM 2		MCC	UPS-2	3CX 4mm2	130	600V	0.85	PVC ARMOURED	COPPER	6 KVA
64		UPS-1&2-DB		UPS-1&2	UPS-1&2-DB	3CX 4mm2	10	600V	0.85	PVC ARMOURED	COPPER	
65		DCS PANEL		UPS-1&2-DB	MAIN CONTROL PANEL	3CX 2.5mm2	30	600V	0.85	PVC ARMOURED	COPPER	0.4 KW
66		ENGINEERING STATION		UPS-1&2-DB	ENGINEERING STATION	3CX 2.5mm2	40	600V	0.85	PVC ARMOURED	COPPER	0.4 KW
67		OPERATOR STATION		UPS-1&2-DB	OPERATOR STATION	3CX 2.5mm2	40	600V	0.85	PVC ARMOURED	COPPER	0.4 KW
68		MCC I/O RIO-001		UPS-1&2-DB	REMOTE I/O	3CX 2.5mm2	180	600V	0.85	PVC ARMOURED	COPPER	0.25 KW
69		PLANT MIMIC PANEL		UPS-1&2-DB	PLANT MIMIC BOARD	3CX 2.5mm2	30	600V	0.85	PVC ARMOURED	COPPER	0.2 KW
70	02-UPS-1201 & 2-I	INTERCOM SYSTEM		UPS-1&2-DB	INTERCOM SYSTEM	3CX 2.5mm2	30	600V	0.85	PVC ARMOURED	COPPER	0.05 KW
71	02-0P3-1201 & 2-1	WBH		UPS-1&2-DB	WBH	3CX 2.5mm2	30	600V	0.85	PVC ARMOURED	COPPER	0.2 KW
72		REBOILER		UPS-1&2-DB	REBOILER	3CX 2.5mm2	30	600V	0.85	PVC ARMOURED	COPPER	0.2 KW
73		FLARE CONTROL PANEL		UPS-1&2-DB	FLARE CONTROL PANEL	3CX 2.5mm2	350	600V	0.85	PVC ARMOURED	COPPER	0.2 KW
74		PRINTER		UPS-1&2-DB	PRINTER	3CX 2.5mm2	40	600V	0.85	PVC ARMOURED	COPPER	0.05 KW
75		LASER PRINTER		UPS-1&2-DB	LASER PRINTER	3CX 2.5mm2	40	600V	0.85	PVC ARMOURED	COPPER	0.1 KW
76		UPS-3		UPS-1&2-DB	UPS-3	3CX 2.5mm2	10	600V	0.85	PVC ARMOURED	COPPER	1 KVA
77		FLOW COMPUTER		UPS-1&2-DB	FLOW COMPUTER	3CX 2.5mm2	40	600V	0.85	PVC ARMOURED	COPPER	0.052 KW
78		UPS (FIRE & GAS)		UPS-2	UPS-3	3CX 2.5mm2	10	600V	0.85	PVC ARMOURED	COPPER	1 KVA
79		JPS-3-DB		UPS-3	UPS-3-DB	3CX 2.5mm2	10	600V	0.85	PVC ARMOURED	COPPER	11077
80		FIRE PANEL			FIRE PANEL	3CX 2.5mm2	30	600V	0.85	PVC ARMOURED	COPPER	0.1 KW
81	02-UPS-1203-I	FIRE MIMIC PANEL		UPS-3-DB UPS-3-DB	FIRE MIMIC PANEL	3CX 2.5mm2	30	600V	0.85	PVC ARMOURED	COPPER	0.05 KW
82		ALARM SYSTEM		UPS-3-DB	ALARM SYSTEM	3CX 2.5mm2	30	600V	0.85	PVC ARMOURED	COPPER	0.03 KW
83		POWER SUPPLY		UPS-3-DB	POWER SUPPLY	3CX 2.5mm2	30	600V	0.85	PVC ARMOURED	COPPER	0.2 KW
84		UPS (EMERGENCY LIGHTING)		MCC	UPS-4	3CX 2.5111112	130	600V	0.85	PVC ARMOURED	COPPER	2 KVA
85		,	iivo)	UPS-4	UPS-4-DB	3CX 4/11/12 3CX 2.5mm2	10	600V		PVC ARMOURED	COPPER	∠ N V A
ဝ၁		UPS-4-DB FIRE WATER PUMP SHED LIGHT (2set.72W each light)			FIRE WATER PUMP SHED	SUN Z.DIIIIIZ	10	0007	0.85	PVC ARMOURED	COFFER	
86				LIGHT PANEL	LIGHT	3CX 2.5mm2	200	600V	0.85	I VO ANWOOKED	COPPER	0.072 KW
87	02-UPS-1204-I	CONTROL ROOM		UPS-4-DB	CONTROL ROOM	3CX 2.5mm2	50	600V	0.85	PVC ARMOURED	COPPER	0.4 KW
88		MCC ROOM		UPS-4-DB	ENGINEER ROOM	3CX 2.5mm2	170	600V	0.85	PVC ARMOURED	COPPER	0.16 KW
89		WORKSHOP BUILDING LIGHT		UPS-4-DB	WORKSHOP BUILDING	3CX 2.5mm2	80	600V	0.85	PVC ARMOURED	COPPER	0.10 KW
90		GENERATOR ROOM		UPS-4-DB	GENERATOR ROOM	3CX 2.5mm2	170	600V	0.85	PVC ARMOURED	COPPER	0.24 KW
		SETERATION TO SIVI			<u> </u>		170	000 v	0.00		3311 EIX	J.27 IXVV
Α	2015.10.28	}	ISSUED	FOR APPROVAL						AS	MH	VG
REV	DATE			SCRIPTION			1	1		PREPARED	CHECKED	APPROVED
- \ — V	DAIL		DL				1	1			SHEGILED	/