



LINE MOLEING/PIPE CLEANING

CHECKLIST (Manual)



All team members must understand and practice hand signals for “Turn on Water”, “Pressure Up/OK to begin blasting”, and “Cut Pressure”

Understand pipe size and layout

Safety Devices

Select appropriate backout preventer

Utilize stinger, if necessary – total rigid length of tool assembly should be at least 1.5 diameter of pipe

Test the safety device before pressuring up – pull on the hose to ensure that the tool catches on the backout preventer

Pressurizing the System

Mark the hose conspicuously at 2', 4', and 6' from the tool

Insert the tool at least 24" into the tube before activating the dump

Use **clear hand signals** and maintain line of sight with the pump operator

Signal to the pump operator to pressurize the system, activate the dump until the required pressure is achieved

Test the dump valve before starting to clean



LINE MOLEING/PIPE CLEANING

CHECKLIST (Manual) - CONT.



Pipe Cleaning – Oscillating Technique (Loop and Feed)

- Use proper hand position – hands 24” apart, knuckles facing up, the hand closest to the pipe has a loose grip, allowing the hose to rotate
- The hand further from the pipe turns 180 degrees towards the front hand, into a “palm up” position – achieve oscillation of the hose
- Feed the hose in 12-18” sections, making sure to back flush frequently to avoid blockage or hydraulicing

System Pressure Down

- Release foot pedal to dump pressure
- Signal pump operator to shut down pump, maintaining line of sight with pump operator
- Maintain control of the hose – do not leave unattended until the pump is completely shut down