



TUBE CLEANING

CHECKLIST (Manual)



- ☐ All team members must understand and practice hand signals for “Turn on Water”, “Pressure Up/OK to begin blasting”, and “Cut Pressure”

Safety Devices

- ☐ Select the proper size AWD collet based on the size of the lance – ensure that it will not allow the metallic hose end to pass through the device
- ☐ Ensure AWD is securely in place to prevent accidental withdrawal of lance
- ☐ Use snorkel tube, if necessary, to maintain maximum 1” between tube sheet and hand guard
- ☐ Test the safety device before pressuring up – pull on the lance to ensure that the hose crimp catches on the collet

Pressurizing the System

- ☐ Demonstrate proper placement and operation of the dump valve
- ☐ Insert the lance and nozzle at least 6” into the tube before activating the dump
- ☐ Use **clear hand signals** and maintain line of sight with the pump operator
- ☐ Signal to the pump operator to pressurize the system, activate the dump until the required pressure is achieved
- ☐ Test the dump valve before starting to clean



TUBE CLEANING

CHECKLIST (Manual) – CONT.



Flex Lancing – Oscillating Technique (Loop and Feed)

- ☐ Use proper hand position – hands 24” apart, knuckles facing up, the hand closest to the tube has a loose grip, allowing the lance to rotate
- ☐ The hand further from the tube turns 180 degrees towards the front hand, into a “palm up” position – achieve oscillation of the lance
- ☐ Feed the lance in 12-18” sections, making sure to back flush frequently to avoid blockage or hydraulicing

System Pressure Down

- ☐ Release foot pedal to dump pressure
- ☐ Signal pump operator to shut down pump, maintaining line of sight with pump operator
- ☐ Maintain control of the lance – do not leave unattended until the pump is completely shut down