



TAMIL NADU FIRE AND RESCUE SERVICES

(Under section 13 of the Tamil Nadu Fire Service Act 1985 and

Tamil Nadu Fire Service Rule 1990 - Appendix-III)

Licence No: 1244/FL/NMSB/2025

Dated: 13/05/2025

District Office,
Fire and Rescue Service,
Tiruvallur District.

ISSUE OF FIRE LICENSE

Ref: (1) Letter no: 284324 from the FM INDIA SUPPLY CHAIN PVT LTD Dated: 03/05/2025

The Fire License is hereby granted under section 13 of the Tamil Nadu Fire and Rescue Service Act 1985 for Industrial Logistics park Building In the name of M/s. FM India Supply Chain Pvt. Ltd., (M/s. Jurojin Developers Pvt Ltd.), S.No.26/1, 2, 3, 27/1, 2, 28/1, 2, 3, 4, 5, 6B, 7B, 8B; 29/1, 2, 3, 4, 5B, 30/1, 2, 3, 4, 5, 6, 7A1, 7A2, 7B, 8, 9, 31/1, 37/2B1A, 44/4, in Alinjivakkam village, 34/3A2, 37/2B, 39/1, 2, 40, 41, 42/2, 43/1A1A2, 1A1B, 2B2, 46, 47, 48/1A, 49/2B, Bandikavanoor Village, Ponneri Taluk, Tiruvallur district. Consisting of Ground Floor + Mezzanine Floor only (HIP-4) with the Height of 16.30 Meters and total built-up area in 14623.97 Sq.mt within the jurisdiction of Ponneri based on the inspection was done by the District Officer Thiruvallur on 06/05/2025. Subject to the condition noted thereon and such other conditions as may be prescribed. This licence is valid for **THREE YEARS** from 16/05/2025 to 15/05/2028 and should be renewed on 16/05/2028

CONDITIONS

1. All fire fighting equipment should always be kept in good working condition at all times and it should be as per the NBC 2016 part -IV maintained well and working in good condition. The trained personnel should always be available to operate the systems in case of any emergency.
2. Fire extinguishers should be installed and maintained as per IS 2190:2010
3. The staff should be trained in preliminary fire fighting as per G.O.No:713 Home (Police-17), Dated: 17.08.2005 with Fire and Rescue Services Department.
4. Mock drill should be periodically conducted.
5. Any addition and/or alteration of a permanent or temporary structure should be intimated to the Fire and Rescue Services Department.
6. Fire order / contingency plan / evacuation plan should be prepared and displayed in each floor at prominent places and Dos &Donts boards should be displayed.
7. Emergency fire exit, staircases and doors should not be obstructed.
8. Good housekeeping should be maintained and dumping of waste materials any where should be avoided.
9. All the electrical equipment, fitting, accessories and Wiring system should be maintained as per the Code of Practice for Fire Safety of Building (General) Electrical Installation should be followed.

Signature valid

Signed by: DISTRICT OFFICER

THIRUVALLUR Tiruvallur

Home Department
Date: 16-May-2025 12:03:21



To:

M/s. FM India Supply Chain Pvt. Ltd.,

(M/s. Jurojin Developers Pvt Ltd.,)

Alinjivakkam & Bandikavanoor Village,

Ponneri Taluk,

Tiruvallur district

Signature valid

Signed by: DISTRICT OFFICER
THIRUVALLUR Tiruvallur,
Northwestern Region - District Officer,
Home Department
Date:16-May-2025 12:03:21