

**FORM FOR STABILITY CERTIFICATE
(LETTER BY CONSULTING STRUCTURAL ENGINEER)**

Ref. No.: -

Date: 15 /05 /2025

To,
The Chief Executive Officer,
Pune Metropolitan Regional Development Authority.

Sir,

I have been appointed as consulting structural engineer for preparing structural design and drawings for the **warehouse B02** which is new structure consisting of (Ground + one Mezzanine) floors as described in my enclosed design base report, based upon the architectural drawings and other utilities and services requirements given by the owner/developer of the development work of building B2- at Gat No. 356, 369, 370, 401, 402, 403, 404, 405, 406, 407, 408, 410, Village – Karanj Vihire, Tal. Khed, Dist. Pune.

The following listed firms/persons are associated with the work

Architects: - **Mr. Hrishikesh Kulkarni (VK:a architecture)**
Structural Consultant: - **Shanghvi and Associates Consultants Pvt Ltd**
Owner/Developer: - **Karanje Emerald Logistics Park Pvt. Ltd. through Mr. Tapan Bhatt**
RMK Logistics LLP through Mr. Ramdas M. Kakade.
Site Supervision: - **Knight Frank India Pvt Ltd (PMC)**

We hereby certify that, the RCC sub structure of the above proposal has been designed as per Indian Standard code IS 456-2000, IS 1893-2016(Part-1) for seismic load and IS 875-3:2015 for wind load. Further we certify that, the PEB building design is in accordance with the MBMA-12 (For Loading & Serviceability), ASCE-7-2016 (For Load Combination), AISC-2016 (Code of Standard Practice for Steel building), IS801-1975 (code For Cold form Member Design), IS 1893-2016(Part-1) (For Seismic Load) and IS875-2015 (part-3) (For Wind Load). The steel used in fabrication of the PEB building is in accordance with the ASTM or equivalent specifications; Structural welding is in accordance with the American Welding Society standards ASW D1.1M:2015 specifications.


With reference of above code considering following design Load:

Dead Load	0.12 KN/sqm on Roof + self-weight of Structural frame & 3.7 KN/sqm +1.5 KN/sqm (FF) on mezzanine
Live Load	0.57 kN/sqm; office Mezz =5.0KN/sqm; Staircase = 4KN/sqm
Addition collateral Load	0.20kN/sqm; On column 100 Kg/m for Cable trays
Wind Load	39 m/sec (Load Application as per IS875-2015 (part-3); considered enclosed condition, Cpi factor considered +/- 0.2 and Topographic factor 1)
Seismic Load	As per Zone-III

Based on the above codes, we certify that the structure design is safe & stable



303, Kiran Building-D, Parsi Panchayat Road,
Mogra Village, Andheri (E), Mumbai - 400 069.
Cell : +91 98691 82237
E-mail: jiteshpatel_20@yahoo.co.in




INSTRUCTIONS APPENDED TO THE CERTIFICATE OF STABILITY

1. The structure shall be maintained in good working condition, shall be regularly inspected & any hair crack, bending, tilting, leaning or any eventual appearance in the structural fabrication shall be immediately informed to respective authority for right assessment, decision & suggestion for maintenance of safe structure.
2. All issues related to supervision, materials, workmanship and execution are the sole responsibility of the supervising engineer and visits made by the structural consultants are not for supervision since I am not responsible for supervision and quality of work.
3. Water deposition at plinth level or floor level nearby to R.C.C. or steel column shall be avoided.
4. All structural members shall be protected from acidic material & salinity. Arrangement of acidic effluent drainage shall be maintained properly.
5. Any part of construction whose design is not provided by us, is not covered in above certificate.
6. This Certificate is specifically for the above-mentioned structure and does not cover any other structure like compound wall or any ancillary structure etc.
7. The Validation of the certificate is for a period of 5 years after which the warehouse needs to be inspected again for renewal.

This certificate is issued on the clear understanding that my/ our overall responsibility for the structural stability of the building and its proper structural performance will cease the moment any additions or alterations to the structural frame by accident or due to tampering by the users/ occupants for any reasons whatsoever. My/ our responsibility will also cease in the event of overloading or lack of proper maintenance of structure or any such act, which is detrimental to the structure

This certificate is issued in conjunction with the certificates of the licensed engineer / owner certifying the quality of work.

Signature: -



Name of the Structural Consultant: - **Mr. Jitesh Patel**

Reg. License No. PMRDA/STR.ENG /641/2025-27.



Enclosure,

1. Certificate from licensed engineer / owner towards quality compliance of structural work.

303, Kiran Building-D, Parsi Panchayat Road,
Mogra Village, Andheri (E), Mumbai - 400 069.
Cell : +91 98691 82237
E-mail: jiteshpatel_20@yahoo.co.in

