

SHREE SAI ENTERPRISES

CTS NO – 1119/1, Mangaldeep Apt, Nr Ashok Talkies
Pimpri, Pune, Maharashtra – 411017

STABILITY CERTIFICATE

Date – 22/04/2026

To,

SANT ENTERPRISES,
Plot No 811, Omkar Society, Opp Jain Temple,
Dehugaon, Pune - 412109

Dear Sir,

We assure that we have designed, the structure in accordance with the following specification: IS 800-2007, Code of practice for general construction steel.

We hereby certify that the proposed 20m height + 2mtr Pipe D.G. MS Stack structure of 250 KVA is designed to support the D.G Exhaust Pipe of 200mm. The structure has been designed for a wind velocity of 169.4 km/h for the Pune region, ensuring no compromise to structural stability or safety during its use as a DG Exhaust MS Stack.

This Letter is issued on the clear understanding that overall responsibility for the safety and proper performance of the structure shall not be applicable from the moment client performs any additions and /or alterations in the structure, damage to structural members due to any purpose whatsoever, overloading, lack of maintenance or any act that is detrimental to the structure.

This certificate remains valid for 7 years from the date of issue, and a structural audit is recommended at the end of this period or earlier if any deterioration, modification, or abnormal condition is observed.

For SHREE SAI ENTERPRISES,

Shree Sai Enterprises

Proprietor



CTS NO – 1119/1, Mangaldeep Apt, Nr Ashok Talkies, Pimpri, Pune, Maharashtra – 411017