M/GWASC.1

KNX Gateway

Hardware Version: A

Datasheet

Issued: June 10, 2021

File Edition: B



Figure 1. KNX Gateway




Figure 2. Dimensions - Front View




Figure 3. Dimensions - Side View




Figure 4. Components - Front View Figure 5. Components - Side View

Overview

KNX Gateway (see Figure 1) is a protocol conversion gateway based on KNX Bus communication, and enables data exchange with devices of different protocols.

Its main functions include:

- Device list: control feedback, update status
- Supports scene function: add scenes, *area capture scenes, *movie (dynamic) scenes
- Automation function
- Security function
- Clock: local clock, network clock, automatic synchronization of network time
- System detection, device status reporting: device online status, offline status, device abnormal information
- Drive management of third-party products
- Factory reset function
- Data backup and data recovery function

Protocol and software support:

- Internal communication protocols include: https, tcp, udp, etc., and standard mqtt access to third-party servers also supported
- Support intranet communication, remote access
- Support backup upload and download of APP, Cloud, *SD card, debugging software
- Auxiliary support: KNX Assistance Software, KNX ETS, ON+, Cloud server
- Online upgrade: upgrade gateway online via KNX Assistance Software, or upgrade other Bus devices through this gateway

Note: The functions with * are not yet open for use.

Components and Operation

Dimensions - See Figure 2 - 3
Components - See Figure 4 - 5

1. RS485 connector
2. KNX indicator
3. Network status indicator
4. $RS485_1$ indicator
5. $RS485_2$ indicator
6. *SD card slot: supports up to 32G micro SD card
7. Programming button/indicator: 1) Short press the programming button, the indicator turns red for programming mode. 2) Keep pressing the button for 15 seconds to restore the gateway to factory settings.
8. Auxiliary power supply
9. KNX connector
10. RJ45 port

Note: The functions with * is not yet open for use.

Note(s)

- Installation - Distribution box
- Device management - ETS can program and manage KNX TP1 standard devices through this device.
- KNX Bus voltage - 21~30V DC, no AC power supply allowed.

Safety Precautions

- The installation and testing for the product must be carried out by HDL Automation Co., Ltd. or its appointed service agencies. The electric construction shall comply with local laws and safety regulations.
- The device should be installed with DIN rail in DB box. HDL will not be responsible for any consequence caused by the inexpert or faulty installation and wiring methods, which are not in accordance with the instructions contained in this operating instruction.
- Please do not privately disassemble or replace any parts of the product. Otherwise, it may cause mechanical fault, electric shock, fire or personal injuries.
- Please contact our after-sales departments or our designated service agencies for your maintenance service. Product failures caused by private disassembly are not subject to this warranty.

Package Contents

KNX Gateway*1 / Datasheet*1



Figure 6






Figure 7






Figure 8

Figure 6 - 8. Installation

Technical Data

Basic Parameters	
Working voltage	21~30V DC
Working current	20mA/30V DC
Auxiliary voltage	20~30V DC
Auxiliary current	200mA/24V DC
Communication	KNX, RS485, Ethernet
Interface	KNX connector*1 Auxiliary power supply*1 RS485 connector*2 RJ45 port*1 SD card slot*1
Hardware information	CPU H3@1GHz 4G RAM 8G Flash
Cable diameter of KNX terminal	0.6 - 0.8mm
Operation system	Linux 3.2.0 Kernel
External Environment	
Working temperature	-5℃~45℃
Working relative humidity	≤90%
Storage temperature	-20℃~60℃
Storage relative humidity	≤93%
Specifications	
Dimensions	90×36×63.7 (mm)
Net weight	87g
Housing material	PA66
Installation	35mm DIN rail installation (See Figure 6 - 8)
Protection rating (Compliant with EN 60529)	IP20
Approved	
CE, RoHS	
KNX	

KNX Cable Guide

KNX	KNX cable
-	Black
+	Red

Installation

Installation - See Figure 6 - 8

Step 1. Fix the DIN rail with screws.
Step 2. Buckle the bottom cap of the gateway on the edge of the DIN rail.
Step 3. Press the device on the DIN rail, slide it and fix it up until an appropriate position is adjusted.

ЧТУП "ОллВижн"
г. Минск, ул. Богдановича, 11
Техническая поддержка
+375 29 7 511 611
E-mail: info@allvision.by
Website: https://hdl.by

©Copyright by HDL Automation Co., Ltd. All rights reserved.
Specifications subject to change without notice.