



West Bengal State Electricity Distribution Company Limited
(A Government of West Bengal Enterprise)
OFFICE OF THE DIRECTOR(DIST.)
A -BLOCK, 7TH FLOOR, VIDYUT BHABAN,
BIDHANNAGAR, KOLKATA - 700 091
e-mail: directordistribution708@gmail.com
Tel:(033)2359-1891 . Fax:(033)2334 5607,Website: www.wbsedcl.in

CIRCULAR NO. 120

Dt.06.03.2019.

Sub: Methodology for implementation of HVDS Project.

The basic purpose of HVDS is to shorten the LT line so that combined HT/LT ratio becomes higher in the changed scenario. The following methodology is to be implemented while surveying / execution of HVDS system.

- (a) Install DTRs in load center, shorten LT line.
- (b) Convert the existing/new LT line by AB cable.
- (c) Drawal of HT line to be made by bare conductor as far as practicable but where situation demands HT AB cable may be drawn judiciously.
- (d) New LT line should not be drawn unnecessarily.
- (e) Existing LT line may be bifurcated /shorten as far as possible.
- (f) Only when the peak load of existing DTR exceeds 70% then only additional DTR may be considered.

In case if the existing DTR is not loaded more than 70% then the existing DTR is to be shifted in the load center by drawal of only HT line and the existing LT line to be converted into two nos. LT feeder instead of existing one.

Unnecessary installation of DTR which is not commensurate with above mentioned philosophy should be avoided. Justification of installation of new DTR should be assessed during survey and that should be confirmed by the concerned Station Manager and AE(Tech.). In case of conversion of LT conductor by LT AB cable, SMC box meant for Service Connection to the consumer must be sealed properly as well as to be locked so that in case of any tampering in SMC box that can be visualized. During survey, GPS technology should be adopted by the vendors in such a way that GPS carrying new DTR in tapping point and new LT line to be captured so that the same is to be incorporated in the existing GIS network.

In the above process, number of DTR required obviously will be reduced with the LOA quantity and then agency may be entrusted with other works for which admissible rate will be provided to the vendors.



West Bengal State Electricity Distribution Company Limited

(A Government of West Bengal Enterprise)

OFFICE OF THE DIRECTOR(DIST.)

A-BLOCK, 7TH FLOOR, VIDYUT BHABAN,

BIDHANNAGAR, KOLKATA - 700 091

e-mail: directordistribution708@gmail.com

Tel:(033)2359-1891 . Fax:(033)2334 5607,Website: www.wbsedcl.in

All Divisional Managers are requested to strictly adhere to the above points and take up survey and necessary execution work accordingly.

The above information is to be communicated to all Station Managers and AE(Tech.) so that in every single case of installation of new DTR, concerned Station Manager and AE(Tech.) will sign the document.

The above methodology is also to be communicated to the vendors so that there should not be any confusion between them.


Sd/-
S.K.Dey
Director (Distribution)
WBSEDCL.

Memo No.D/D/41/Project/120/1261(1-34)

Dt.06.03.2019.

Copy to:

1. The Divisional Manager, Habra/ Bongaon / Barrackpore/ Naihati/ Basirhat/ Barasat/ Tarakeswar / Arambag/ Singur/ Chandannagar/ Serampore/ Baruipur/ Behala/ Canning/ Ghatal/Jhargram/ Belda/ Medinipur /Kharagpur/ Rampurhat/ Bolpur/ Suri/ Burdwan Rural/ Memari/Asansole/Kalna (Dist.)Division,WBSEDCL.- **For necessary action as above.**
2. The Regional Manager, 24-Prgs(North)/(South)/Paschim Midnapur Regional Office, WBSEDCL.
3. The Zonal Manager, Burdwan /Kolkata/ Midnapur, (Dist.) Zonal Office,WBSEDCL
4. The Chief Engineer Dist.(Project),WBEDCL.
5. P.S. to CMD,WBSEDCL

 6/3/19
Director (Distribution): WBSEDCL.