

WEST BENGAL STATE ELECTRICITY DISTRIBUTION COMPANY LIMITED

(A GOVERNMENT OF WEST BENGAL ENTERPRISE)

Office of the Chief Engineer (Distribution)

Distribution Head Quarters



Vidyut Bhavan (1st Floor); Block - D; Bidhannagar, Salt Lake, Sector -II; Kolkata-700091

Circular No. - 05

Dated - 15.05.2023

Subject: - Maintaining ground clearance of overhead lines

It has been observed that repairing of roads across the state is taking place time to time and during such repairing works, road level is also elevated by various Govt. and other authorities. This leads to reduction of vertical clearance of the existing overhead electrical network which may lead to electrical accident. Apart from that, there are some old over head lines crossing various roads at different locations where the ground clearance has diminished due to various reasons.

In view of the above, it is enjoined upon all concerned to increase the ground clearance of all the over head lines where the clearance is below the level of maintainable height as per Indian Electricity rule. It is also advised that at the time of such rectification work the vertical clearance should be 1 Meter higher than the minimum clearance maintainable as per Indian Electricity rules for different voltage levels so that sufficient ground clearance is maintained even after elevation of road.

Such type of work should be taken up immediately and must be completed within 15 days.

This should be treated as most urgent.

(S. Mukherjee)

Chief Engineer (Distribution)

WBSEDCL

Memo No. - CED/Circular / 68 (1 to 109)

Dated - 15.05.2023

Copy forwarded to :-

01. Director (Dist.) / (HR) : WBSEDCL , Vidyut Bhavan, Kolkata - 91
02. Chief Engineer : P & E / Safety : WBSEDCL, Vidyut Bhavan, Kolkata - 700091
03. The Zonal Manager : - Kolkata / Burdwan / Midnapore / Berhampore / Siliguri - Zone, WBSEDCL
04. The Regional Manager :
 - Bidhannagar / South 24 Pgs / North 24 Pgs / Howrah / Hooghly / Burdwan / Paschim Burdwan / Birbhum / Paschim Midnapore / Purba Midnapore / Bankura / Purulia / Nadia / Murshidabad / Malda / Darjeeling / Jalpaiguri / Alipurduar / Coochbehar/ Uttar Dinajpur / Dakshin Dinajpur Region, WBSEDCL

WEST BENGAL STATE ELECTRICITY DISTRIBUTION COMPANY LIMITED

(A GOVERNMENT OF WEST BENGAL ENTERPRISE)



Office of the Chief Engineer (Distribution)
Distribution Head Quarters

WBSEDCL

Vidyut Bhavan (1st Floor); Block – D; Bidhannagar, Salt Lake, Sector –II; Kolkata-700091

05. The Divisional Manager :

- Alipurduar / Arambagh / Asansol / Baduria / Bankura / Barrackpore / Barasat / Baruipur / Basirhat / Behala / Berhampore / Bidhannagar-I / Bidhannagar- II / Bishnupur / Bongaon / Bolpur / Belda / Bhangar / Burdwan North / Burdwan South / Buniadpur / Canning / Chandannagar / Contai / Coochbehar / Dakshin Dinajpur / Darjeeling / Diamond Harbour / Dinhata / Domkal / Durgapur / Egra / Garia / Ghatal / Habra / Haldia / Howrah-I/ Howrah- II /Islampur /Jalpaiguri /Jhargram/ Jiaganj/Joynagar/ Kakdwip/ Kalna/ Kalyani/ Kandi/ Katwa/ Kharagpur/ Krishnanagar/ Khatra / Kurseong / Kalimpong /Mal/ Memari/ Midnapur / Mogra/Mathabhanga / Naihati/ Nakashipara/ North Malda/Newtown/ Purulia/ Raghunathpur / Raghunathganj/ Rampurhat /Raiganj/Ranaghat/ Serampore/ Singur-Haripal/South Malda/Suri/ Siliguri Town/ Siliguri Suburban/ Tamluk/ Tarakeswar/ Tehatta / Uluberia Division, WBSEDCL

06. P.S. to Chairman & Managing Director, WBSEDCL