



WEST BENGAL STATE ELECTRICITY DISTRIBUTION COMPANY LIMITED

(A Government of West Bengal Enterprises)

REGISTERED OFFICE: BIDYUT BHAWAN, SALT LAKE, BLOCK: DJ, SECTOR-II, KOLKATA - 700 091

CIN- U40109WB2007SGC113473, Web site: www.wbsedcl.in

WBSEDCL

Circular No. 06

Date: 10/04/2019

Expectation level of the consumers in the every corners of the state is increasing day by day after electrification of all the towns and villages. Now they need more better quality of power supply as our service is improving gradually. Interruption free best quality power supply is our motto by strengthening & standardization of distribution networks with introduction of latest updated technology. It will help us to manage the distribution network more efficiently and our organization will be economically more viable. So following modifications of existing network / Sub-Station are needed to handle the distribution network more easiest way.

1. Drawal of 11 KV 1C X 1000 sq mm XLPE Cable for each phase from 11 KV cable support structure of 10/6.3 MVA PTR to 11 KV Incomer Switchgear panel instead of double run 11 KV 3C X 300 sq mm XLPE Cable.
2. For all 11 KV Outgoing feeders, 11 KV 3C X 300 sq mm XLPE Cable to be used.
3. For all 33 KV Feeder, 3C X 400 sq mm XLPE Cable to be used.
4. LT AB cable of size 70 sq mm to be used, other size of LT AB Cable will be discarded.
5. Sealing of Cable entry box of indoor panels are to be done by Plaster of Paris.
6. For 315 KVA & above rating of DTR, single core LT Cables to be drawn from DTR secondary to feeder pillar Box / LT Kiosk instead of 4C LT Cable.

DTR Rating	1.1 KV Cable to be considered from DTR secondary to Feeder Pillar Box / LT Kiosk
315 KVA, 11/0.415 KV	Single Run - 4 X 1C X 630 sq mm XLPE
630 KVA, 11/0.415 KV	Double Run - 4 X 1C X 630 sq mm XLPE

All concerned are requested to follow the above mentioned instruction scrupulously for preparation of any scheme henceforth.

Sd/-

(S. P. Moitra)

Chief Engineer (Distribution)

WBSEDCL



WEST BENGAL STATE ELECTRICITY DISTRIBUTION COMPANY LIMITED

(A Government of West Bengal Enterprises)

REGISTERED OFFICE: BIDYUT BHAWAN, SALT LAKE, BLOCK: DJ, SECTOR-II, KOLKATA - 700 091
CIN- U40109WB2007SGC113473, Web site: www.wbsedcl.in

WBSEDCL

Memo No. CED/Technical Circular/ 351(1-113)

Date: 10/04/2019

Distribution

1. The Chief Engineer, P&E / P&C / DTD / DPD / Project-II / Project-III / Commercial / Regulation, WBSEDCL.
2. The Zonal Manager: Kolkata/ Burdwan/ Midnapore/ Berhampore/ Siliguri Zone, WBSEDCL.
3. The Regional Managers: Bidhannagar/ North 24 Parganas/ South 24 Parganas/ Howrah/ Bankura/ Purulia/ PurbaMidnapur/ PaschimMidnapur/ Birbhum/ Hooghly/ Burdwan/ Jalpaiguri/ Darjeeling/ Raiganj/ Coochbehar/Alipurduar/ DakshinDinajpur(Balurghat) / Malda/ Murshidabad / Nadia Region, WBSEDCL.
4. The Divisional Managers: Alipurduar/ Arambagh/Asansol/ Bankura/ Barrackpore/ Barasat/ Baruipur/ Basirhat/ Behala/ Berhampore/ Bidhannagar-I /Bidhannagar- II /Bishnupur / Bongaon/ Bolpur/ Belda / Burdwan Urban / Burdwan Rural/ Buniadpur / Canning / Chandannagar / Contai/ Coochbehar / DakshinDinajpur /Darjeeling/ Diamond Harbour / Domkal/ Durgapur/ Egra/ Garia/ Ghatal/ Habra/ Haldia/ Howrah-I/ Howrah- II /Islampur /Jalpaiguri /Jhargram/ Jiaganj/ Kakdwip/ Kalna/ Kalyani/ Kandi/ Katwa/ Kharagpur/ Krishnanagar/ Khatra / Kurseong / Kalimpong /Mal/ Memari/ Midnapur / Mogra/ Naihati/ Nakasipara/ North Malda/ Purulia/ Raghunathpur / Raghunathganj/ Rampurhat /Raiganj/ Serampore/ Singur-Haripal/South Malda/ Mathabhanga /Suri/ Siliguri Town/ Siliguri Suburban/ Tamluk/ Tarakeswar/ Tehatta / Uluberia (D) Division, WBSEDCL.
5. PS to CMD, WBSEDCL.
6. PS to Director (Distribution) / Director (Project) / Director (Finance), WBSEDCL.


Chief Engineer (Distribution)
WBSEDCL