

Dtr. (Dist) / LR / 4053
DL 9.6.25

Government of West Bengal
Department of Power

CMD/P / 77
- 5 JUN 2025

3/C, LA-Block, Sector-III, Bidyut Unnayan Bhawan 5th Floor, Salt Lake,
Kolkata 700 106

No.881-POW-C-IV-Estt.

Date : 05.06.2025

From : The Assistant Secretary,
Department of Power.

To :
✓ 1. CMD, WBSEDCL
2. CMD, WBPDC
3. MD, WBSETCL
4. MD, DPL
5. Chief Electrical Inspector, Directorate of Electricity
6. MD (G&D), CESC

All Dis.


All ZM, RM, DM
+ ED(Dist), CE(Dist-S)
CE(Dist-N)


Sub : Circulation of Gazette Notification as detailed below.

Sir,

I have been directed to forward the following Notifications (copy enclosed) as communication to your office for information and necessary action.

1. No.445-PO/O/C-IV/1E-06/12 dated 21.03.2025.
2. No.465-Pow-16011/3/2019 dated 25.03.2025.
3. No.542-PO/O/C-IV/1E-29/2024 dated 09.04.2025.
4. No.826-PO/O/C-IV/1E-06/12 dated 28.05.2025.

Encl. As stated above

Yours faithfully


Assistant Secretary to the
Government of West Bengal

No. 881/1(4)-POW-C-IV-Estt.

Date :05.06.2025

Copy forwarded for information and necessary action to the :

1. Advisor Hydro
2. Law Officer, Deptt. of Power.
3. SSP.
4. Office Copy


Assistant Secretary
Government of West Bengal

The

Kolkata Gazette
सत्यमेव जयते

Extraordinary
Published by Authority

JYAISTHA 8]

THURSDAY, MAY 29, 2025

[SAKA 1947

PART I—Orders and Notifications by the Governor of West Bengal, the High Court, Government Treasury, etc.

GOVERNMENT OF WEST BENGAL

Department of Power
Bidyut Unnayan Bhawan,
3/C, LA-Block, Sector-III, Saltlake, Kolkata-700 106

No. 445-PO/O/C-IV/1E-06/12

Date : 21.03.2025

NOTIFICATION

In exercise of the powers conferred under Sub-section (1) of Section 162 of the Electricity Act, 2003, read with clause (zu) of Regulation 2 (1) of the Central Electricity Authority (Measures relating to Safety & Electric Supply) Regulations, 2023, the undersigned is directed by order of the Governor to specify that the notified voltage for the purpose of self-certification under Regulation 32 and Regulation 45 of the said Regulations shall be 11 kV.

This suppresses the previous Notification of this Department bearing No.562/PO/C-IV/1E-06/12 dated 07.07.2017 and Notification No.429/PO/C-IV/1E-06/12 dated 19.03.2025, conforming to the Central Electricity Authority (Measures Relating to Safety and Electric Supply) 2023.

By order of the Governor,

ANJAN CHAKRABARTI
Special Secretary to the Government of West Bengal

The

Kolkata **Gazette**
सत्यमेव जयते

Extraordinary
Published by Authority

JYAISTHA 8]

THURSDAY, MAY 29, 2025

[SAKA 1947

PART I—Orders and Notifications by the Governor of West Bengal, the High Court, Government Treasury, etc.

GOVERNMENT OF WEST BENGAL

Department of Power

Bidyut Unnayan Bhawan,

3/C, LA-Block, Sector-III, Saltlake, Kolkata-700 106

No. 826-PO/O/C-IV/1E-06/12

Date : 28.05.2025

NOTIFICATION

In continuation of the earlier notification of this Department bearing no. 445/PO/O/C-IV/1E-06/12 dated 21.03.2025; it is to further notify that:

1. For self-certification up to the Notified Voltage, i.e. 11 kV, duly filled up Form-III of Schedule -II of Central Electricity Authority (Measures relating to Safety & Electric Supply) Regulations, 2023, signed by the owner of the installation and certified by the Chartered Electrical Safety Engineer/Graduate Electrical Engineer with National Electrical Supervisory Competence Certificate/Graduate Electrical Engineer with Energy Audit Certificate issued by BEE, Government of India, to be submitted to the Electrical Inspector. The self-certified electrical installation shall be considered fit for the commencement of supply or recommencement after shutdown for six months only after the report of self-certification is duly received by the office of Electrical Inspector and if not acknowledged by the Electrical Inspector within three working days, it shall be deemed to be received.
2. Notwithstanding anything contained above, as per Regulation 45 (1) (b), every electrical installation covered under section 54 of the Electricity Act, 2003, i.e. (a) in any street having 250 watt & 100 volts or, (b) in any place (i) in which one hundred or more persons are ordinarily likely to be assembled or, (ii) which is a factory within the meaning of the Factories Act, 1948 shall be inspected and tested by the Electrical Inspector and as per Regulation No. 32 (4), every installations covered under section 54 of the Electricity Act, 2003, shall be periodically inspected and tested by the Electrical Inspector.

By order of the Governor,

ANJAN CHAKRABARTI

Special Secretary to the Government of West Bengal