

Self Certified Installation Certificate

To

The Station Manager/ Regional Manager/ Chief Engineer Commercial,

.....

.....

Sub: Submission of Self Certified Installation Certificate.

Ref: Application No.: dated.....

Dear Sir / Madam,

This is in reference to my above application for installation of GIRSPV system I /We hereby confirm you that I /We have completed the work of installation of the GIRSPV system of capacity.....and submit the following basic information for your perusal and request you to inspect and commission the system.

Sl. No.	Particulars	Information
A.	Details of the Solar PV Module	
1.	Type of Module	Polycrystalline/ Mono-crystalline/TOPCon/HJT/ Any other Crystalline Technology
2.	Name and address of manufacturer	
3.	Capacity of each Module (Wp)	
4.	No. of Modules (attach Serial Nos.)	
5.	Total Capacity (kWp)	
6.	Date of Installation	
7.	Applicable Standard (BIS/IEC)	IEC 61215 / IS 14286, IEC 61730(Part I & II), IEC 62804
B.	Details of the Inverter	
8.	Name and address of the Inverter manufacturer	
9.	Brand Name of the Inverter	
10.	Serial Nos. of inverters installed	
11.	AC Capacity of individual Inverter (kW)	
12.	Cumulative AC capacity of Inverters (kW)	
13.	Current THD at full load & Voltage THD-less than 3%	YES/NO
14.	Ingress Protection Limit	

15.	Date of Installation	
16.	Applicable Standard (BIS/IEC)	IEC-62109(Part I & II), IEC-60068, IEC-61683, IEC 61000, IEC 62116, IEC 61727
C.	Details of the DC Cables	
17.	Make / Name of manufacturer	
18.	Size & Type	
19.	Applicable Standard (IEC)	IS 17293
D.	Details of the AC Cables	
20.	Make / Name of manufacturer	
21.	Size & Type	
22.	Applicable Standard (IS/IEC)	IS 7098 (Part-I & II)/IS 1554/IS 694
E.	Details of the Array Junction Box(AJB)	
23.	Make / Name of manufacturer	
24.	Serial No.	
25.	DC Surge Protection Device	
26.	MCB / Isolator quantity & capacity	
27.	Size & Type	
28.	Applicable Standard (IEC)	IEC 61643 –Surge Protection Device, IEC 60529- Ingress Protection
F.	Details of the AC Distribution Box/Inverter Interfacing Panel	
29.	Make / Name of manufacturer	
30.	Serial No.	
31.	AC Surge Protection Device	
32.	MCB / MCCB quantity & capacity	
33.	Size & Type	
34.	Applicable Standard (IEC)	IEC 61643 - Surge Protection Device, IEC 60898 - MCB
G.	Details of the Earthing *	
35.	Earth resistance (shall be less than 2 ohms)	
36.	Size of the Earth wire / flat*	
37.	Two separate Earthing points: Module Mounting Structure & DC Surge Protection Device	Yes / No
	Inverter, AC Surge Protection Device & Lightening	Yes / No

	Arrester	
38.	Size & Type	
39.	Applicable Standard (BIS / IEC)	IS 3043
	Note: * Earthing shall be done in accordance IS 3043-1986, provided that Earthing conductors shall have a minimum size of 6 mm ² copper wire or 10 mm ² aluminum wire or 3 mm ² X 70 mm ² hot dip galvanized steel flat.	
H.	Details of the Caution signage	
40.	Caution Signage	IS 2551
I.	Provision of manual and automatic switches: Yes / No	
41.	Manual / Automatic Switches	
J.	G.P.S. Co-ordinates of the RTSPV System Installation	
42.	Latitude / Longitude	
K.	Operation and Maintenance	
43.	Whether Operation and Maintenance Manual provided to the consumer: Yes / No	

Standards Certificate / Standard Number BIS / IEC / etc. to be mentioned, wherever applicable.

Certification:

I / We certify that the above said GIRSPV system is installed and the equipment used in the system comply the Technical and Safety Standards as specified in the regulations notified by the Respective Authorities.

Signature of the Applicant

Name and Address

Name:.....

.....

.....

Date:.....

Enclosures:

1. Copy of test report of PV modules, Inverter, Cable etc as per procedure 3.5.
2. Data sheets / Drawing for the array mounting System.
3. Actual Single line wiring diagram (SLD) of the GIRSPV System.