



West Bengal State Electricity Distribution Company Limited

(A Government of West Bengal Enterprise)

ওয়েস্ট বেঙ্গল স্টেট ইলেকট্রিসিটি ডিস্ট্রিবিউশন কোম্পানী লিমিটেড
(পশ্চিমবঙ্গ সরকারের একটি উদ্যোগ)

CIN no: U04109WB2007SGC113473

Website: www.wbsedcl.in

Telefax: +913323210963

email: corp.safety@wbsedcl.in

VidyutBhavan

06th Floor, A - Block,

Salt Lake City, Kolkata 700 091

Office Order no: 04.....

dated 08/06/2021

Towards minimization of Accidents due to Unsafe Conditions in WBSEDCL's system & Unsafe Act of Technical Workforce, an Action Plan has been formulated. The Plan comprises of Long Term measure as well as Short Term & Continuous measures for concerned area of System, synopsis of which is detailed below.

A. LONG TERM MEASURE

Serial No	Brief Description of the unsafe Condition	Target Timeline
A	Conductor snapping & Loose Sag.	For survey & estimate: By August'2021 Steps: Replacement of conductor, reduction of span length, trimming of tree branches etc. Procurement & Implementation: By Feb'2022
B	Dual/ multiple source in a single structure.	For survey & estimate: By August'2021 Steps: Increase of clearance, fixing of box bracket, creation of Dead Span, fixing of Signage etc. Procurement & Implementation: By March'2022
C	Prevention of unnatural death of Wild life due to Electrocutation.	For survey & estimate: By August'2021 Steps: Enhancement of ground clearance, strengthening of pole with concrete and suitable stay wire, reduction of span length, barbed wire around the poles, AB Cable etc. Procurement & Implementation: By March'2022
D	Unsafe DTR installation.	For survey & estimate: By August'2021 Steps: Replacement of broken isolator handle, proper height of isolator, proper gap between contacts and proper isolation of isolator, proper earthing etc. Procurement & Implementation: By March'2022
E	Single switchgear operating two or more outgoing feeders.	For survey & estimate: By 31 st August'2021 Steps: Repair/ replacement of the defective gear, arrangement of new breaker installation etc. Procurement & Implementation: By March'2022

B. SHORT TERM & CONTINUOUS MEASURE

Serial No	Brief Description of the unsafe Condition / act:	Target Timeline
A	Leaning of poles & lowering of conductor /damaged PCC poles/ existence of wooden poles/ improper earthing of LA at UG Cable	For survey & estimate: By 30thSept'2021 Steps: Re-installation of stay, re-sagging, replacement of wooden poles & wooden brackets, corrective measure for leaning

		poles etc. Procurement & Implementation: By Jan'2022
B	Cradle Guard/ Tie Guard Crossing point / Fixing of spacers	For survey & estimate: By 30th Sept'2021 Steps: Fixing of cradle guard & spacers, reduce unnecessary sagging, proper clearance i.r.o. feeder crossing etc. Procurement & Implementation: By Jan'2022
C	Diversion of one outgoing feeder to another Substation due to emergency/ load diversion.	Implementation by 31 st December'2021 Steps: Fixing of proper signage at location, proper communication must be ensured etc.
D	Malfunctioning of 33KV DBCR/ TPGO Isolator at Substation & 11KV Isolator at DTR.	For survey & estimate: By 30th Sept'2021 Steps: Adjustment or replacement of defective contact & handle of isolator etc. Procurement & Implementation: By Jan'2022
E	Missing of feeder identification & non availability of requisite number of Shut down/ Break down/ Feeder diversion boards at some of the 33 KV Substations.	Positively by Sept'2021
F	Non-availability of switching instruction at Substation	Positively by Sept'2021
G	Safety Meeting at Division & Zonal Level.	Immediate Action.
H	Non availability/ nonuse of proper PPEs by Technical work force for HT & LT network	Immediate Action
I	Improper/ insufficient documentation at Substation / CCCs.	Immediate Action
J	Routine and Surprise visit at worksite during any execution for observance of SOP and availability and use of PPEs.	Immediate Action

**C. CONTINUOUS MEASURES FOR GENERATION OF AWARENESS AMONG
GENERAL PUBLIC AND TECHNICAL WORKFORCE & SAFETY TRAINING**

Serial No	Brief Description of the unsafe Condition / act:	Target Timeline
A	Safety Awareness Programme for General Public.	At least one programme in every month at each Division.
B	Safety Awareness Programme for Technical Workers	At least one bi-monthly programme at each Division.
C	Safety Training Programme for Technical Workers	In addition to Scheduled Training as per prevailing Training calendar, a special drive of at least one Safety Training to be imparted to those Technical Workers, who are yet to receive any Training so far, by March'2022

The detailed Action Plan with time frame & Implementing Authority is appended.

Since the plan is relating to up keeping and maintenance of our distribution network in good condition the main responsibility of implementation of the **Safety Action Plan** vests with the Distribution wing along with necessary support from the Project wing. Under this situation **Chief Engineer (Distribution)** is requested to follow up for its proper implementation on a regular basis out of his existing resources, which may be reviewed subsequently in PRT Meeting.

Besides that **Training wing** has a very effective part in the **Action Plan** which may be implemented by them in rigorous manner.

This is for information and necessary action by all concerned in the Distribution set up. Safety wing is responsible for close follow up of the plan in consultation with the Zonal Manager and Regional Managers on regular basis and provide input/support as may be required from time to time.

A quarterly compiled report on the progress of implementation of the Action Plan to be submitted by the Zonal Authority to Corporate Safety Cell with endorsement to the Director: Distribution and Chief Engineer: Distribution for review in the PRT Meeting.

Enclosed: As stated


(Sujay Sarkar)
Director: HR

Memo no: Safety/5/2021/ 32 (r-9)

Dated: 08/06/2021

Distribution:

1. The Chairman & Managing Director, WBSEDCL.
2. The Director: Distribution/ Finance, WBSEDCL.
3. The Legal Advisor, WBSEDCL.
4. The Chief Engineer: Distribution/ Procurement, WBSEDCL.
5. The General Manager: (HR&A), WBSEDCL.
6. The General Manager: HRD & Training Department, WBSEDCL – for advice to the Principal of all EETI & Training Institute at Kalyani, Nadia for their information & necessary action.
7. The Zonal Manager/ Sr. Manager (HR&A): all Zones, WBSEDCL.
8. The Regional Manager/ HR&A Officer: all Regions, WBSEDCL.
9. The Divisional Manager: all Divisions, WBSEDCL – for guidance & circulation to Assistant Engineer: Technical/ Station Manager/ Assistant Manager (HR&A) under his jurisdiction for immediate action.