



West Bengal State Electricity Distribution Company Limited

(A Government of West Bengal Enterprise)

CIN no: U04109WB2007SGC113473

Website: www.wbsedcl.in

email: ce.corpsafetycell@gmail.com

Corporate Safety Cell

Vidyut Bhavan
05th Floor, B - Block,
Salt Lake City, Kolkata-91

Circular No.: 02/2022
Date: 03.11.2022

(Amended Circular in replacement of prevailing Circular No. 05/2011 dated 01.03.2011 & 01/2022 dated 03.06.2022)

Sub: Specification, quantity and other parameters of PPEs for observing safety norms

To ensure availability & use of sufficient number of PPEs, following yardstick is to be followed scrupulously by site in-charges. This yardstick is equally applicable to any workforce during erection, repair, operation & maintenance works in WBSEDCL's distribution network including substations. Precisely, following yardstick is for the workforce of WBSEDCL as well as the workforce of agencies engaged by WBSEDCL for erection, repair, operation & maintenance work.

Fire Extinguisher for 33/11/6.6 kV Substations:

33 kV substations are prone to fire hazard like electrical fire from electrical installations, fire from flammable oil of transformer, OCB etc. and also fire of solid combustible materials. Considering the above type of fire hazards, the following types of fire extinguishers along with sand bucket suitable to combat fire at 33/11/6.6 kV substation are suggested.

Sl. No.	Type of Fire Extinguisher	Portable type (Capacity)	Required No.
1.	Carbon dioxide (CO ₂) type (BC) IS:15683:2006	Preferable 4.5 kg	02
2.	Dry Chemical Powder(BC)/ABC Dry Powder type IS:15683:2006	Preferable 5.0 kg	02
3.	Mechanical Foam Type (AB) IS:15683:2006	9.0 litre	01
4.	Water (Gas Cartridge) Type (A) IS : 940 / Water (Stored Pressure) Type IS: 15683:2006	9.0 litre	01 To be kept at left side of the main entrance of the control room.
5.	Clean Agent Fire Extinguisher (Stored Pressure) Type IS: 15683:2006	2.0 kg	01
5.	Sand bucket with Stand IS: 2546	9.0 litre	Four(4) Buckets are to be kept under shed by the side of each entrance gate coming from Switch Yard to Control Room.

Note :

- Fire Extinguisher shall be placed on supporting wall or in cabinets in such a way that their bottom should be 750 mm to 1000 mm above the floor level.



- iii. All firefighting equipments shall be subjected to routine maintenance, inspection and testing with record.
- iv. All employees/employees of Agency should be conversant with the operation & use of Fire Extinguisher.
- v. Items under SI. No. 1, 2 & 3 are to be kept hanging at easy accessible wall in front of the switch gear & panel.
- vi. Items under SI. No. 3 & 4 are to be used at "Power off" position.
- vii. Operation of all such kits be made by departmental employees and by the contractor's employees wherever it is out sourced. A training shall be organized by the Divisional Manager concerned.

Fire Extinguisher for various Office Establishments including CCCs:

The office establishments including CCCs are exposed to fire hazard like electrical fire from electrical wiring, involving electrical equipment and delicate equipment, i.e., Computer and its accessories, AC machine, Xerox machine etc. and also fire from solid combustible materials. Considering the above type of fire hazard, the following types of fire extinguishers are suggested to combat fire.

SI. No.	Type of Fire Extinguisher	Portable type (Capacity)	Required No.
1.	Carbon dioxide (CO ₂) type IS:15683:2006 *Most suitable for "B", "C" type & "Electrical" fire.	Preferable 4.5 kg	03 nos. per 1000 sq. ft. floor area *The extinguishers shall be placed in conspicuous locations over the entire floor area especially at cash, collection kiosk, computer etc. and shall be readily accessible for immediate use at the time of emergency.
2.	Water (Gas Cartridge) Type IS:940 / Water (Stored Pressure) Type IS: 15683:2006 * Not suitable for "electrical" fire until make it dead/de-energized from source. Most suitable for "A" type fire.	9.0 litre	Total 02 nos. in any Office Establishment * To be kept at any side of the main entrance to the Office under covered & protected area and shall be readily available at the time of emergency.

Note:

- i. Fire Extinguisher shall be mounted on supporting wall or in cabinets in such a way that their bottom should be 750 mm to 1000 mm above the floor level
- ii. All extinguishers to be re-filled immediately after discharge
- iii. All firefighting equipment shall be subjected to routine maintenance, inspection and testing with record which shall be earned out by properly trained person.
- iv. All employees / employees of agency should be conversant with the operation & use of Fire Extinguisher.



Personal Protective Equipments for Technical Staff/ agency workers to be used during various works at Distribution Network:

Sl No.	Equipment / Accessories	Short Specification	Requisite Quantity to be kept at each worksite	To be provided and maintained by	Remarks
1	Industrial Safety Belt	IS:3521 & all its amendments compliant Full body harness with waist belt, fall arrest attachment and other accessories	60% of total workforce per worksite	For hired workforce of any Agency: to be provided & maintained by the Agency.	To be used till in serviceable condition and to be replaced immediately with new ones after loss of serviceability
2	Industrial Safety Helmet	IS:2925 compliant Helmet with head strap & chin strap fittings	100% of total workforce per worksite	Else, WBSEDCL authority shall provide & maintain these items	
3	Hand Gloves(pair)	IS:4770 compliant rubber gloves for electrical purpose suitable for 11 kV system	100% of total workforce per worksite		
4	Gum Boot(Pair)	Made of rubber	30% of total technical workforce per worksite and 100% operational workforce at 33/11/6.6 kV substation.		
5	Discharge cum Earthing Rod	For working up to 11 kV: Highly insulated FRP Telescopic type with 3 sections & self locking arrangement, total length >= 5.5 M; Aluminum C Clamp at top, Crocodile Clip for earthing; >=12 M 10 sqmm PVC insulated Cu cable. For working upto 33 kV: Highly insulated Epoxy resin Telescopic type with 3 sections & self locking arrangement, total length >= 5.5 M; Aluminium C Clamp at top, Crocodile Clip for earthing; >=15 M 10 sqmm PVC insulated Cu cable.	Two sets with inter phase shorting arrangement at each worksite		
6	Earth Spike(GI)	As per standard specification	Two spikes at each worksite		



Sl No.	Equipment / Accessories	Short Specification	Requisite Quantity to be kept at each worksite	To be provided and maintained by	Remarks
7	Bamboo Ladder	Made of matured seasoned bamboo; Steps of ladder shall be guarded by GI wire binding.	One for each worksite	For hired workforce of any Agency: to be provided & maintained by the Agency.	To be used till in serviceable condition and to be replaced immediately with new ones after loss of serviceability
8	Lifting Rope	High quality nylon rope	6 bundles for each worksite	Else, WBSEDCL authority shall provide & maintain these items	
9	High Voltage Detector	Technical Specification available in www.wbsedcl.in	One at each worksite (shall be at each substation and each LT & HT mobile van)		
10	Traffic Cone with Nylon Rope & Caution/Danger board	Cone: PVC made Cone with florescent strip and logo of WBSEDCL; Height :2'6" Rope: Yellow Color ½" Diameter Nylon Rope	As per Memo No. Safety/01/192 dated 13.12.2021 of the Director(HR)	Both for hired workforce of agencies and WBSEDCL's own workforce, these items are to be provided by WBSEDCL authority	Memo No. Safety/1/242 dated 21.02.2022 of Director(HR)
11	Safety Vest	As per Memo No. Safety/01/123 dated 31.08.2021 of Dir(HR)	100% of total workforce per worksite		Memo No. Safety/01/192 dated 13.12.2021 of the Director(HR)
12	First Aid Box	One bottle potassium permanganate crystal, 12 no. of roller & triangular bandage, sterilized cotton wool, one bottle mercurochrome(2%) solution in water, aspirin tablet, burn gel with burn-dressing, scissor, Dettol	One set per worksite	For hired workforce of any Agency: to be provided & maintained by the Agency. Else, WBSEDCL authority shall provide & maintain this item.	Memo No. Safety/01/123 dated 31.08.2021 of Dir(HR)

West Bengal State Electricity Distribution Company Limited

(A Government of West Bengal Enterprise)

ওয়েস্ট বেঙ্গল স্টেট ইলেক্ট্রিসিটি ডিস্ট্রিবিউশন কোম্পানী লিমিটেড
(পশ্চিমবঙ্গ সরকারের একটি উদ্যোগ)

Telefax: +913323210963
email: ce.corpsafetycell@gmail.com

CIN no: U04109WB2007SGC113473
Website: www.wbsedcl.in

Vidyut Bhavan
05th Floor, B - Block,
Salt Lake City, Kolkata 700 091

Distribution:-

Dated:- 03.11.22

Memo No.: Safety/ 44/211(1-156)

1. The Chief Engineer: Safety /Dist./ IT/ Dist. Planning/ R.E./ DPD/ Proj-II/ Proj-III/ Commercial/ Hydrel/ EMD/ PTP/ Regulation/ CRM/ P&C/ DTD/ PIDD/ PSPD/ PPSP/ Turga/ R&EM/ Solar/ Hydrel Constrn./ Communication/ Corp. Monitoring, WBSEDCL
2. The General Manager (HR&A), WBSEDCL
3. The Zonal Manager: Kolkata/Burdwan/Berhampore/Medinipur/Siliguri Zone, WBSEDCL
4. The Regional Manager: South 24 Pgnos./ Bidhannagar/ Howrah/ North 24 Pgnos./ Birbhum/ Purba Burdwan/ Paschim Burdwan/ Hooghly/ Purba Medinipur/ Paschim Medinipur/ Purulia/ Bankura/ Nadia/ Murshidabad/ Malda/ Uttar Dinajpur/ Dakshin Dinajpur/ Darjeeling/ Jalpaiguri/ Coochbehar/ Alipurduar Region, WBSEDCL
5. The Project Manager: Barasat/ Baruipur/ Diamond Harbour/ Suri/ Burdwan/ Howrah-Hooghly/ Paschim Medinipur/ Purba Medinipur/ Bankura/ Purulia/ Malda/ Murshidabad/ Nadia/ Coochbehar/ Siliguri/ Raiganj/ Balurghat/ Jalpaiguri R.E. Project, WBSEDCL
6. The Divisional Manager: All Divisions, WBSEDCL
7. The Manager (F&A), E-C, WBSEDCL
8. The P.S. to CMD/Director(HR)/ Director(Dist.)/ Director(R&T)/ Director(Project)/ Director(Generation)/Executive Director (IT)/ Executive Director (Commercial), WBSEDCL