



Certificate of Compliance

This certificate is issued for the following:

Steel Pipe for Automatic Fire Sprinkler Systems

Product	Listing Country	Nominal Pipe Size, in.	Rated Working Pressure, psi	Rated Working Pressure, kPa	Certification Type
Schedule 10 ^{a, d, m, q}	China	1, 1-1/4, 1-1/2, 2, 2-1/2, 3, 4, 5, 6	300	2070	FM Approved
Schedule 10 ^{a, d, m, q}	China	8, 10, 12	225	1550	FM Approved

Notes:

- a - FM Approved for use with FM Approved pipe couplings on rolled grooves.
- d - When hot dip galvanized by factory, the sprinkler pipe is FM Approved for dry pipe systems.
- m - FM Approved for use in all steel sprinkler systems composed of uncoated steel pipe.
- q - Manufactured out of ASTM A795 / A795M Grade B steel

Prepared for: Tianjin Youfa International Trade Co Ltd, RM 1502-1509, 15F, NO. 4 Anshun Building
Dafeng Road, Hongqiao District, Tianjin City, China 300120

FM Approvals Class: 1630 – “Steel Pipe for Automatic Fire Sprinkler Systems”

Approval Identification: 3064021

Approval Granted: March 9, 2018

To verify the availability of the Approved product, please refer to www.approvalguide.com

Said Approval is subject to satisfactory field performance, continuing Surveillance Audits, and strict conformity to the constructions as shown in the Approval Guide, an online resource of FM Approvals.

A handwritten signature in black ink, reading "David B. Fuller".

David B. Fuller
VP, Manager – Fire Protection

FM Approvals
1151 Boston-Providence Turnpike
Norwood, MA 02062
USA



Member of the FM Global Group



Certificate of Compliance

This certificate is issued for the following:

Steel Pipe for Automatic Fire Sprinkler Systems

Product	Listing Country	Nominal Pipe Size, in.	Rated Working Pressure, psi	Rated Working Pressure, kPa	Certification Type
Schedule 40 ^{a, b, d, e, m, q}	China	1, 1-1/4, 1-1/2, 2, 2-1/2, 3, 4, 5, 6	300	2070	FM Approved
Schedule 40 ^{a, b, d, e, m, q}	China	8, 10, 12	225	1550	FM Approved

Notes: a - FM Approved for use with FM Approved pipe couplings on rolled grooves.
b - FM Approved for use with FM Approved pipe fittings when threaded.
d - When hot dip galvanized by factory, the sprinkler pipe is FM Approved for dry pipe systems.
e - Any FM Approved pipe coupling or fitting suitable for use with Schedule 10 pipe may be used with this product at the lower rated pressure of the pipe or the fitting.
m - FM Approved for use in all steel sprinkler systems composed of uncoated steel pipe.
q - Manufactured out of ASTM A53 / A53M Grade B steel

Prepared for: Tianjin Youfa International Trade Co Ltd, RM 1502-1509, 15F, NO. 4 Anshun Building
Dafeng Road, Hongqiao District, Tianjin City, China 300120


FM Approvals Class: 1630 – “Steel Pipe for Automatic Fire Sprinkler Systems”

Approval Identification: 3064021

Approval Granted: March 9, 2018

To verify the availability of the Approved product, please refer to www.approvalguide.com

Said Approval is subject to satisfactory field performance, continuing Surveillance Audits, and strict conformity to the constructions as shown in the Approval Guide, an online resource of FM Approvals.



David B. Fuller
VP, Manager – Fire Protection

FM Approvals
1151 Boston-Providence Turnpike
Norwood, MA 02062
USA

