

CERTIFICATE OF COMPLIANCE

Certificate Number 20170131-EX27390
Report Reference EX27390-20170104
Issue Date 2017-JANUARY-31

Issued to: TIANJIN YOUFA INTERNATIONAL TRADE CO.,LTD
RM 1502~1509, 15F, NO. 4 Anshun Building
Dafeng Road (Aqua City), Hongqiao Distr.
300120 Tianjin, CHINA

**This is to certify that
representative samples of**

Metallic Sprinkler Pipe

Schedule 10 steel sprinkler pipe in the 1, 1-1/4, 1-1/2, 2, 2-1/2, 3, 4, 5, 6, 8 and 10 in sizes, as per ASTM A795, Grade B, Type E.

Schedule 40 steel sprinkler pipe in the 1, 1-1/4, 1-1/2, 2, 2-1/2, 3, 4, 5, 6, 8, 10 and 12 in sizes, as per ASTM A53, Grade B, Type E

Have been investigated by UL in accordance with the Standard(s) indicated on this Certificate.

Standard(s) for Safety:

UL 852 - Metallic Sprinkler Pipe for Fire Protection Service
ULC/ORD C199S - Light Wall Steel Pipes for Sprinkler Systems for Fire Protection Service

Additional Information:

See the UL Online Certifications Directory at www.ul.com/database for additional information

Only those products bearing the UL Certification Mark should be considered as being covered by UL's Certification and Follow-Up Service.

Look for the UL Certification Mark on the product.



Bruce Mahrenholz, Director North American Certification Program

UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact a local UL Customer Service Representative at <http://ul.com/aboutul/locations/>

