



Certificate of Compliance

This certificate is issued for the following:

Indicating Butterfly Valves

Model VBG12121 and VBG12C121

Sizes 2, 2-1/2, 3, 4, 5, 6, 8 and 10 inch NPS

76.1, 139.7 and 165.1 mm

Rated Working Pressure: 300 psi (2070 kPa)

Prepared For:

FlowCom Mechanical Technology Co., Ltd.
Unit 2-801, No. 2388 Xiupu Rd
Pudong, Shanghai 201315
People's Republic of China

Manufactured at:

FlowCom Mechanical Technology Co., Ltd.
3988 Dongjing Rd, Qingzhou Economy Development Zone
Weifang, Shandong Province 262500
People's Republic of China

FM Approvals Class: 1112, dated August 2006

Approval Identification: 3059666
PR452444

Approval Granted: November 8, 2017
September 6, 2019

To verify the availability of the Approved product, please refer to www.approvalguide.com

Said Approval is subject to satisfactory field performance, continuing Surveillance Audits, and strict conformity to the constructions as shown in the Approval Guide, an online resource of FM Approvals.

David B. Fuller
VP – Manager, Fire Protection
FM Approvals
1151 Boston-Providence Turnpike
Norwood, MA 02062 USA





Certificate of Compliance

This certificate is issued for the following:

Indicating Butterfly Valves

Model VBG12121 and VBG12C121
Sizes 2-1/2, 3, 4, 5, 6, 8 and 10 inch NPS
76.1, 139.7 and 165.1 mm

Model VBW12121 and VBW12C121
Sizes 2-1/2, 3, 4, 5, 6 and 8 inch NPS

Rated Working Pressure: 300 psi (2070 kPa)

Prepared For:

FlowCom Mechanical Technology Co., Ltd.
Unit 2-801, No. 2388 Xiupu Rd
Pudong, Shanghai 201315
People's Republic of China

Manufactured at:

FlowCom Mechanical Technology Co., Ltd.
3988 Dongjing Rd, Qingzhou Economy Development Zone
Weifang, Shandong Province 262500
People's Republic of China

FM Approvals Class: 1112, dated August 2006

Approval Identification: 0003059666

Approval Granted: November 8, 2017

To verify the availability of the Approved product, please refer to www.approvalguide.com

Said Approval is subject to satisfactory field performance, continuing Surveillance Audits, and strict conformity to the constructions as shown in the Approval Guide, an online resource of FM Approvals.

A handwritten signature in black ink, appearing to read "D.B. Fuller".

David B. Fuller
VP – Manager, Fire Protection
FM Approvals
1151 Boston-Providence Turnpike
Norwood, MA 02062 USA

