



GLOBAL FLUX S.A.S.

TIANJIN BAOLAI FORTUNE TRADE CO.,LTD

ADDRESS: 04, 9TH FLOOR, NINGTAI PLAZA, NO.1 XIAGUANG ROAD,

NANKAI DISTRICT, TIANJIN, CHINA

MILL TEST CERTIFICATES

GLOBAL FLUX S.A.S.

SOLUCIONES PARA FLUIDOS

www.globalflux.com.co

REF NO: BLHJYP088C

DATE OF ISSUE: 5/Nov/2025

GOODS: ERW FIRE PIPES

SPECIFICATION: ASTM A795

INVOICE NO.HJYP088-GLOBAL

HEAT NO.	SIZE						CHEMICAL COMPOSITION (%)														TENSION TEST			PRESSURE	FLATTENING /BENDING TEST	NON-DESTRUCTIVE TEST	VISUAL DIMENSION
	SIZE MM	SIZE IN	W.T. SCH	LENGTH (M)	AMOUNT PCS	THEORETICAL WEIGHT (MT)	C	Mn	Si	P	S	Cu	Ni	V	Ti	Cr	Mo	Ni+V	Ni+V+Ti	Ce	T.S.	Y.P.	E.L.				
																					Mpa	Mpa	(%)				
4A-08996	33.4	1"	SCH40	5.80	40	0.580	0.28	0.98	0.13	0.011	0.014	0.006	0.004	0.005	0.004	0.007	0.005	0.009	0.013	0.163	423	245	30	700	G	G	G
4C-09165	48.3	1-1/2"	SCH10	5.80	300	5.411	0.27	1.02	0.14	0.014	0.008	0.005	0.004	0.006	0.004	0.007	0.005	0.01	0.014	0.154	428	245	32	1000	G	G	G
4C-09165	60.3	2"	SCH10	5.80	300	6.838	0.27	1.07	0.12	0.014	0.015	0.005	0.004	0.007	0.006	0.007	0.005	0.011	0.017	0.169	438	248	30	1000	G	G	G
4B-08194	73	2-1/2"	SCH10	5.80	300	9.152	0.27	1.15	0.11	0.015	0.009	0.005	0.003	0.008	0.003	0.008	0.004	0.011	0.014	0.144	443	254	31	1000	G	G	G
4B-08194	88.9	3"	SCH10	5.80	260	9.742	0.27	1.13	0.13	0.015	0.015	0.005	0.003	0.005	0.004	0.009	0.004	0.008	0.012	0.148	433	254	30	1000	G	G	G

COATING TEST (EPOXY POWDER)

Coating thickness ≥100μm	TEST ITEM	Cure time,min (232°C±3°C)		Gel time, s (205°C±3°C)		Paricle size //150μm,%		Paricle size //250μm,%		Thermal characteristics //Tg1, °C (20°C/min, N2)		Thermal characteristics //Tg2, °C (20°C/min, N2)		Thermal characteristics ΔH, J/g (20°C/min, N2)	
105	TEST METHOD	CSA Z245.20-2018/12.1		CSA Z245.20-2018/12.2		CSA Z245.20-2018/12.5		CSA Z245.20-2018/12.5		CSA Z245.20-2018/12.7		CSA Z245.20-2018/12.7		CSA Z245.20-2018/12.7	
	TEST RESULT	0.5	G	14.90	G	0.46	G	0	G	63.9	G	101.2	G	42.4	G
TEST ITEM	Bending resistance (-30°C±3°C)	Abrasive resistance (CS-17, 1000g/1000r)		Chemical Resistance (PH2.5~3.0) (20°C±3°C, 90d)		Density, g/cm ³		Cathodic Disbondment, mm (24h,65°C±3°C, - 3.5±0.15V,3%NaCl, Saturated calomel reference electrode)		Adhesion, Rating (24h, 75°C±3°C)		Moisture content of the epoxy powder-Mass loss (105°C±3°C,2h)			
TEST METHOD	SY/T4113.3-2019	GB/T 1768-2006		SY/T4113.9-2020		CSA Z245.20-2018/12.6		CSA Z245.20-2018/12.8		CSA Z245.20-2018/12.14		CSA Z245.20-2018/12.4			
TEST RESULT	G	69	G	G	G	1.466	G	1.1	ERRTT	1	G	0.38	G	G	G

WE HEREBY CERTIFY THAT :

1. THE MATERIAL HEREIN HAS BEEN TESTED IN ACCORDANCE WITH ABOVE SPECIFICATIONS AND THE RESULTS OF ALL TESTS ARE ACCEPTABLE.

2. TESTING RESULTS SHOWED THAT THE COAT WAS EXCELLENT IN ABRASION RESISTANCE, CORROSION RESISTANCE,STAIN RESISTANCE AND SLIP RESISTANCE.

3. UNDER NORMAL CIRCUMSTANCES, THE LIFE OF THE GOODS IS 15 YEARS.

SIGNATURE



Typed by: 贾莹莹

Approved by

张立

Date 2024-11-05