



Certificate of Compliance

This certificate is issued for the following:

Automatic Sprinklers for Fire Protection

Model	K	Type	Resp.	Element	NPT (in.)	Finishes	Temperature Ratings °F (°C)
FW1205	5.6	HSW	SR	5 mm	½	Brass, Chrome, Polyester	135, 155, 175, 200, 286 (57, 68, 79, 93, 141)
FW2205	5.6	HSW	QR	3 mm	½	Brass, Chrome, Polyester	135, 155, 175, 200, 286 (57, 68, 79, 93, 141)
FW1005	5.6	SSU	SR	5 mm	½	Brass, Chrome, Polyester	135, 155, 175, 200, 286 (57, 68, 79, 93, 141)
FW2005	5.6	SSU	QR	3 mm	½	Brass, Chrome, Polyester	135, 155, 175, 200, 286 (57, 68, 79, 93, 141)
FW1105	5.6	SSP	SR	5 mm	½	Brass, Chrome	135, 155, 175, 200, 286 (57, 68, 79, 93, 141)
FW2105	5.6	SSP	QR	3 mm	½	Brass, Chrome	135, 155, 175, 200, 286 (57, 68, 79, 93, 141)

Prepared for:

FlowCom Mechanical Technology Co Ltd
Unit 2-801, No. 2388, Xiupu Rd
Pudong, Shanghai 201315
China

Approval Standard: FM 2000 (February 2018)

Approval Identification: PR469489

Approval Granted: 19 June 2024

To verify the availability of the Approved product, please refer to www.approvalguide.com

Said Approval is subject to satisfactory field performance, continuing Surveillance Audits, and strict conformity to the constructions as shown in the Approval Guide, an online resource of FM Approvals.

David B. Fuller
VP, Manager – Fire Protection
FM Approvals
One Technology Way
Norwood, MA 02062

