

UL Product iQ®



# VNIV.EX28079 - Sprinklers, Automatic and Open

## Sprinklers, Automatic and Open

See General Information for Sprinklers, Automatic and Open

### FLOWCOM MECHANICAL TECHNOLOGY (SHANGHAI) CO LTD

EX28079

Unit 2-801, No. 2388 Xiupu Road,  
Pudong

201315 Shanghai, CHINA

Sprinkler Identification Number (SIN) FW1205, FW2205, FW1005, FW2005, FW1105, FW2105, and FW1305 Glass Bulb Type.

### UPRIGHT AND PENDENT STANDARD-SPRAY SPRINKLERS

#### NOMINAL 5.6 K-FACTOR

| SIN    | Response Type | Type    | System Working Pressure, psig | Temp Rating, °F |
|--------|---------------|---------|-------------------------------|-----------------|
| FW1005 | SR            | Upright | 175                           | 135, 155, 175   |
| FW2005 | QR            | Upright | 175                           | 155             |
| FW1105 | SR            | Pendent | 175                           | 135, 155, 175   |
| FW2105 | QR            | Pendent | 175                           | 155             |

### STANDARD SIDEWALL-SPRAY SPRINKLERS

| SIN      | Response Type | Type       | Nom K-Factor | System Working Pressure, psig | Temp Rating, °F |
|----------|---------------|------------|--------------|-------------------------------|-----------------|
| FW1205*# | SR            | Horizontal | 5.6          | 175                           | 155             |
| FW2205*# | QR            | Horizontal | 5.6          | 175                           | 155             |

\* - Installed 4 to 12 in. below ceiling.

# - For ordinary hazard occupancies.

### CONVENTIONAL (OLD STYLE) SPRINKLERS

| SIN    | Response Type | Nom K-Factor | Temp Rating, °F |
|--------|---------------|--------------|-----------------|
| FW1305 | SR            | 5.6          | 155             |

Trademark and/or Tradename: "FLO"

Last Updated on 2019-06-05

The appearance of a company's name or product in this database does not in itself assure that products so identified have been manufactured under UL Solutions' Follow - Up Service. Only those products bearing the UL Mark should be considered to be Certified and covered under UL Solutions' Follow - Up Service. Always look for the Mark on the product.

UL Solutions permits the reproduction of the material contained in Product iQ subject to the following conditions: 1. The Guide Information, Assemblies, Constructions, Designs, Systems, and/or Certifications (files) must be presented in their entirety and in a non-misleading manner, without any manipulation of the data (or drawings). 2. The statement "Reprinted from Product iQ with permission from UL Solutions" must appear adjacent to the extracted material. In addition, the reprinted material must include a copyright notice in the following format: "©2022 UL LLC."