

CERTIFICATE OF COMPLIANCE

Certificate Number EX15868
Report Reference EX15868-20130819
Date 2021-December-27

Issued to: FLOWCOM MECHANICAL TECHNOLOGY (SHANGHAI)
CO LTD
Unit 2-801, No. 2388 Xiupu Road,
Pudong
Shanghai 201315 CN

This is to certify that
representative samples of

BUTTERFLY VALVES
See Addendum Page for Product Designation(s).

Have been investigated by UL in accordance with the
Standard(s) indicated on this Certificate.

Standard(s) for Safety: UL 1091 -Standard for Butterfly Valves for Fire Protection
Service
ULC/ORD-C1091-74- Preliminary Standard for Butterfly
Valves for Fire Protection Service

Additional Information: See the UL Online Certifications Directory at
<https://iq.ulprospector.com> for additional information

This Certificate of Compliance does not provide authorization to apply the UL Mark. Only the UL Follow-Up
Services Procedure provides authorization to apply the UL Mark.

Only those products bearing the UL Mark should be considered as being UL Certified and covered under UL's
Follow-Up Services.

Look for the UL Certification Mark on the product.



Bruce Mahrenholz, Director North American Certification Program
UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please
contact a local UL Customer Service Representative at <http://ul.com/aboutul/locations/>



CERTIFICATE OF COMPLIANCE

Certificate Number EX15868
Report Reference EX15868-20130819
Date 2021-December-27

This is to certify that representative samples of the product as specified on this certificate were tested according to the current UL requirements

Model VBG01 and VBG01C coated ductile iron body butterfly valves in 2, 2.5, 3, 4, 6, 8, 10, 12, 15, 16, 18, 20, 24, 30, 36, 42, 48, 60, 72, 96, 120, 144, 168, 192, 216, 240, 288, 324, 360, 408, 456, 504, 576, 648, 720, 800, 900, 1000, 1100, 1200, 1300, 1400, 1500, 1600, 1800, 2000, 2200, 2400, 2600, 2800, 3000, 3200, 3400, 3600, 3800, 4000, 4200, 4400, 4600, 4800, 5000, 5200, 5400, 5600, 5800, 6000, 6200, 6400, 6600, 6800, 7000, 7200, 7400, 7600, 7800, 8000, 8200, 8400, 8600, 8800, 9000, 9200, 9400, 9600, 9800, 10000 mm nominal sizes.

Model VBG01C and Model VBG01 are identical except the Model VBG01 is supervised open and Model VBG01C is supervised closed.

Model VBG12121 and VBG12C121 are the same as current listed model VBG01 and VBG01C separately except a new coating and new gear boxes applied.

Model VBG12121 and VBG12C121 are identical except the Model VBG12121 is supervised open while Model VBG12C121 is supervised closed.

Model VBG03121 and VBG03C121 are the same as current listed model VBG12121 and VBG12C121 separately except two tapping boss were added to valve body.

Model VBG03121 and VBG03C121 are identical except the Model VBG03121 is supervised open while Model VBG03C121 is supervised closed

Model VBG12121H and VBG12C121H are the same as model VBG12121 and VBG12C121 separately except end configuration is Wafer type, While Model VBG12121 and VBG12C121 have groove connection.

Model VBG12121H and VBG12C121H are the same model VBG12121 and VBG12C121 separately except a little modification on valve disc which caused a higher pressure rating, 363 psi.

Model VBG12121H and VBG12C121H are identical except the Model VBG12121H is supervised open while Model VBG12C121H is supervised closed.

Model VBG13121H and VBG13C121H are the same model VBG12121H and VBG12C121H separately except two tapping boss were added to valve body and little changes on lower stem and upper flange.

Model VBG13121H and VBG13C121H are identical except the Model VBG13121H is supervised open while Model VBG13C121H is supervised closed.

Model VBG12121H and VBG12C121H are the same as model VBG12121H and VBG12C121H separately except end configuration is Wafer type, While Model VBG12121H and VBG12C121H have groove connection.



Bruce Mahrenholz, Director North American Certification Program

UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact a local UL Customer Service Representative at <http://ul.com/aboutul/locations/>



CERTIFICATE OF COMPLIANCE

Certificate Number EX15868
Report Reference EX15868-20130819
Date 2021-December-27

Model VBG01, VBG01C, VBG12121, VBG12C121, VBW12121 and VBW12C121 are rated 300 psi, model VBG12121H, VBG12C121H, VBW12121 and VBW12C121 are rated 363 psi. All these models incorporate internal supervisory tamper switches intended for indoor/outdoor use.

The valve body is constructed of ductile iron material conforming to ASTM A 395, Grade 60-40-18.

The disc is made of ductile iron (ASTM A 395) and encapsulated with EPDM rubber material.

The upper and lower stems are constructed of stainless steel material conforming to ASTM A 276, Type 420.



B. Mahlen

Bruce Mahrenholz, Director North American Certification Program

UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact a local UL Customer Service Representative at <http://ul.com/aboutul/locations/>