

CERTIFICATE OF COMPLIANCE

Certificate Number EX15738
Report Reference EX15738-20110727
Issue Date 2020-AUGUST-28

Issued to: FLOWCOM MECHANICAL TECHNOLOGY (SHANGHAI)
CO LTD
Unit 2-801, No. 2388 Xiupu Road, Pudong, Shanghai,
201315 CHINA

**This certificate confirms that
representative samples of**

HANGERS, PIPE
See addendum page for Models/Product

Have been investigated by UL in accordance with the
Standard(s) indicated on this Certificate.

Standard(s) for Safety: UL 203- Pipe Hanger Equipment for Fire Protection Service
Additional Information: See the UL Online Certifications Directory at
<https://iq.ulprospector.com> for additional information.

This *Certificate of Compliance* does not provide authorization to apply the UL Mark. Only the UL Follow-Up Services Procedure provides authorization to apply the UL Mark.

Only those products bearing the UL Mark should be considered as being UL Certified and covered under UL's Follow-Up Services.

Look for the UL Certification Mark on the product.



Bruce Mahrenholz, Director North American Certification Program
UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact a local UL Customer Service Representative at <http://ul.com/aboutul/locations/>



CERTIFICATE OF COMPLIANCE

Certificate Number EX15738
Report Reference EX15738-20110727
Issue Date 2020-AUGUST-28

This is to certify that representative samples of the product as specified on this certificate were tested according to the current UL requirements.

Model	Hanger Type	Rod Size	NPS+	Comments
SH01	Band Hanger	3/8 in, M10	1/2, 3/4, 1, 1-1/4, 1-1/2, 2, 2-1/2, 3, 3-1/2, 4	-
SH01	Band Hanger	1/2 in, M12	5, 6, 8	-
SH02	Band Hanger	3/8 in, M10	1/2, 3/4, 1, 1-1/4, 1-1/2, 2, 2-1/2, 3, 3-1/2, 4	—
SH02	Band Hanger	1/2 in., M12	5, 6, 8	-
SH03	Band Hanger	1/2 in., M12	2, 2-1/2, 3, 3-1/2	-
SH03	Band Hanger	5/8 in., M16	4, 5	-
SH03	Band Hanger	3/4 in., M20	6	-
SH03	Band Hanger	7/8 in., M22	8	-
BC01	Universal Beam Clamp	3/8 in, M10	Up to 4	-
BC01	Universal Beam Clamp	1/2 in, M12	Up to 8	-
CH01	Clevis	3/8 in, M10	1/2, 3/4, 1, 1-1/4, 1-1/2, 2	-
CH01	Clevis	1/2 in, M12	2-1/2, 3	-
CH01	Clevis	5/8 in, M16	4, 5	-
CH01	Clevis	3/4 in, M20	6, 8	-
CH02	Clevis Hanger	3/8 in, M10	1/2, 3/4, 1, 1-1/4, 1-1/2, 2,	—
CH02	Clevis Hanger	1/2 in, M12	2-1/2, 3, 4, 5	—
CH02	Clevis Hanger	5/8 in, M16	6, 8	—
RC01	Riser Clamp	N/A	1/2, 3/4, 1, 1-1/4, 1-1/2, 2, 2-1/2, 3, 3-1/2, 4, 5, 6, 8, 10, 12	—
SP01	Pipe Clamp	3/8 in, M10	1/2, 3/4, 1, 1-1/4, 1-1/2, 2, 2-1/2, 3, 3-1/2	—
SP01	Pipe Clamp	1/2 in, M12	4, 5, 6	—
SP01	Pipe Clamp	5/8 in, M16	8	—
SR01	Surge Restrainer	N/A	1/2, 3/4, 1, 1-1/4, 1-1/2, 2	Use with SH01 and SH02
UB01	U-Bolt	N/A	1/2, 3/4, 1, 1-1/4, 1-1/2, 2, 2-1/2, 3, 4, 5, 6, 8, 10, 12	U-Orientation
UB01	U-Bolt	N/A	76.1 mm, 84 mm, 93 mm, 99 mm, 103 mm, 111 mm, 119 mm, 123 mm, 127 mm, 137 mm, 139.7 mm, 143 mm, 149 mm, 161 mm, 165.1 mm, 173 mm, 192 mm, 215 mm, 245 mm, 270 mm, 296 mm	U-Orientation

Note: +NPS – Nominal Pipe Size

B. Mahlen

Bruce Mahlenholz, Director North American Certification Program

UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact a local UL Customer Service Representative at <http://ul.com/aboutul/locations/>

