NATIONAL ELECTRICITY

GRID CODE

REPUBLIC OF GHANA

October, 2009

The Transmission Utility shall notify the System Operator if
(a) the system frequency has deviated from the nominal value of 50 Hz by more than 0.2 Hz or otherwise contrary to the limits

An unrelated paragraph about metering that has no frequency content at all.