ELECTRICITY SUPPLY AND DISTRIBUTION (STANDARDS OF PERFORMANCE) REGULATIONS, 2008

Voltage levels

8. (1) Subject to regulation 21(1), a supplier shall ensure that the voltage at the point of supply to a customer's premises or electrical installation is within plus or minus ten percent of the following voltage levels: (a) 230 Volts; (b) 400 Volts; (c) 11 Kilovolts; (d) 33 Kilovolts; or (e) 34.5 Kilovolts.

(2) A supplier shall achieve the voltage levels specified in regulation 8 (1) within the period specified in the Electricity Supply (Technical and Operational) Rules, 2005 (LI 1816).

Date of Gazette notification: 13th June, 2008