

State Load Despatch Center, Airoli (MSETCL) Statement I
Daily system Report for 05/Aug/2026 WEDNESDAY

I GENERATION (MUs)			II EXCHANGES (MUs)		
A) MSPGCL	Daily	Monthly	E) InterState Exchanges	Daily	Monthly
1) Thermal	140.591	666.898	1) Gujrat	1.366	-5.927
2) Hydro	13.779	73.822	2) Madhya Pradesh	5.665	17.519
3) Gas	6.668	32.797	3) Chattisgarh	0.810	8.510
Total MSPGCL	161.038	773.517	4) Maharashtra	187.748	852.853
B) 1) APLM	48.680	231.895	5) Goa (Amona)	-1.363	-7.226
2) JSWEL	23.408	114.088	Total	194.226	865.729
3) VIPL	9.664	48.353	a) Mumbai Schedule	44.410	216.454
4) RPL(AMT)	23.576	116.666	b) Mumbai Drawl	47.735	228.967
5) SWPGPL	8.593	47.277	c) MSEDCL Bilateral *	136.128	644.768
6) Other IPP	12.559	59.447	Include PX	0.000	0.000
7) PGPL	0.000	0.000	d) Mumbai Bilateral *	44.410	216.454
C) 1) TPCL Thermal	10.966	55.479	Include PX	0.000	0.000
2) TPCL Hydro	4.792	22.882	Standby	0.000	0.000
3) TPCL Gas	3.360	16.184	H) ENERGY CATERED (MUs)		
4) AEML Thermal	8.431	44.448	1) MSEDCL	479.687	2309.235
D) STATE			2) Mumbai Discoms	75.284	367.960
1) Thermal	286.468	1384.551	3) Other Discoms	13.794	68.108
(A1+C1+C4+(B1-B6))			TOTAL STATE	568.765	2745.303
2) Hydro	18.571	96.704			
(A2+C2)					
3) Gas	10.028	48.981			
(A3+B7+C3)					
4) Wind	34.634	231.672			
6) SOLAR	24.838	117.666			
TOTAL STATE	374.539	1879.574			

* Displayed for information, not added in total.

DETAILS OF MAHARASHTRA STATE PEAK DEMAND(MW) Statement II

PARTICULARS	A. Morning Peak at 9 Hrs	B. Day Peak at 18 Hrs	C. Evening Peak at 20 Hrs	D. Night Minimum at 4 Hrs
MSPGCL Thermal	5803	5582	6562	6152
MSPGCL Hydro	395	489	1070	322
MSPGCL Gas	274	277	280	279
MSPGCL Total Generation	6472	6348	7912	6753
Central Sector Receipt	9951	9218	9057	6719
WIND	1222	1795	1609	1174
CPP / IPP Thermal	5195	4542	6222	5716
CPP / IPP Gas	0	0	0	0
SOLAR	1735	915	0	0
Exchange with Mumbai	-2275	-2355	-1820	-1260
MSEDCL DEMAND MET	21714	19848	22370	18633
Load Shedding	0	0	0	0
MSEDCL DEMAND	21714	19848	22370	18633
TPCL GENERATION	595	827	1185	642
AEML GENERATION	270	323	467	410
MUMBAI DEMAND	3140	3505	3472	2312
OTHER DISCOM DEMAND	586	615	610	469
STATE DEMAND MET	25440	23968	26452	21414
STATE DEMAND	25440	23968	26452	21414
Frequency (Hz)	50.11	50.02	50.01	50.02

FREQUENCY PARTICULARS

MAXIMUM FREQ.	MINIMUM FREQ.	AVERAGE FREQ.	FREQ. BELOW 49.4 Hz
50.29 Hz at 08.57 Hrs	49.73 Hz at 05.09 Hrs	50	0 % of Time(min)

Note : The report is based on Operational Data and is for statistical purpose only.

Daily and Progressive Generation,Maximum,Minimum for 05/Aug/2026

Generating unit	Generation			
	Daily (Mus)	Monthly (Mus)	Max (MW)	Min (MW)
Koradi				
Unit 6	3.14	14.71	157	100
Unit 8	10.84	55.13	542	371
Unit 9	11.08	53.26	520	366
Unit 10	10.94	52.88	495	400
Total	36.00	175.99		
Bhusawal				
Unit 3	3.26	15.92	165	115
Unit 4	0.02	25.67	15	0
Unit 5	0.00	0.00	0	0
Unit 6	12.17	58.52	611	367
Total	15.44	100.11		
Parli				
Unit 6	3.68	15.23	206	0
Unit 7	3.79	17.65	189	144
Unit 8	3.89	19.18	181	143
Total	11.35	52.05		
Chandrapur				
Unit 3	2.73	12.40	125	93
Unit 4	2.32	10.48	113	82
Unit 5	8.30	37.57	390	300
Unit 6	8.04	38.14	405	280
Unit 7	0.00	0.00	0	0
Unit 8	8.52	41.44	450	295
Unit 9	8.56	41.07	430	280
Total	38.48	181.09		
Paras				
Unit 3	4.14	18.89	203	150
Unit 4	4.24	19.15	232	130
Total	8.38	38.04		
Khaparkheda				
Unit 1	2.79	14.36	160	105
Unit 2	2.92	5.00	167	100
Unit 3	2.87	15.51	168	88
Unit 4	3.32	16.88	180	127
Unit 5	10.17	32.97	490	300
Total	22.07	84.71		
Nasik				
Unit 3	3.03	13.86	140	110
Unit 4	2.98	15.52	146	100
Unit 5	2.86	5.52	140	107
Total	8.87	34.90		
Uran				
All Units	6.67	32.80	281	274
Total	6.67	32.80		
PGPL				
Unit 1	0.00	0.00	0	0
Unit 2	0.00	0.00	0	0
Total	0.00	0.00		
PENCH (MS)				
Pench (MS)	0.07	0.92	20	0
Total	0.07	0.92		
Koyna				

Generating unit	Generation			
	Daily (Mus)	Monthly (Mus)	Max (MW)	Min (MW)
Stage 1-2	2.74	12.70	560	40
Stage 4	1.16	12.52	250	0
Stage 3	1.71	7.90	160	0
Total	5.60	33.11		
Hydro				
KDPH	0.43	2.16	18	18
VTRNA	0.58	2.90	60	0
TILLARI	0.52	2.53	61	0
BHIRA T.R.	0.45	2.21	80	0
SMLHY_PTN	5.56	27.35	238	222
GHATGHAR	0.63	3.55	125	0
Total	8.18	40.71		
Wind				
Total	34.63	231.67	0	0
Total	34.63	231.67		
CPP				
APML(Mus)	48.68	231.90	0	0
JSWEL(Mus)	23.41	114.09	0	0
VIPL(Mus)	9.66	48.35	0	0
RPLAMT-Mus	23.58	116.67	0	0
SWPGPL-Mus	8.59	47.28	0	0
Dhariwal	0.00	0.00	0	0
IEPL	4.56	21.29	216	149
Other(Mus)	1.64	8.25	0	0
JPL	5.48	25.27	274	146
VMEPL	0.00	0.00	0	0
LMEL	0.88	4.64	44	27
Total	126.48	617.73		
SOLAR				
Total	24.84	117.67	0	0
Total	24.84	117.67		
Tata				
Trombay 5	7.22	36.45	478	253
Trombay 6	0.00	0.00	0	0
Trombay 7A	2.03	9.67	108	58
Trombay 7B	1.33	6.51	63	47
TATA Hydro	4.79	22.88	395	80
Trombay 8	3.75	19.03	228	129
Total	19.12	94.54		
AEML				
DTPS U-1&2	8.43	44.45	475	269
Total	8.43	44.45		

* Infirm Power			Summary			Summary		
Particulars	Daily (Mus)	Monthly	Particulars	Daily (Mus)	Monthly (Mus)	Particulars	Daily (Mus)	Monthly (Mus)
			MSPGCL Thermal	140.59	666.90	MSPGCL Total	161.04	773.52
			MSPGCL Thml+Gas	147.26	699.70	Koyna 1,2 & 4 Total	3.90	25.21
			MSPGCL Hydro	13.78	73.82	State Total	374.54	1879.57

State Load Despatch Center,Airoli (MSETCL)

Annexure-2

Hourly Load Data As on 05/Aug/2026

TIME SR. NO.	MSPGCL GEN.			TOTAL	WIND	CPP / IPP		SOLAR	CS SHARE	CS RECPT	Mum. NET EXCH.	MSEDC L DEM. MET	Load Shedding		MSEDC L DEM. WITH LS	MUMBAI DEMAND	OTHER DISCOM DEMAND	STATE DEMAND	FREQ. (Hz)
	THM	HY	GAS			THM	GAS						Planned	*Transmission Constraint					
1	6396	515	279	7190	1283	5925	0	0	7066	6696	-1288	19290	0	0	19290	2775	516	22581	50.01
2	6315	512	278	7105	1309	5575	0	0	7016	6738	-1341	18893	0	0	18893	2562	494	21948	49.98
3	6151	506	281	6938	1307	5776	0	0	6646	6470	-1300	18709	0	0	18709	2391	482	21582	50.01
4	6152	322	279	6753	1174	5716	0	0	6951	6719	-1260	18628	0	0	18628	2312	474	21414	50.02
5	6150	302	276	6728	1234	5733	0	0	7586	7363	-1317	19255	0	0	19255	2296	486	22037	49.95
6	6150	293	279	6722	1280	5893	0	1	8986	8609	-1422	20566	0	0	20566	2398	518	23481	49.90
7	6212	438	280	6930	1157	6091	0	212	9995	9586	-1558	21882	0	0	21882	2603	536	25021	50.01
8	6096	434	280	6810	1162	5718	0	866	9881	9811	-1848	21966	0	0	21966	2827	553	25346	50.04
9	5803	395	274	6472	1222	5195	0	1735	9621	9951	-2275	21710	0	0	21710	3140	590	25440	50.11
10	5180	361	274	5815	1249	4626	0	2490	10314	10275	-2592	21244	0	0	21244	3439	619	25302	50.02
11	5062	294	279	5635	1359	4456	0	3082	9000	8824	-2756	19973	0	0	19973	3666	628	24266	49.94
12	5000	289	274	5563	1598	4425	0	3535	8716	7750	-3016	19228	0	0	19228	3880	627	23735	49.97
13	4921	289	275	5485	1643	4049	0	2992	8561	7151	-2888	17801	0	0	17801	3735	631	22167	50.00
14	5038	293	278	5609	1671	3879	0	2263	8236	7710	-2628	17889	0	0	17889	3533	614	22037	50.00
15	5050	286	277	5613	1807	3892	0	2510	8156	7803	-2646	18377	0	0	18377	3506	602	22485	49.97
16	5162	328	278	5768	1864	3974	0	2370	7912	7627	-2611	18371	0	0	18371	3517	621	22509	49.99
17	5294	449	278	6021	1799	4414	0	1756	8865	8358	-2596	19143	0	0	19143	3517	609	23269	49.93
18	5582	489	277	6348	1795	4542	0	915	9590	9218	-2355	19844	0	0	19844	3505	619	23968	50.02
19	6440	806	279	7525	1638	5535	0	111	9518	9184	-2131	21235	0	0	21235	3449	627	25311	50.06
20	6562	1070	280	7912	1609	6222	0	0	9220	9057	-1820	22365	0	0	22365	3472	615	26452	50.01
21	6536	1412	279	8227	1485	6252	0	0	7811	8153	-1658	21854	0	0	21854	3362	605	25821	50.02
22	6532	1508	276	8316	1484	6256	0	0	7013	7165	-1505	21111	0	0	21111	3242	605	24958	49.98
23	6440	1397	278	8115	1320	6217	0	0	6969	6953	-1461	20567	0	0	20567	3133	577	24277	49.99
24	6367	791	280	7438	1185	6119	0	0	7173	7055	-1463	19786	0	0	19786	3024	548	23358	50.02
MUs	140.59	13.78	6.67	161.04	34.63	126.48	0.00	24.84	200.80	194.23	-47.73	479.69	0.00	0.00	479.69	75.28	13.79	568.77	50.00

NOTE : ALL VALUES IN MW

Mumbai Net Exch is shown with reference to MSETCL system and (-) sign indicates MSETCL periphery to Mumbai system.

*Load Shedding due to Transmission Constraint :-

Maximum Demand scenario for the date 05/Aug/2026		
State Demand	MSEDC L Non-Coincident Peak Demand	Mumbai Non-Coincident Peak Demand
26452 MW	22365 MW	3880 MW
20 Hrs	20 Hrs	12 Hrs
Includes LS - 0 MW	Includes LS - 0 MW	--

State Load Despatch Center,Airoli (MSETCL) Statement-VI

Details of Generating Unit Outages/Trippings for 05/Aug/2026

Position as on 6.30 Hrs of 06/Aug/2026

Generating Company	Name of Generating Unit	Capacity	Tripped Date	Tripped Time	Sync.Date	Sync. Time	Reason of Outage	Expected Date
PLANNED OUTAGE								
MSPGCL								
MSPGCL	Koyna Unit 12	80	15/06/2026	10:00		Continued.	COH	13/08/2026
MSPGCL	Bhusawal Unit 5	500	05/07/2026	01:01		Continued.	Capital Overhaul for 35 days	09/08/2026
MSPGCL	Chandrapur Unit 7	500	06/07/2026	14:13		Continued.	COH	10/08/2026
Total Capacity MSPGCL		1080						
IPP								
IPP	Adani U-2	660	20/07/2026	01:12		Continued.	Planned COH, BLR.	23/08/2026
IPP	RPL(AMT) U-1	270	21/07/2026	00:00		Continued.	withdrawn for Boiler licence renewal & other maintenance work.	12/08/2026
IPP	SWPGPL U-1	135	04/08/2026	01:20		Continued.	Annual Overhaul	28/08/2026
Total Capacity IPP		1065						
Total Capacity PLANNED OUTAGE		2145						
FORCED OUTAGE								
MSPGCL								
MSPGCL	Uran Unit A0	120	21/04/2026	21:37		Continued.	Gas Skid Trip	31/12/2026
MSPGCL	Ghatghar Unit-1	125	17/05/2026	08:52		Continued.	Stator Earth Fault	15/08/2026
MSPGCL	Koyna Unit 10	80	20/07/2026	20:25		Continued.	B-phase Overcurrent and Overall Differential Relay protection	20/09/2026
MSPGCL	Bhusawal Unit 4	500	04/08/2026	00:39	05/08/2026	23:40	Boiler Tube Leakage	
MSPGCL	Parli Unit 6	250	05/08/2026	10:04	05/08/2026	12:48	Furnace Pressure High	
Total Capacity MSPGCL		325						
IPP								
IPP	LMEL Unit 3	30	01/06/2026	00:04		Continued.	steam unavailability	31/08/2026
IPP	VMEPL Unit 1	60	28/07/2026	05:00		Continued.	bed drains choked and bed height rising issue	
IPP	VMEPL Unit 2	60	30/07/2026	00:15		Continued.	Boiler DCC RAV 2A & 2B jammed	
Total Capacity IPP		150						
Total Capacity FORCED OUTAGE		475						
UNIT UNDER ZERO SCHEDULE / RSD								
MSPGCL								
MSPGCL	Uran Unit 6	108	29/07/2026	22:00		Continued.	No Schedule by buyer due to open cycle operation High cost.	
MSPGCL	Uran Unit 5	108	30/07/2026	23:29		Continued.	No Schedule by buyer due to open cycle operation High cost.	
Total Capacity MSPGCL		216						
Total Capacity UNIT UNDER ZERO SCHEDULE / RSD		216						
FORCED OUTAGE DUE TO NO PPA								

State Load Despatch Center,Airoli (MSETCL) Statement-VI
Details of Generating Unit Outages/Trippings for 05/Aug/2026

Position as on 6.30 Hrs of 06/Aug/2026

Generating Company	Name of Generating Unit	Capacity	Tripped Date	Tripped Time	Sync.Date	Sync. Time	Reason of Outage	Expected Date
IPP								
IPP	PGPL U1	262	07/02/2017	17.30		Continued.	No Schedule (NO PPA)	
IPP	PGPL U2	126	07/02/2017	17.30		Continued.	No Schedule.(NO PPA)	
Total Capacity IPP		388						
Total Capacity FORCED OUTAGE DUE TO NO PPA		388						

* Other generator generating power instead of contracted genertaor with tri-party agreement in between generatos & discom (Case-IV bidding)

State Load Despatch Center,Airoli (MSETCL)
Details of Line outages/Trippings for 05/Aug/2026

Statement-VII

Position as on 6.30 Hrs of 06/Aug/2026

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
400 KV TIEBAY Outages/Trippings							
400KV TIE BAY 405 GT 1 -AKOLA 2 CKT 2 @ NANDGAONPETH	InterState	05/08/2026	15:38	05/08/2026	18:08	T	DUE TO WATER INGRESS IN GT-1 PRV-1 TB.
400 KV MAINBAY Outages/Trippings							
400KV MAIN BAY 404 - GT 1 @ NANDGAONPETH	InterState	05/08/2026	15:38	05/08/2026	18:08	T	DUE TO WATER INGRESS IN GT-1 PRV-1 TB.
MAIN BAY - 404 CHD SWITCHING CKT2 @ CHANDRAPUR 2	IntraState	05/08/2026	10:00	05/08/2026	14:05	PO	Diagnostic testing of Bus CT, CB & Allied bay maintenance work
MAIN BAY (405) OF 315 MVA ICT - 2 @ AKOLA	IntraState	05/08/2026	16:46	05/08/2026	18:01	T	PDR TRIPPED.
400 KV LR Outages/Trippings							
50 MVAR LINE REACTOR OF 400KV KUMBHARGAON(NANDED) CKT 1 AT 400KV PARLI	IntraState	05/03/2025	20:45			HT	Due to Voltage constraint LR kept out at Parly ss.
400 KV LINE Outages/Trippings							
400KV-AURANGABAD-M (WALUJ)-PUNE-GIS-1	InterState	05/08/2026	08:58			HT	H/T AT WALUJ END.
JAIGAD - KARAD CKT - 2	IntraState	29/03/2026	10:27			T	Tripped on distance protection.
AURANGABAD(MS) - PUNE (GIS) CKT - 2	IntraState	21/07/2026	23:46			HT	Load management
KHADKA-AURANGABAD (WALUJ)	IntraState	01/08/2026	22:43			HT	Over Voltage
MAIN BUS - 1 @ AKOLA	IntraState	03/08/2026	11:38			PO	Bus Bar Protection required out of Service. For checking of events on busbar ie 400kV Bus-I and 400 kV Bus II
MAIN BUS - 2 @ AKOLA	IntraState	03/08/2026	11:38			PO	Bus Bar Protection required out of service for checking of events on busbar ie 400kV Bus-I and 400 kV Bus II
LONIKAND 2 - KARJAT CKT - 1	IntraState	05/08/2026	10:24	05/08/2026	20:40	PO	1)Providing twin jumpering at tension towers using C type wedge connectors 2) Insulator string replacement with antifog long rod insulators
BUS REACTOR (125 MVar) @ ALKUD	IntraState	05/08/2026	19:17	06/08/2026	05:12	T	Back up impedance relay
NEW KOYNA-KARAD CKT - 1	IntraState	06/08/2026	07:12			PO	Distance Main1, LBB relay retrofitting work along with panel rewiring work for compliance of WRPC protection audit point.
400 KV ICT Outages/Trippings							
STATION TF No 3 @ CHANDRAPUR GCR	IntraState	01/03/2023	15:07			PO	1) Oil filtration work 2) Testing of Station transformer 3) Preventive maintenance work.
400/220 KV 3X105 MVA ICT - 1 @ KHARGHAR	IntraState	21/07/2026	11:24			EO	Heavy oil leakage observed from ICT-1, B ph LV Bushing.
400/11kV STN-4A @ DEEPNAGAR	IntraState	31/07/2026	11:36			EO	for the 500 MW planned work of STN-4A Transformer bushing, TAN-DELTA testing, Oil filtration, and Numerical Protection Relay testing, work as per GENCO requirement
400/220/33 KV 500 MVA ICT - 3 @ JEJURI	IntraState	05/08/2026	11:09	05/08/2026	20:09	PO	Routine Testing & Maintenance Work
400/220/33 KV 500MVA ICT - 1 @ KHAPARKHEDA 2	IntraState	05/08/2026	11:32			PO	Transformer Oil Filtration,Painting,OLTC Mechanism Overhauling Work and NIFPS Maintenance Work
400 KV GT-4 (500 MW) @ DEEPNAGAR	IntraState	05/08/2026	13:20	05/08/2026	15:45	PO	FOR BAY MAINTENANCE, 400KV MAIN CB DCRM 7 400KV CVT DAIGNOSTIC TESTING WORKS.

State Load Despatch Center,Airoli (MSETCL)
Details of Line outages/Trippings for 05/Aug/2026

Statement-VII

Position as on 6.30 Hrs of 06/Aug/2026

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
400/220/33 KV 500MVA ICT - 3 @ NAGOTHANE	IntraState	05/08/2026	20:14			T	Tripped on OSR
400 KV BR Outages/Trippings							
80 MVAR BUS REACTOR @ PADGHE	IntraState	24/07/2025	22:05			HT	Sparking observed
220 KV TIEBAY Outages/Trippings							
BUS COUPLER @ KUDUS	IntraState	08/07/2026	08:10			HT	Load management.
BUS COUPLER @ PHURSUNGI	IntraState	24/07/2026	13:02			HT	For Load management.
220 KV LINE Outages/Trippings							
NARANGWADI - SOLAPUR PG CKT - 2	InterState	01/08/2026	11:29			PO	Replacement of existing 0.4 ACSR Conductor of 220kV Narangwadi-Solapur (PG) Ckt-2 by HPC conductor under Sanction Scheme.
WAGHIVALI (MSETCL) - ULWE GIS CKT - 2	IntraState	25/06/2024	08:05			T	Tripped on differential protection
WAGHIVALI (MSETCL) - WAGHIVALI (TATA) CKT - 1	IntraState	30/12/2024	10:44			HT	Hand tripped only at Waghivali (TATA) End only For load management on 220kV Ulwe - Waghivali ckt -1
WAGHIVALI (MSETCL) - WAGHIVALI (TATA) CKT - 2	IntraState	30/12/2024	10:44			HT	Hand tripped only at Waghivali (TATA) End only For load management on 220kV Ulwe - Waghivali ckt -1
KHANDESHWAR - TIMBER MARKET CKT - 1	IntraState	12/02/2026	14:37			T	Tripped on distance protection.
220KV GIS DCHI - COLOURCHEM	IntraState	12/05/2026	20:08			T	Tripped on distance protection.
BHOSARI-1(GIS)-Microsoft-II GIS (PNQ27 CKT-1)	IntraState	25/06/2026	07:26			T	Distance Protection.
220 KV NTT GLOBAL (Estella)-MANKOLI	IntraState	06/07/2026	05:01			T	Diffrential Prot. B-ph fault current 14.57kA dIST 9.5KM FROM NTT Global
KALMESHWAR-PANDHURNA	IntraState	11/07/2026	08:02			HT	For Controlled loading.
MAIN BUS SECTION - 1 @ MAHAPE	IntraState	15/07/2026	11:16			PO	for reconfiguring default setting, changing busbar setting and testing work on CTR make numerical bus bar protection system.
EKLAHARE (OCR) - PADGHE	IntraState	19/07/2026	18:47			HT	Load management
220KV TAPTITANDA- AMRAPUR CKT I	IntraState	21/07/2026	19:59			T	Tripped on distance protection.
LONIKAND1-LONIKAND2 (INTER CONNECTOR)	IntraState	24/07/2026	22:42			HT	For Load Management.
TALOJA - NAVI MUMBAI (PG)(TEMPORARY) LINE	IntraState	25/07/2026	12:30			PO	or safety purpose from Dtd. 24.07.2026 @ 08:00 hrs to 31.07.2026 @ 18:00 hrs on Continuous basis for Replacement of .35 ACSR Sheep conductor by HPC of 220kV Print House & Pachanand (Temporary) line (MSLDC purview) under LES schemes.
CHINCHWAD-2 - TELCO	IntraState	27/07/2026	11:55			PO	Bunching of 220kV Chinchwad2-Telco & 220kV Chinchwad2-Chakan line @ T.L.No. :- 43-44
CHAKAN - CHINCHWAD 2	IntraState	27/07/2026	12:17			PO	1) Bunching between loc no 43 - 44. 2) removal of jump on tower loc no 43 of 220 kv Chinchwad 2 - Chakan Line 3) Replacement of existing 0.4 ACSR conductor by HTLS work from Chinchwad2 ss Gantry to TL No. : -43

State Load Despatch Center,Airoli (MSETCL)
Details of Line outages/Trippings for 05/Aug/2026

Statement-VII

Position as on 6.30 Hrs of 06/Aug/2026

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
ALKUD - MENDHEGIRI CKT - 2	IntraState	31/07/2026	13:54			T	Distance Protection.
KALWA SALSETTE - 3	IntraState	04/08/2026	23:12	05/08/2026	09:11	PO	¿Metro 4 Project work (Line Raising Job at Shangrilla Crossing, Bhandup) : work in vicinity for Formation of three terminal line - 220 kV KVTL Vikhroli - AEML Chandivali / Salsette-1 :-
DAHANU - VERSOVA	IntraState	04/08/2026	23:22	05/08/2026	14:17	PO	PEB erection activities at Shahid Bhagat singh station
CHANDIVALI (AEML) - VIKHROLI (KVPTL)	IntraState	04/08/2026	23:22	05/08/2026	10:05	PO	¿Metro 4 Project work (Line Raising Job at Shangrilla Crossing, Bhandup) : Formation of three terminal line - 220 kV KVTL Vikhroli - AEML Chandivali / Salsette-1 line
SALSETTE - VIKHROLI (GIS) CKT-1	IntraState	04/08/2026	23:45	05/08/2026	10:05	PO	¿Metro 4 Project work (Line Raising Job at Shangrilla Crossing, Bhandup) : Formation of three terminal line - 220 kV KVTL Vikhroli - AEML Chandivali / Salsette-1
GHATGHAR - BAPGAON	IntraState	04/08/2026	23:54	05/08/2026	09:32	T	Distance prot. Optd. Yph fault ,Zone1, Fault current-1.975 kAmp. A/R Block.
MALINAGAR - KARKAMB	IntraState	05/08/2026	09:34	05/08/2026	15:44	PO	Outage is required for Quarterly Maintenance
MAIN BUS - 2 @ MALINAGAR	IntraState	05/08/2026	09:53	05/08/2026	13:40	PO	Outage is required for Quarterly Maintenance
TILLARI - AMONA LINE	IntraState	05/08/2026	10:12	05/08/2026	17:10	PO	Insulator replacement and iso replacement work
URAN - APTA CKT - 1	IntraState	05/08/2026	11:00	05/08/2026	19:53	PO	Insulator replacement work under Scheme
ALKUD - VITA	IntraState	05/08/2026	11:18	05/08/2026	12:59	PO	SF6 CB Diagnostic Testing work.
LONIKAND 1 - KHED CITY	IntraState	06/08/2026	02:24			T	Distance Protection
LONIKAND 1 - KHED CITY	IntraState	06/08/2026	07:32			PO	To carryout the restringing of OPGW at M/C T.Loc no 10-11 by project Div II pune. OPGW snapped on dated 01.07.2026
LONIKAND 2 - KHED CITY	IntraState	06/08/2026	07:36			PO	To carryout the restringing of OPGW at M/C T.Loc no 10-11 by project Div II pune. OPGW snapped on dated 01.07.2026
SALSETTE - VIKHROLI (GIS) CKT - 2	IntraState	06/08/2026	07:56			PO	Metro 4 Project work (Line Raising Job at Shangrilla Crossing, Bhandup) : 1. Tower Erection at loc. 3 & 4 of TS RoW. 2. Conductor / OPGW Shifting at New loc. 3 & 4 3. Conductor stringing in span 3(New)-3(Old) 4. Old loc. 4 tower dismantling
TALANDGE - SAWANTWADI	IntraState	06/08/2026	09:38			PO	faulty insulator replacement
URAN - APTA CKT - 1	IntraState	06/08/2026	10:02			PO	Insulator replacement work under Scheme
220 KV ICT Outages/Trippings							
220/132 KV 200 MVA ICT - 2 @ ALEPHATA	IntraState	06/07/2026	18:40			T	Tripped on differential protection.
220/132 KV 100MVA ICT 2 @ SOUTH SOLAPUR	IntraState	31/07/2026	09:37			PO	For 200MVA 220/132KV BBL ICT Augmentation Work
220 KV BUSBAR Outages/Trippings							

State Load Despatch Center,Airoli (MSETCL)
Details of Line outages/Trippings for 05/Aug/2026

Statement-VII

Position as on 6.30 Hrs of 06/Aug/2026

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
NTT NEON (DC 13)-BUS-1	IntraState	25/07/2026	11:50			PO	220 KV BUS-1, CT (100/1 to 200/1) replacement work
MAIN BUS - 2 @ PRINT HOUSE	IntraState	31/07/2026	17:12			PO	)For Installation of bus-2 link to newly erected 220kV GIS bay for commissioning of TF 3 2) Bus bar Protection out for new bay integration
110 KV LINE Outages/Trippings							
KALWA KALYAN	IntraState	09/01/2026	13:38			PO	For upgradation to 220 kV Kalwa Kalyan line project work
SALSETTE SAKI 4	IntraState	02/03/2026	09:06			PO	EHV cable termination to provide LILLO arrangements at IIT Mumbai (Power supply to IIT) at Loc. 22-22B.
SALSETTE VIKHROLI CKT - 1	IntraState	31/07/2026	07:24			PO	Metro 4 Project work (Line Raising Job at Shangrilla Crossing, Bhandup): 1. Diversion of 220 kV Kalwa Salsette 3 Line on 110kV Salsette Vikhroli 1 Line (TDS bottom Circuit) in section between Bhandup village to loc. 92 (Salsette) for tower erection work at loc. 3 & 4 of TS RoW
SALSETTE - VIKHROLI CKT - 2	IntraState	31/07/2026	07:24			PO	Metro 4 Project work (Line Raising Job at Shangrilla Crossing, Bhandup):2. Diversion of 220 kV Kalwa Salsette 4 Line on 110kV Salsette Vikhroli 2 Line (TDS bottom Circuit) in section between Bhandup village to loc. 92 (Salsette) for tower erection work at loc. 3 & 4 of TS RoW
TATA AMBERNATH MSETCL NERAL	IntraState	05/08/2026	11:23	05/08/2026	17:31	PO	For checking LS GOD Alignment by OEM & Protection Trials at Ambarnath end

HT : Hand Tripping, T : Tripping, PO : Planned Outage, EO : Emergency Outage