

State Load Despatch Center, Airoli (MSETCL) Statement I
Daily system Report for 05/Jul/2026 SUNDAY

I GENERATION (MUs)			II EXCHANGES (MUs)		
A) MSPGCL	Daily	Monthly	E) InterState Exchanges	Daily	Monthly
1) Thermal	134.314	690.326	1) Gujrat	-4.850	-22.304
2) Hydro	6.801	28.940	2) Madhya Pradesh	3.965	-2.836
3) Gas	6.323	32.697	3) Chattisgarh	-0.350	1.870
Total MSPGCL	147.438	751.963	4) Maharashtra	129.267	791.705
B) 1) APLM	45.679	253.853	5) Goa (Amona)	-0.806	-4.262
2) JSWEL	21.506	106.224	Total	127.226	764.173
3) VIPL	12.282	63.845	a) Mumbai Schedule	38.645	204.042
4) RPL(AMT)	22.340	130.229	b) Mumbai Drawl	38.478	217.364
5) SWPGPL	9.929	50.896	c) MSEDCL Bilateral *	117.495	589.081
6) Other IPP	11.963	63.336	Include PX	0.000	0.000
7) PGPL	0.000	0.000	d) Mumbai Bilateral *	38.645	204.042
C) 1) TPCL Thermal	8.493	47.215	Include PX	0.000	0.000
2) TPCL Hydro	2.301	16.581	Standby	0.000	0.000
3) TPCL Gas	2.552	14.205	H) ENERGY CATERED (MUs)		
4) AEML Thermal	7.488	41.587	1) MSEDCL	434.503	2306.431
D) STATE			2) Mumbai Discoms	59.312	336.952
1) Thermal	273.994	1447.511	3) Other Discoms	13.095	67.663
(A1+C1+C4+(B1-B6))			TOTAL STATE	506.910	2711.046
2) Hydro (A2+C2)	9.102	45.521			
3) Gas (A3+B7+C3)	8.875	46.902			
4) Wind	66.641	317.259			
6) SOLAR	21.072	89.680			
TOTAL STATE	379.684	1946.873			

* Displayed for information, not added in total.

DETAILS OF MAHARASHTRA STATE PEAK DEMAND(MW) Statement II

PARTICULARS	A. Morning Peak at 10 Hrs	B. Day Peak at 18 Hrs	C. Evening Peak at 20 Hrs	D. Night Minimum at 3 Hrs
MSPGCL Thermal	5380	5298	6274	5565
MSPGCL Hydro	226	231	493	235
MSPGCL Gas	265	261	259	265
MSPGCL Total Generation	5871	5790	7026	6065
Central Sector Receipt	6622	5702	5814	4786
WIND	2426	2996	2978	2773
CPP / IPP Thermal	5060	4668	5804	5513
CPP / IPP Gas	0	0	0	0
SOLAR	1914	752	0	0
Exchange with Mumbai	-1664	-1690	-1515	-1301
MSEDCL DEMAND MET	19661	17647	19542	17361
Load Shedding	0	0	0	0
MSEDCL DEMAND	19661	17647	19542	17361
TPCL GENERATION	497	572	758	556
AEML GENERATION	281	286	444	307
MUMBAI DEMAND	2442	2548	2717	2164
OTHER DISCOM DEMAND	569	572	565	475
STATE DEMAND MET	22671	20766	22824	20000
STATE DEMAND	22671	20766	22824	20000
Frequency (Hz)	50.00	49.92	49.93	50.02

FREQUENCY PARTICULARS

MAXIMUM FREQ.	MINIMUM FREQ.	AVERAGE FREQ.	FREQ. BELOW 49.4 Hz
50.38 Hz at 13.25 Hrs	49.59 Hz at 19.42 Hrs	50.01	0 % of Time(min)

Note : The report is based on Operational Data and is for statistical purpose only.

Daily and Progressive Generation,Maximum,Minimum for 05/Jul/2026

Generating unit	Generation			
	Daily (Mus)	Monthly (Mus)	Max (MW)	Min (MW)
Koradi				
Unit 6	2.23	15.70	133	52
Unit 8	11.07	21.22	584	362
Unit 9	11.36	58.54	580	365
Unit 10	10.39	55.66	500	380
Total	35.05	151.13		
Bhusawal				
Unit 3	2.98	15.09	130	120
Unit 4	7.36	30.02	395	280
Unit 5	0.28	33.86	276	0
Unit 6	10.84	58.71	580	368
Total	21.47	137.67		
Parli				
Unit 6	3.68	19.60	180	145
Unit 7	3.51	18.09	166	126
Unit 8	3.78	20.18	231	141
Total	10.97	57.87		
Chandrapur				
Unit 3	3.00	12.26	135	115
Unit 4	2.74	11.87	128	91
Unit 5	4.90	31.35	265	105
Unit 6	5.46	17.48	290	172
Unit 7	4.44	25.25	203	165
Unit 8	7.31	40.15	346	289
Unit 9	7.54	40.86	404	274
Total	35.39	179.22		
Paras				
Unit 3	3.69	19.50	168	144
Unit 4	3.85	19.80	200	143
Total	7.54	39.29		
Khaparkheda				
Unit 1	2.96	15.36	140	105
Unit 2	2.89	14.89	141	104
Unit 3	3.29	16.47	156	129
Unit 4	0.00	0.00	0	0
Unit 5	8.93	45.13	425	300
Total	18.07	91.84		
Nasik				
Unit 3	0.00	3.32	0	0
Unit 4	3.02	15.27	135	116
Unit 5	2.80	14.71	135	108
Total	5.82	33.30		
Uran				
All Units	6.32	32.70	269	259
Total	6.32	32.70		
PGPL				
Unit 1	0.00	0.00	0	0
Unit 2	0.00	0.00	0	0
Total	0.00	0.00		
PENCH (MS)				
Pench (MS)	0.00	0.00	0	0
Total	0.00	0.00		
Koyna				

Generating unit	Generation			
	Daily (Mus)	Monthly (Mus)	Max (MW)	Min (MW)
Stage 1-2	0.00	0.00	0	0
Stage 4	0.00	0.00	0	0
Stage 3	0.41	2.19	80	0
Total	0.41	2.19		
Hydro				
KDPH	0.00	0.00	0	0
VTRNA	0.79	3.76	60	0
TILLARI	0.47	0.47	60	0
BHIRA T.R.	0.47	1.89	80	0
SMLHY_PTN	4.16	18.20	178	162
GHATGHAR	0.50	2.43	125	0
Total	6.39	26.75		
Wind				
Total	66.64	317.26	0	0
Total	66.64	317.26		
CPP				
APML(Mus)	45.68	253.85	0	0
JSWEL(Mus)	21.51	106.22	0	0
VIPL(Mus)	12.28	63.84	0	0
RPLAMT-Mus	22.34	130.23	0	0
SWPGPL-Mus	9.93	50.90	0	0
Dhariwal	0.00	0.00	0	0
IEPL	4.68	24.94	267	152
Other(Mus)	1.62	8.25	0	0
JPL	4.97	26.28	265	143
Total	123.00	664.52		
SOLAR				
Total	21.07	89.68	0	0
Total	21.07	89.68		
Tata				
Trombay 5	5.29	30.84	317	170
Trombay 6	0.00	0.00	0	0
Trombay 7A	1.40	8.19	59	58
Trombay 7B	1.15	6.01	48	48
TATA Hydro	2.30	16.58	180	44
Trombay 8	3.20	16.38	155	128
Total	13.35	78.00		
AEML				
DTPS U-1&2	7.49	41.59	464	279
Total	7.49	41.59		

* Infirm Power			Summary			Summary		
Particulars	Daily (Mus)	Monthly	Particulars	Daily (Mus)	Monthly (Mus)	Particulars	Daily (Mus)	Monthly (Mus)
			MSPGCL Thermal	134.31	690.33	MSPGCL Total	147.44	751.96
			MSPGCL Thml+Gas	140.64	723.02	Koyna 1,2 & 4 Total	0.00	0.00
			MSPGCL Hydro	6.80	28.94	State Total	379.68	1946.87

State Load Despatch Center,Airoli (MSETCL)

Annexure-2

Hourly Load Data As on 05/Jul/2026

TIME SR. NO.	MSPGCL GEN.			TOTAL	WIND	CPP / IPP		SOLAR	CS SHARE	CS RECPT	Mum. NET EXCH.	MSEDC L DEM. MET	Load Shedding		MSEDC L DEM. WITH LS	MUMBAI DEMAND	OTHER DISCOM DEMAND	STATE DEMAND	FREQ. (Hz)
	THM	HY	GAS			THM	GAS						Planned	*Transmission Constraint					
1	5706	245	267	6218	2734	5599	0	0	4819	4935	-1410	17555	0	0	17555	2419	521	20495	49.95
2	5682	233	266	6181	2791	5674	0	0	4774	5015	-1285	17890	0	0	17890	2281	486	20657	50.01
3	5565	235	265	6065	2773	5513	0	0	5029	4786	-1301	17357	0	0	17357	2164	479	20000	50.02
4	5386	236	265	5887	2870	5475	0	0	5229	5025	-1259	17531	0	0	17531	2081	467	20079	50.05
5	5834	234	266	6334	2685	5635	0	0	5201	4928	-1235	17867	0	0	17867	2059	480	20406	50.00
6	6139	309	269	6717	2641	5876	0	0	6039	5498	-1274	18930	0	0	18930	2102	528	21560	49.97
7	6106	302	268	6676	2509	5876	0	163	6654	5967	-1294	19366	0	0	19366	2089	531	21986	49.99
8	6035	324	266	6625	2354	5747	0	584	6561	6235	-1361	19616	0	0	19616	2139	568	22323	50.00
9	5682	258	267	6207	2408	5205	0	1120	7029	6801	-1483	19700	0	0	19700	2283	558	22541	49.96
10	5380	226	265	5871	2426	5060	0	1914	6962	6622	-1664	19658	0	0	19658	2442	572	22671	50.00
11	4982	177	259	5418	2698	4511	0	2564	6742	5901	-1765	18750	0	0	18750	2531	576	21858	50.09
12	5034	236	260	5530	2730	4245	0	2898	5202	5158	-2097	17896	0	0	17896	2854	569	21318	50.08
13	5050	236	262	5548	2905	4227	0	2769	4565	4327	-2111	17118	0	0	17118	2881	547	20546	50.12
14	5093	185	263	5541	2871	4230	0	2425	4396	4105	-2027	16592	0	0	16592	2847	553	19992	50.23
15	5081	244	262	5587	2905	4229	0	2210	4257	3971	-1958	16374	0	0	16374	2802	570	19746	50.06
16	5139	289	264	5692	2827	4256	0	2138	4193	3736	-1696	16399	0	0	16399	2541	554	19494	49.93
17	5179	229	261	5669	2912	4252	0	1480	5211	4564	-1672	16648	0	0	16648	2509	556	19714	49.95
18	5298	231	261	5790	2996	4668	0	752	5430	5702	-1690	17644	0	0	17644	2548	575	20766	49.92
19	5996	332	263	6591	2978	5562	0	55	5150	5911	-1569	18948	0	0	18948	2643	580	22171	50.05
20	6274	493	259	7026	2978	5804	0	0	6225	5814	-1515	19539	0	0	19539	2717	568	22824	49.93
21	5902	496	261	6659	2912	5540	0	0	6224	6319	-1736	19118	0	0	19118	2714	576	22408	50.02
22	6244	400	261	6905	2980	5663	0	0	5312	5461	-1798	18617	0	0	18617	2676	594	21887	50.02
23	5886	344	260	6490	2924	5428	0	0	5367	5379	-1686	17978	0	0	17978	2549	557	21084	49.99
24	5641	307	263	6211	2834	5424	0	0	4897	5067	-1592	17413	0	0	17413	2441	531	20385	49.99
MUs	134.31	6.80	6.32	147.44	66.64	123.70	0.00	21.07	131.47	127.23	-38.48	434.50	0.00	0.00	434.50	59.31	13.10	506.91	50.01

NOTE : ALL VALUES IN MW

Mumbai Net Exch is shown with reference to MSETCL system and (-) sign indicates MSETCL periphery to Mumbai system.

*Load Shedding due to Transmission Constraint :-

Maximum Demand scenario for the date 05/Jul/2026		
State Demand	MSEDC Non-Coincident Peak Demand	Mumbai Non-Coincident Peak Demand
22824 MW	19700 MW	2881 MW
20 Hrs	9 Hrs	13 Hrs
Includes LS - 0 MW	Includes LS - 0 MW	--

State Load Despatch Center,Airoli (MSETCL) Statement-VI
Details of Generating Unit Outages/Trippings for 05/Jul/2026

Position as on 6.30 Hrs of 06/Jul/2026

Generating Company	Name of Generating Unit	Capacity	Tripped Date	Tripped Time	Sync.Date	Sync. Time	Reason of Outage	Expected Date
PLANNED OUTAGE								
MSPGCL								
MSPGCL	Khaparkheda Unit 4	210	13/06/2026	09:28		Continued.	Annual Overhaul	19/07/2026
MSPGCL	Koyna Unit 12	80	15/06/2026	10:00		Continued.	COH	13/08/2026
MSPGCL	Bhusawal Unit 5	500	05/07/2026	01:01		Continued.	Capital Overhaul for 35 days	09/08/2026
Total Capacity MSPGCL		790						
Total Capacity PLANNED OUTAGE		790						
FORCED OUTAGE								
MSPGCL								
MSPGCL	Uran Unit A0	120	21/04/2026	21:37		Continued.	Gas Skid Trip	31/12/2026
MSPGCL	Ghatghar Unit-1	125	17/05/2026	08:52		Continued.	Stator Earth Fault	15/08/2026
MSPGCL	Koyna Unit 4	70	12/06/2026	14:00		Continued.	Repair work of HRT surge Well and EVT	07/07/2026
MSPGCL	Koyna Unit 8	80	12/06/2026	15:35		Continued.	Repair work of HRT surge Well and EVT	07/07/2026
MSPGCL	Koyna Unit 5	80	12/06/2026	16:00		Continued.	Repair work of HRT surge Well and EVT	07/07/2026
MSPGCL	Koyna Unit 7	80	12/06/2026	16:45		Continued.	Repair work of HRT surge Well and EVT	07/07/2026
MSPGCL	Koyna Unit 1	70	12/06/2026	16:50		Continued.	Repair work of HRT surge well and EVT.	07/07/2026
MSPGCL	Koyna Unit 6	80	12/06/2026	17:00		Continued.	Repair work of HRT surge Well and EVT	07/07/2026
MSPGCL	Koyna Unit 3	70	12/06/2026	17:00		Continued.	Repair work of HRT surge Well and EVT	07/07/2026
MSPGCL	Koyna Unit 2	70	13/06/2026	12:20		Continued.	Inspection of HRT and repair of Surge Well	07/07/2026
MSPGCL	Nasik Unit 3	210	02/07/2026	10:00		Continued.	Boiler Tube Leakage	05/07/2026
Total Capacity MSPGCL		1055						
IPP								
IPP	LMEL Unit 3	30	01/06/2026	00:04		Continued.	steam unavailability	31/08/2026
IPP	VMEPL Unit 2	60	29/06/2026	03:30	05/07/2026	04:42	boiler coal feeder's issue.	
IPP	RPL(AMT) U-4	270	03/07/2026	11:30		Continued.	FD Fan Problem.	08/07/2026
IPP	VMEPL Unit 1	60	04/07/2026	06:13		Continued.	issue in boiler's coal feeders	
IPP	VMEPL Unit 2	60	05/07/2026	05:04		Continued.	boiler coal feeder's issue.	
Total Capacity IPP		420						
Total Capacity FORCED OUTAGE		1475						
UNIT UNDER ZERO SCHEDULE / RSD								
MSPGCL								
MSPGCL	Uran Unit 6	108	27/06/2026	06:26		Continued.	No Schedule by buyer due to open cycle operation High cost.	
MSPGCL	Uran Unit 5	108	27/06/2026	06:38		Continued.	No Schedule by buyer due to open cycle operation High cost	

State Load Despatch Center,Airoli (MSETCL) Statement-VI
Details of Generating Unit Outages/Trippings for 05/Jul/2026

Position as on 6.30 Hrs of 06/Jul/2026

Generating Company	Name of Generating Unit	Capacity	Tripped Date	Tripped Time	Sync.Date	Sync. Time	Reason of Outage	Expected Date
Total Capacity MSPGCL		216						
Total Capacity UNIT UNDER ZERO SCHEDULE / RSD		216						
FORCED OUTAGE DUE TO NO PPA								
IPP								
IPP	PGPL U1	262	07/02/2017	17.30		Continued.	No Schedule (NO PPA)	
IPP	PGPL U2	126	07/02/2017	17.30		Continued.	No Schedule.(NO PPA)	
Total Capacity IPP		388						
Total Capacity FORCED OUTAGE DUE TO NO PPA		388						
OUTAGE DUE TO FUEL SHORTAGE								
MSPGCL								
MSPGCL	Koyna STG-IV Unit-1	250	02/06/2026	00:00		Continued.	Vide CE MSPGCL Pophali mail dtd01.06.2026 all kgsc machines kept onstandstill mode from02.06.2026 due tolow reservoir level, (Koyna provide 560 MW DCfrom 19:00 of 07.06.2026 to 02:00 hrs of 08.06.26)	
MSPGCL	Koyna STG-IV Unit-2	250	02/06/2026	00:00		Continued.	Vide CE MSPGCL Pophali mail dtd01.06.2026 all kgsc machines kept onstandstill mode from02.06.2026 due tolow reservoir level, (Koyna provide 560 MW DCfrom 19:00 of 07.06.2026 to 02:00 hrs of 08.06.26)	
MSPGCL	Koyna Unit 9	80	02/06/2026	00:00		Continued.	Vide CE MSPGCL Pophali mail dtd01.06.2026 all kgsc machines kept onstandstill mode from02.06.2026 due tolow reservoir level, (Koyna provide 560 MW DCfrom 19:00 of 07.06.2026 to 02:00 hrs of 08.06.26)	
MSPGCL	Koyna STG-IV Unit-4	250	02/06/2026	00:00		Continued.	Vide CE MSPGCL Pophali mail dtd01.06.2026 all kgsc machines kept onstandstill mode from02.06.2026 due tolow reservoir level, (Koyna provide 560 MW DCfrom 19:00 of 07.06.2026 to 02:00 hrs of 08.06.26)	
MSPGCL	Koyna Unit 11	80	02/06/2026	00:00		Continued.	Vide CE MSPGCL Pophali mail dtd01.06.2026 all kgsc machines kept onstandstill mode from02.06.2026 due tolow reservoir level, (Koyna provide 560 MW DCfrom 19:00 of 07.06.2026 to 02:00 hrs of 08.06.26)	
MSPGCL	Koyna STG-IV Unit-3	250	02/06/2026	00:00		Continued.	Vide CE MSPGCL Pophali mail dtd01.06.2026 all kgsc machines kept onstandstill mode from02.06.2026 due tolow reservoir level,	

State Load Despatch Center, Airoli (MSETCL) Statement-VI
Details of Generating Unit Outages/Trippings for 05/Jul/2026

Position as on 6.30 Hrs of 06/Jul/2026

Generating Company	Name of Generating Unit	Capacity	Tripped Date	Tripped Time	Sync.Date	Sync. Time	Reason of Outage	Expected Date
MSPGCL	Koyna Unit 10	80	07/06/2026	02:00		Continued.	(Koyna provide 560 MW DC from 19:00 of 07.06.2026 to 02:00 hrs of 08.06.26) Vide CE MSPGCL Pophali mail dtd 01.06.2026 all kgsc machines kept on standstill mode from 02.06.2026 due to low reservoir level, (Koyna provide 560 MW DC from 19:00 of 07.06.2026 to 02:00 hrs of 08.06.26)	
Total Capacity MSPGCL		1240						
Total Capacity OUTAGE DUE TO FUEL SHORTAGE		1240						

* Other generator generating power instead of contracted generator with tri-party agreement in between generators & discom (Case-IV bidding)

State Load Despatch Center,Airoli (MSETCL)
Details of Line outages/Tripping for 05/Jul/2026

Statement-VII

Position as on 6.30 Hrs of 06/Jul/2026

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
765 KV LINE Outages/Tripping							
KORADI III - AKOLA II Ckt - 1	IntraState	26/06/2026	16:38			T	Tripped on Distance protection , dist-144.12kM, Rph earth fault-3.60kA
500 KV LINE Outages/Tripping							
CHANDRAPUR - PADGHE HVDC POLE 1	IntraState	24/06/2026	06:28	05/07/2026	14:08	EO	1. For inspection of 2A bushing Bucholz Alarm of Pole 1 B phase Converter Transformer appeared on SCADA 2) General inspection of transformer
CHANDRAPUR - PADGHE HVDC POLE 1	IntraState	05/07/2026	15:49	05/07/2026	18:09	T	Tripped on DC filter Z1 Trip and DC filter Z1 F1 overload Trip at Padghe end.
400 KV LR Outages/Tripping							
50 MVAR LINE REACTOR OF 400KV KUMBHARGAON(NANDED) CKT 1 AT 400KV PARLI	IntraState	05/03/2025	20:45			HT	Due to Voltage constraint LR kept out at Parly ss.
400 KV LINE Outages/Tripping							
400KV-AURANGABAD-M (WALUJ)-PUNE-GIS-2	InterState	27/06/2026	15:33			HT	To Control 400kV Talegaon (PG)-Chakan line loading.
KARAD - SOLAPUR (PG)	InterState	05/07/2026	19:14			T	Tripped on distance protection.
400KV-VIKHROLI-TALEGAON(PG) LINE	InterState	06/07/2026	09:00			T	Distance Protection.
JAIGAD - KARAD CKT - 2	IntraState	29/03/2026	10:27			PO	Main 2 distance relay replacement work
KHADKA-AURANGABAD (WALUJ)	IntraState	05/07/2026	12:36			HT	Over Voltage
400 KV ICT Outages/Tripping							
STATION TF No 3 @ CHANDRAPUR GCR	IntraState	01/03/2023	15:07			PO	1) Oil filtration work 2) Testing of Station transformer 3) Preventive maintenance work.
400/220 KV 500 MVA ICT - 6 @ PADGHE	IntraState	05/07/2026	14:11	05/07/2026	15:30	T	Tripped due to 220kV Pal bay 29B isolator damaged observed on Bus-2.
400/220 KV 3X105 MVA ICT - 1 @ PADGHE	IntraState	05/07/2026	14:11	05/07/2026	18:02	T	Tripped due to 220kV Pal bay 29B isolator damaged observed on Bus-2.
400/220 KV 500 MVA ICT - 5 @ PADGHE	IntraState	05/07/2026	14:11	05/07/2026	17:13	T	Tripped due to 220kV Pal bay 29B isolator damaged observed on Bus-2.
400/220/33 KV 315 MVA ICT - 3 @ PADGHE	IntraState	05/07/2026	14:11			T	Tripped due to 220kV Pal bay 29B isolator damaged observed on Bus-2.
400 KV BR Outages/Tripping							
80 MVAR BUS REACTOR @ PADGHE	IntraState	24/07/2025	22:05			HT	Sparking observed
220 KV TIEBAY Outages/Tripping							
BUS COUPLER @ PHURSUNGI	IntraState	27/06/2026	06:30			HT	Load management
220 KV LINE Outages/Tripping							
WAGHIVALI (MSETCL) - ULWE GIS CKT - 2	IntraState	25/06/2024	08:05			T	Tripped on differential protection
WAGHIVALI (MSETCL) - WAGHIVALI (TATA) CKT - 2	IntraState	30/12/2024	10:44			HT	Hand tripped only at Waghivali (TATA) End only For load management on 220kV Ulwe - Waghivali ckt -1
WAGHIVALI (MSETCL) - WAGHIVALI (TATA) CKT - 1	IntraState	30/12/2024	10:44			HT	Hand tripped only at Waghivali (TATA) End only For load management on 220kV Ulwe - Waghivali ckt -1

State Load Despatch Center,Airoli (MSETCL)
Details of Line outages/Trippings for 05/Jul/2026

Statement-VII

Position as on 6.30 Hrs of 06/Jul/2026

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
SHIVAJINAGAR-MALEGAON	IntraState	27/12/2025	17:51			EO	Outage proposal for bunching at loc no.20 for HPC reconductoring work (from Loc no 20/1 to Loc no 162 as shown in PPT attached)
KHANDESHWAR - TIMBER MARKET CKT - 1	IntraState	12/02/2026	14:37			T	Tripped on distance protection.
AMRAPUR - TAPTITANDA CKT - 1	IntraState	22/04/2026	15:33			T	AT T E= B PH, IF=3.3KA, D=48.50KM
220KV GIS DCHI - COLOURCHEM	IntraState	12/05/2026	20:08			T	Tripped on distance protection.
LONIKAND1-LONIKAND2 (INTER CONNECTOR)	IntraState	22/06/2026	20:07			HT	H/T for load management.
BHOSARI-1(GIS)-Microsoft-II GIS (PNQ27 CKT-1	IntraState	25/06/2026	07:26			T	Distance Protection.
EKLAHARE (OCR) - PADGHE	IntraState	26/06/2026	23:10			HT	Load management
KALMESHWAR-PANDHURNA	IntraState	04/07/2026	21:40	05/07/2026	09:46	HT	Load management
SALSETTE - VIKHROLI (GIS) CKT - 3	IntraState	05/07/2026	10:59			T	Tripped on Y-B phase to phase fault.
TALANDGE - SAWANTWADI	IntraState	05/07/2026	11:49	05/07/2026	14:03	T	Distance Protection.
PADGHE - KAMBA 1	IntraState	05/07/2026	14:11			T	Tripped due to 220 kV Padghe Bus 2 tripped
PADGHE - TEMGHAR - 2	IntraState	05/07/2026	14:11			T	Tripped due to 220kV Padge Bus 2 tripped
TALANDGE - SAWANTWADI	IntraState	05/07/2026	14:39	05/07/2026	21:12	T	Tripped on distance protection.
BOMBAY DYEING - SAHARA	IntraState	05/07/2026	16:40	05/07/2026	19:05	T	Tripped on distance protection.
220 KV PADGHE-KUDUS	IntraState	05/07/2026	18:44			HT	For Load management of padge bus loading
KALMESHWAR-PANDHURNA	IntraState	05/07/2026	19:28			HT	HT AT PANDHURNA END
BOMBAY DYEING - SAHARA	IntraState	05/07/2026	23:23			T	Tripped on distance protection R Phase
URSE-CHINCHWAD	IntraState	06/07/2026	02:35				Dist Protection Y-ph 8.64kA Z-1
220 KV NTT GLOBAL (Estella)-MANKOLI	IntraState	06/07/2026	05:01			T	Differential Prot. B-ph fault current 14.57kA dIST 9.5KM FROM NTT Global
URAN - ULWE GIS CKT - 2	IntraState	06/07/2026	06:23			T	Dist Prot. Yph fault current 20.07 kA
DAHANU - GHODBUNDER CKT - 2	IntraState	06/07/2026	07:49			T	Distance Protection.
TALANDGE - HAMIDWADA	IntraState	06/07/2026	08:40	06/07/2026	11:14	PO	Replacement of flashover string at location no. 74 B ph
220 KV BUSBAR Outages/Trippings							
MAIN BUS - 1 @ PRINT HOUSE	IntraState	08/05/2026	12:07			PO	For replacement of Tariff metering CT from 100/1A to 200/1A.
MAIN BUS SECTION @ SAYNE	IntraState	03/07/2026	16:40	05/07/2026	18:24	EO	outage proposal for Integration of new 220/33 KV ,50 MVA PTR into the existing busbar scheme .Bus bar scheme will be kept out of service
BUS - B @ PADGHE	IntraState	05/07/2026	14:11			T	Tripped due to 220kV Pal bay 29B isolator damaged observed on Bus-2.
110 KV LINE Outages/Trippings							
KALWA KALYAN	IntraState	09/01/2026	13:38			PO	For upgradation to 220 kV Kalwa Kalyan line project work
SALSETTE SAKI 4	IntraState	02/03/2026	09:06			PO	EHV cable termination to provide LILO arrangements at IIT Mumbai (Power supply to IIT) at Loc. 22-22B.

HT : Hand Tripping, T : Tripping, PO : Planned Outage, EO : Emergency Outage