

State Load Despatch Center, Airoli (MSETCL) Statement I
Daily system Report for 06/Jul/2026 MONDAY

I GENERATION (MUs)			II EXCHANGES (MUs)		
A) MSPGCL	Daily	Monthly	E) InterState Exchanges	Daily	Monthly
1) Thermal	130.726	821.052	1) Gujrat	-4.533	-26.837
2) Hydro	8.744	37.684	2) Madhya Pradesh	-3.012	-5.848
3) Gas	4.792	37.489	3) Chattisgarh	1.400	3.270
Total MSPGCL	144.262	896.225	4) Maharashtra	133.323	925.028
B) 1) APLM	48.875	302.728	5) Goa (Amona)	-1.388	-5.650
2) JSWEL	19.612	125.836	Total	125.790	889.963
3) VIPL	12.155	76.000	a) Mumbai Schedule	40.973	245.015
4) RPL(AMT)	22.682	152.911	b) Mumbai Drawl	42.461	259.825
5) SWPGPL	9.961	60.857	c) MSEDCL Bilateral *	109.391	698.473
6) Other IPP	12.480	75.816	Include PX	0.000	0.000
7) PGPL	0.000	0.000	d) Mumbai Bilateral *	40.973	245.015
C) 1) TPCL Thermal	10.244	57.459	Include PX	0.000	0.000
2) TPCL Hydro	2.690	19.271	Standby	0.000	0.000
3) TPCL Gas	2.863	17.068	H) ENERGY CATERED (MUs)		
4) AEML Thermal	8.077	49.664	1) MSEDCL	425.593	2732.024
D) STATE			2) Mumbai Discoms	66.335	403.287
1) Thermal	274.812	1722.323	3) Other Discoms	12.575	80.238
(A1+C1+C4+(B1-B6))			TOTAL STATE	504.503	3215.549
2) Hydro	11.434	56.955			
(A2+C2)					
3) Gas	7.655	54.557			
(A3+B7+C3)					
4) Wind	65.222	382.481			
6) SOLAR	19.590	109.270			
TOTAL STATE	378.713	2325.586			

* Displayed for information, not added in total.

DETAILS OF MAHARASHTRA STATE PEAK DEMAND(MW) Statement II

PARTICULARS	A. Morning Peak at 10 Hrs	B. Day Peak at 18 Hrs	C. Evening Peak at 20 Hrs	D. Night Minimum at 4 Hrs
MSPGCL Thermal	5133	5175	5964	5265
MSPGCL Hydro	342	308	577	359
MSPGCL Gas	122	135	164	263
MSPGCL Total Generation	5597	5618	6705	5887
Central Sector Receipt	6966	5939	5854	4667
WIND	2553	2824	2898	2803
CPP / IPP Thermal	4676	5067	6293	5211
CPP / IPP Gas	0	0	0	0
SOLAR	1976	763	0	0
Exchange with Mumbai	-2259	-2048	-1605	-1177
MSEDCL DEMAND MET	18958	17599	19606	16962
Load Shedding	0	0	0	0
MSEDCL DEMAND	18958	17599	19606	16962
TPCL GENERATION	566	558	863	552
AEML GENERATION	295	335	470	284
MUMBAI DEMAND	3120	2941	2938	2013
OTHER DISCOM DEMAND	551	564	539	429
STATE DEMAND MET	22629	21104	23083	19404
STATE DEMAND	22629	21104	23083	19404
Frequency (Hz)	50.05	50.06	49.80	50.01

FREQUENCY PARTICULARS

MAXIMUM FREQ.	MINIMUM FREQ.	AVERAGE FREQ.	FREQ. BELOW 49.4 Hz
50.33 Hz at 11:30 Hrs	49.4 Hz at 19:49 Hrs	49.98	0 % of Time(min)

Note : The report is based on Operational Data and is for statistical purpose only.

Daily and Progressive Generation,Maximum,Minimum for 06/Jul/2026

Generating unit	Generation			
	Daily (Mus)	Monthly (Mus)	Max (MW)	Min (MW)
Koradi				
Unit 6	2.34	18.04	128	43
Unit 8	9.95	31.17	532	343
Unit 9	9.96	68.50	515	367
Unit 10	10.19	65.86	515	390
Total	32.44	183.56		
Bhusawal				
Unit 3	1.94	17.03	130	0
Unit 4	8.06	38.07	480	290
Unit 5	0.00	33.86	0	0
Unit 6	10.36	69.06	561	370
Total	20.35	158.02		
Parli				
Unit 6	3.70	23.30	188	128
Unit 7	3.72	21.81	189	140
Unit 8	3.95	24.13	231	144
Total	11.36	69.23		
Chandrapur				
Unit 3	3.00	15.26	136	122
Unit 4	2.72	14.59	139	88
Unit 5	6.24	37.60	300	200
Unit 6	6.06	23.54	311	200
Unit 7	2.44	27.69	200	0
Unit 8	7.51	47.66	390	282
Unit 9	7.45	48.31	390	272
Total	35.43	214.65		
Paras				
Unit 3	3.70	23.20	182	144
Unit 4	3.54	23.34	173	137
Total	7.24	46.53		
Khaparkheda				
Unit 1	2.99	18.35	150	110
Unit 2	2.92	17.80	144	109
Unit 3	3.22	19.69	143	130
Unit 4	0.00	0.00	0	0
Unit 5	8.81	53.94	440	300
Total	17.94	109.78		
Nasik				
Unit 3	0.00	3.32	0	0
Unit 4	3.01	18.28	130	122
Unit 5	2.97	17.68	154	115
Total	5.98	39.28		
Uran				
All Units	4.79	37.49	267	120
Total	4.79	37.49		
PGPL				
Unit 1	0.00	0.00	0	0
Unit 2	0.00	0.00	0	0
Total	0.00	0.00		
PENCH (MS)				
Pench (MS)	0.00	0.00	0	0
Total	0.00	0.00		
Koyna				

Generating unit	Generation			
	Daily (Mus)	Monthly (Mus)	Max (MW)	Min (MW)
Stage 1-2	0.00	0.00	0	0
Stage 4	0.20	0.20	203	0
Stage 3	2.06	4.25	160	0
Total	2.26	4.45		
Hydro				
KDPH	0.00	0.00	0	0
VTRNA	0.78	4.53	60	0
TILLARI	0.75	1.22	60	0
BHIRA T.R.	0.44	2.33	80	0
SMLHY_PTN	3.89	22.09	177	138
GHATGHAR	0.62	3.05	125	0
Total	6.48	33.23		
Wind				
Total	65.22	382.48	0	0
Total	65.22	382.48		
CPP				
APML(Mus)	48.88	302.73	0	0
JSWEL(Mus)	19.61	125.84	0	0
VIPL(Mus)	12.16	76.00	0	0
RPLAMT-Mus	22.68	152.91	0	0
SWPGPL-Mus	9.96	60.86	0	0
Dhariwal	0.00	0.00	0	0
IEPL	4.76	29.71	266	150
Other(Mus)	1.60	9.86	0	0
JPL	5.26	31.54	275	146
Total	124.91	789.44		
SOLAR				
Total	19.59	109.27	0	0
Total	19.59	109.27		
Tata				
Trombay 5	6.88	37.71	442	259
Trombay 6	0.00	0.00	0	0
Trombay 7A	1.65	9.84	109	45
Trombay 7B	1.22	7.23	64	39
TATA Hydro	2.69	19.27	334	38
Trombay 8	3.37	19.75	221	94
Total	15.80	93.80		
AEML				
DTPS U-1&2	8.08	49.66	501	281
Total	8.08	49.66		

* Infirm Power			Summary			Summary		
Particulars	Daily (Mus)	Monthly	Particulars	Daily (Mus)	Monthly (Mus)	Particulars	Daily (Mus)	Monthly (Mus)
			MSPGCL Thermal	130.73	821.05	MSPGCL Total	144.26	896.22
			MSPGCL Thml+Gas	135.52	858.54	Koyna 1,2 & 4 Total	0.20	0.20
			MSPGCL Hydro	8.74	37.68	State Total	378.71	2325.59

State Load Despatch Center,Airoli (MSETCL)

Annexure-2

Hourly Load Data As on 06/Jul/2026

TIME SR. NO.	MSPGCL GEN.			TOTAL	WIND	CPP / IPP		SOLAR	CS SHARE	CS RECPT	Mum. NET EXCH.	MSEDC L DEM. MET	Load Shedding		MSEDC L DEM. WITH LS	MUMBAI DEMAND	OTHER DISCOM DEMAND	STATE DEMAND	FREQ. (Hz)
	THM	HY	GAS			THM	GAS						Planned	*Transmission Constraint					
1	5850	355	265	6470	2815	5505	0	0	4305	4494	-1475	17288	0	0	17288	2338	521	20147	50.01
2	5389	392	264	6045	2826	5367	0	0	4542	4403	-1350	16785	0	0	16785	2210	506	19501	50.01
3	5317	377	264	5958	2902	5284	0	0	4422	4461	-1234	16905	0	0	16905	2088	466	19459	50.01
4	5265	359	263	5887	2803	5211	0	0	4299	4667	-1177	16959	0	0	16959	2013	432	19404	50.01
5	5461	357	263	6081	2783	5336	0	0	4565	4525	-1176	17112	0	0	17112	2009	437	19558	49.97
6	5645	349	262	6256	2667	5407	0	0	5708	5429	-1233	18060	0	0	18060	2095	466	20621	49.96
7	5906	264	260	6430	2649	5344	0	272	5980	6158	-1317	19036	0	0	19036	2237	500	21773	49.93
8	5640	421	260	6321	2509	5214	0	765	6733	6530	-1574	19227	0	0	19227	2467	538	22232	50.03
9	5173	427	246	5846	2569	4735	0	1428	6852	6883	-1944	18985	0	0	18985	2814	532	22331	50.01
10	5133	342	122	5597	2553	4676	0	1976	6464	6966	-2259	18955	0	0	18955	3120	555	22629	50.05
11	5121	223	123	5467	2683	4591	0	2632	5699	5818	-2689	17959	0	0	17959	3506	543	22008	50.12
12	5025	229	125	5379	2653	4309	0	2707	5844	5354	-2709	17151	0	0	17151	3524	542	21217	50.16
13	5065	167	123	5355	2441	4302	0	2436	5785	4418	-2626	15788	0	0	15788	3454	538	19780	49.96
14	5163	165	120	5448	2247	4239	0	2030	5631	4621	-2480	15575	0	0	15575	3325	530	19430	49.98
15	5012	221	122	5355	2273	4336	0	1726	5536	4677	-2402	15418	0	0	15418	3242	547	19207	49.88
16	5010	228	122	5360	2573	4535	0	1502	5176	5453	-2389	16492	0	0	16492	3195	542	20229	49.96
17	4916	270	120	5306	2831	4823	0	1311	5241	5145	-2161	16709	0	0	16709	2978	546	20233	50.03
18	5175	308	135	5618	2824	5067	0	763	5584	5939	-2048	17595	0	0	17595	2941	568	21104	50.06
19	5692	387	143	6222	2839	5677	0	42	5718	6195	-1732	18687	0	0	18687	2945	556	22188	50.04
20	5964	577	164	6705	2898	6293	0	0	6024	5854	-1605	19602	0	0	19602	2938	543	23083	49.80
21	5929	556	229	6714	2910	6414	0	0	5024	5382	-1343	19548	0	0	19548	2870	529	22947	49.67
22	5984	755	263	7002	2897	6406	0	0	4553	4454	-1123	19105	0	0	19105	2773	531	22409	49.88
23	6004	544	267	6815	3016	6410	0	0	4048	4033	-1099	18612	0	0	18612	2669	563	21844	49.98
24	5887	471	267	6625	3061	6284	0	0	3874	3930	-1316	18039	0	0	18039	2584	545	21168	50.03
MUs	130.73	8.74	4.79	144.26	65.22	125.77	0.00	19.59	127.61	125.79	-42.46	425.59	0.00	0.00	425.59	66.34	12.58	504.50	49.98

NOTE : ALL VALUES IN MW

Mumbai Net Exch is shown with reference to MSETCL system and (-) sign indicates MSETCL periphery to Mumbai system.

*Load Shedding due to Transmission Constraint :-

Maximum Demand scenario for the date 06/Jul/2026		
State Demand	MSEDC Non-Coincident Peak Demand	Mumbai Non-Coincident Peak Demand
23083 MW	19602 MW	3524 MW
20 Hrs	20 Hrs	12 Hrs
Includes LS - 0 MW	Includes LS - 0 MW	--

State Load Despatch Center,Airoli (MSETCL) Statement-VI
Details of Generating Unit Outages/Trippings for 06/Jul/2026

Position as on 6.30 Hrs of 07/Jul/2026

Generating Company	Name of Generating Unit	Capacity	Tripped Date	Tripped Time	Sync.Date	Sync. Time	Reason of Outage	Expected Date
PLANNED OUTAGE								
MSPGCL								
MSPGCL	Khaparkheda Unit 4	210	13/06/2026	09:28		Continued.	Annual Overhaul	19/07/2026
MSPGCL	Koyna Unit 12	80	15/06/2026	10:00		Continued.	COH	13/08/2026
MSPGCL	Bhusawal Unit 5	500	05/07/2026	01:01		Continued.	Capital Overhaul for 35 days	09/08/2026
MSPGCL	Chandrapur Unit 7	500	06/07/2026	14:13		Continued.	COH	10/08/2026
Total Capacity MSPGCL		1290						
Total Capacity PLANNED OUTAGE		1290						
FORCED OUTAGE								
MSPGCL								
MSPGCL	Uran Unit A0	120	21/04/2026	21:37		Continued.	Gas Skid Trip	31/12/2026
MSPGCL	Ghatghar Unit-1	125	17/05/2026	08:52		Continued.	Stator Earth Fault	15/08/2026
MSPGCL	Koyna Unit 4	70	12/06/2026	14:00		Continued.	Repair work of HRT surge Well and EVT	07/07/2026
MSPGCL	Koyna Unit 8	80	12/06/2026	15:35		Continued.	Repair work of HRT surge Well and EVT	07/07/2026
MSPGCL	Koyna Unit 5	80	12/06/2026	16:00		Continued.	Repair work of HRT surge Well and EVT	07/07/2026
MSPGCL	Koyna Unit 7	80	12/06/2026	16:45		Continued.	Repair work of HRT surge Well and EVT	07/07/2026
MSPGCL	Koyna Unit 1	70	12/06/2026	16:50		Continued.	Repair work of HRT surge well and EVT.	07/07/2026
MSPGCL	Koyna Unit 6	80	12/06/2026	17:00		Continued.	Repair work of HRT surge Well and EVT	07/07/2026
MSPGCL	Koyna Unit 3	70	12/06/2026	17:00		Continued.	Repair work of HRT surge Well and EVT	07/07/2026
MSPGCL	Koyna Unit 2	70	13/06/2026	12:20		Continued.	Inspection of HRT and repair of Surge Well	07/07/2026
MSPGCL	Nasik Unit 3	210	02/07/2026	10:00	07/07/2026	06:55	Boiler Tube Leakage	05/07/2026
Total Capacity MSPGCL		845						
IPP								
IPP	LMEL Unit 3	30	01/06/2026	00:04		Continued.	steam unavailability	31/08/2026
IPP	RPL(AMT) U-4	270	03/07/2026	11:30		Continued.	FD Fan Problem.	08/07/2026
IPP	VMEPL Unit 1	60	04/07/2026	06:13		Continued.	issue in boiler's coal feeders	
IPP	VMEPL Unit 2	60	05/07/2026	05:04		Continued.	boiler coal feeder's issue.	
IPP	JSW (J) U1	300	06/07/2026	16:43		Continued.	Turbine bearing Vabration high	
Total Capacity IPP		720						
Total Capacity FORCED OUTAGE		1565						
UNIT UNDER ZERO SCHEDULE / RSD								
MSPGCL								
MSPGCL	Uran Unit 6	108	27/06/2026	06:26		Continued.	No Schedule by buyer due to open cycle operation High cost.	
MSPGCL	Uran Unit 5	108	27/06/2026	06:38		Continued.	No Schedule by buyer due to open cycle operation	

State Load Despatch Center,Airoli (MSETCL) Statement-VI
Details of Generating Unit Outages/Trippings for 06/Jul/2026

Position as on 6.30 Hrs of 07/Jul/2026

Generating Company	Name of Generating Unit	Capacity	Tripped Date	Tripped Time	Sync.Date	Sync. Time	Reason of Outage	Expected Date
							High cost.	
MSPGCL	Bhusawal Unit 3	210	06/07/2026	16:00		Continued.	Zero schedule given by MSEDCL.	
MSPGCL	Nasik Unit 3	210	07/07/2026	06:55		Continued.	ZERO schedule given by MSEDCL	
Total Capacity MSPGCL		636						
Total Capacity UNIT UNDER ZERO SCHEDULE / RSD		636						
FORCED OUTAGE DUE TO NO PPA								
IPP								
IPP	PGPL U1	262	07/02/2017	17.30		Continued.	No Schedule (NO PPA)	
IPP	PGPL U2	126	07/02/2017	17.30		Continued.	No Schedule.(NO PPA)	
Total Capacity IPP		388						
Total Capacity FORCED OUTAGE DUE TO NO PPA		388						
OUTAGE DUE TO FUEL SHORTAGE								
MSPGCL								
MSPGCL	Koyna Unit 9	80	02/06/2026	00:00		Continued.	Vide CE MSPGCL Pophali mail dtd01.06.2026 all kgsc machines kept onstandstill mode from02.06.2026 due tolow reservoir level, (Koyna provide 560 MW DCfrom 19:00 of 07.06.2026 to 02:00 hrs of 08.06.26)	
MSPGCL	Koyna STG-IV Unit-2	250	02/06/2026	00:00		Continued.	Vide CE MSPGCL Pophali mail dtd01.06.2026 all kgsc machines kept onstandstill mode from02.06.2026 due tolow reservoir level, (Koyna provide 560 MW DCfrom 19:00 of 07.06.2026 to 02:00 hrs of 08.06.26)	
MSPGCL	Koyna STG-IV Unit-3	250	02/06/2026	00:00		Continued.	Vide CE MSPGCL Pophali mail dtd01.06.2026 all kgsc machines kept onstandstill mode from02.06.2026 due tolow reservoir level, (Koyna provide 560 MW DCfrom 19:00 of 07.06.2026 to 02:00 hrs of 08.06.26)	
MSPGCL	Koyna STG-IV Unit-4	250	02/06/2026	00:00		Continued.	Vide CE MSPGCL Pophali mail dtd01.06.2026 all kgsc machines kept onstandstill mode from02.06.2026 due tolow reservoir level, (Koyna provide 560 MW DCfrom 19:00 of 07.06.2026 to 02:00 hrs of 08.06.26)	
MSPGCL	Koyna STG-IV Unit-1	250	02/06/2026	00:00	06/07/2026	20:57	Vide CE MSPGCL Pophali mail dtd01.06.2026 all kgsc machines kept onstandstill mode from02.06.2026 due tolow reservoir level, (Koyna provide 560 MW DCfrom 19:00 of	

State Load Despatch Center,Airoli (MSETCL) Statement-VI
Details of Generating Unit Outages/Trippings for 06/Jul/2026

Position as on 6.30 Hrs of 07/Jul/2026

Generating Company	Name of Generating Unit	Capacity	Tripped Date	Tripped Time	Sync.Date	Sync. Time	Reason of Outage	Expected Date
MSPGCL	Koyna Unit 11	80	02/06/2026	00:00		Continued.	07.06.2026 to 02:00 hrs of 08.06.26) Vide CE MSPGCL Pophali mail dtd01.06.2026 all kgsc machines kept onstandstill mode from02.06.2026 due tolow reservoir level, (Koyna provide 560 MW DCfrom 19:00 of 07.06.2026 to 02:00 hrs of 08.06.26)	
MSPGCL	Koyna Unit 10	80	07/06/2026	02:00		Continued.	Vide CE MSPGCL Pophali mail dtd01.06.2026 all kgsc machines kept onstandstill mode from02.06.2026 due tolow reservoir level, (Koyna provide 560 MW DCfrom 19:00 of 07.06.2026 to 02:00 hrs of 08.06.26)	
MSPGCL	Koyna STG-IV Unit-1	250	06/07/2026	21:45		Continued.	Vide CE MSPGCL Pophali mail dtd01.06.2026 all kgsc machines kept onstandstill mode from02.06.2026 due tolow reservoir level.	
Total Capacity MSPGCL		1240						
Total Capacity OUTAGE DUE TO FUEL SHORTAGE		1240						

* Other generator generating power instead of contracted genertaor with tri-party agreement in between generatos & discom (Case-IV bidding)

State Load Despatch Center,Airoli (MSETCL)
Details of Line outages/Trippings for 06/Jul/2026

Statement-VII

Position as on 6.30 Hrs of 07/Jul/2026

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
765 KV LINE Outages/Trippings							
KORADI III - AKOLA II Ckt - 1	IntraState	26/06/2026	16:38			T	Tripped on Distance protection , dist-144.12kM, Rph earth fault-3.60kA
400 KV LR Outages/Trippings							
50 MVAR LINE REACTOR OF 400KV KUMBHARGAON(NANDED) CKT 1 AT 400KV PARLI	IntraState	05/03/2025	20:45			HT	Due to Voltage constraint LR kept out at Parly ss.
400 KV LINE Outages/Trippings							
400KV-AURANGABAD-M (WALUJ)-PUNE-GIS-2	InterState	27/06/2026	15:33			HT	To Control 400kV Talegaon (PG)-Chakan line loading.
KARAD - SOLAPUR (PG)	InterState	05/07/2026	19:14	06/07/2026	15:26	T	Tripped on distance protection.
400KV-VIKHROLI-TALEGAON(PG) LINE	InterState	06/07/2026	09:00	06/07/2026	19:17	T	Distance Protection.
KORADI - BHILAI	InterState	06/07/2026	09:57	06/07/2026	22:42	PO	LINE HT AS OUTAGE AVAILED AT OTHER END .
KORADI 2-WARDHA (PG)	InterState	06/07/2026	12:40	06/07/2026	17:15	EO	Attending Hotspot on Main Bay 413 - Y ph Isolator Jaw Nut-Bolt of 400KV Koradi2- Wardha PGCIL Line at Wardha PGCIL S/stn.
SOLAPUR PG - ALKUD	InterState	06/07/2026	16:09	06/07/2026	20:26	PO	Diagnostic Testing and Routine Maintenance work.
400KV-PADGHE-PG-KHARGHAR(M) ckt-1	InterState	06/07/2026	20:37			T	Tripped on distance protection.
JAIGAD - KARAD CKT - 2	IntraState	29/03/2026	10:27			PO	Main 2 distance relay replacement work
KHADKA-AURANGABAD (WALUJ)	IntraState	05/07/2026	12:36			HT	Over Voltage
PARLI - KUMBHARGAON (NANDED) CKT - 1	IntraState	06/07/2026	05:20	06/07/2026	12:59	T	P END-- Y PH Z1 7.816 KM 14.68 KA N END-- Y PH Z1 66.09 KM 1.72 KA AR LOCK OUT.
JAIGAD - NEW KOYNA CKT - 2	IntraState	06/07/2026	09:40	06/07/2026	12:50	EO	Repair of CVT & LMU for PLCC
400 KV ICT Outages/Trippings							
STATION TF No 3 @ CHANDRAPUR GCR	IntraState	01/03/2023	15:07			PO	1) Oil filtration work 2) Testing of Station transformer 3) Preventive maintenance work.
400/220/33 KV 315 MVA ICT - 3 @ PADGHE	IntraState	05/07/2026	14:11			T	Tripped due to 220kV Pal bay 29B isolator damaged observed on Bus-2.
400/220/33 KV 500 MVA ICT - 4 @ JEJURI	IntraState	06/07/2026	11:14	06/07/2026	18:14	HT	H/T due to oil leakage from Nitrogen injection valve of Y phase unit.
400/220/33 KV 315 MVA ICT - 2 @ PADGHE	IntraState	06/07/2026	16:02	06/07/2026	20:08	T	Tripped on differential protection.
400 KV BR Outages/Trippings							
80 MVAR BUS REACTOR @ PADGHE	IntraState	24/07/2025	22:05			HT	Sparking observed
220 KV TIEBAY Outages/Trippings							
BUS COUPLER @ PHURSUNGI	IntraState	27/06/2026	06:30			HT	Load management
BUS COUPLER @ KUDUS	IntraState	06/07/2026	20:33			HT	HT for load management.
220 KV LINE Outages/Trippings							
WAGHIVALI (MSETCL) - ULWE GIS CKT - 2	IntraState	25/06/2024	08:05			T	Tripped on differential protection
WAGHIVALI (MSETCL) - WAGHIVALI (TATA) CKT - 2	IntraState	30/12/2024	10:44			HT	Hand tripped only at Waghivali (TATA) End only For load management on 220kV Ulwe - Waghivali ckt -1
WAGHIVALI (MSETCL) - WAGHIVALI (TATA) CKT - 1	IntraState	30/12/2024	10:44			HT	Hand tripped only at Waghivali (TATA) End only For load management on 220kV Ulwe - Waghivali ckt -1

State Load Despatch Center,Airoli (MSETCL)
Details of Line outages/Trippings for 06/Jul/2026

Statement-VII

Position as on 6.30 Hrs of 07/Jul/2026

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
SHIVAJINAGAR-MALEGAON	IntraState	27/12/2025	17:51			EO	Outage proposal for bunching at loc no.20 for HPC reconductoring work (from Loc no 20/1 to Loc no 162 as shown in PPT attached)
KHANDESHWAR - TIMBER MARKET CKT - 1	IntraState	12/02/2026	14:37			T	Tripped on distance protection.
AMRAPUR - TAPTITANDA CKT - 1	IntraState	22/04/2026	15:33			T	AT T E= B PH, IF=3.3KA, D=48.50KM
220KV GIS DCHI - COLOURCHEM	IntraState	12/05/2026	20:08			T	Tripped on distance protection.
LONIKAND1-LONIKAND2 (INTER CONNECTOR)	IntraState	22/06/2026	20:07			HT	H/T for load management.
BHOSARI-1(GIS)-Microsoft-II GIS (PNQ27 CKT-1)	IntraState	25/06/2026	07:26			T	Distance Protection.
EKLAHARE (OCR) - PADGHE	IntraState	26/06/2026	23:10			HT	Load management
PADGHE - KAMBA 1	IntraState	05/07/2026	14:11	06/07/2026	19:30	T	Tripped due to 220 kV Padghe Bus 2 tripped
PADGHE - TEMGHAR - 2	IntraState	05/07/2026	14:11	06/07/2026	19:38	T	Tripped due to 220kV Padge Bus 2 tripped
220 KV PADGHE-KUDUS	IntraState	05/07/2026	18:44	06/07/2026	20:30	HT	For Load management of padge bus loading
KALMESHVAR-PANDHURNA	IntraState	05/07/2026	19:28	06/07/2026	09:28	HT	HT AT PANDHURNA END
BOMBAY DYEING - SAHARA	IntraState	05/07/2026	23:23			T	Tripped on distance protection R Phase
URSE-CHINCHWAD	IntraState	06/07/2026	02:35				Dist Protection Y-ph 8.64kA Z-1
220 KV NTT GLOBAL (Estella)-MANKOLI	IntraState	06/07/2026	05:01			T	Differential Prot. B-ph fault current 14.57kA dIST 9.5KM FROM NTT Global
URAN - ULWE GIS CKT - 2	IntraState	06/07/2026	06:23	06/07/2026	16:22	T	Dist Prot. Yph fault current 20.07 kA
DAHANU - GHODBUNDER CKT - 2	IntraState	06/07/2026	07:49			T	Distance Protection.
TALANDGE - HAMIDWADA	IntraState	06/07/2026	08:40	06/07/2026	11:14	PO	Replacement of flashover string at location no. 74 B ph
220 KV BAPGAON-MANKOLI	IntraState	06/07/2026	11:37	06/07/2026	16:36	EO	To make NTT Estella-Bapgaon through. he EEHV C.C.O&M Zone, Washi / CLD Kalwa 1)Mankoli GIS side Jumper at TL No. 2 (CTT) will be removed. 2)Jumper will be connected at TL No 1.
BHENDA - VISHWIND CKT - 1	IntraState	06/07/2026	21:18			HT	Emergency H/T due to sparking.
ADLABS - PEDAMBE	IntraState	07/07/2026	04:56	07/07/2026	06:32	T	Tripped on Dist. Prot. R-ph
URAN - ONGC URAN	IntraState	07/07/2026	06:08	07/07/2026	09:05	HT	both TC of 220KV Uran-ONGC bay CB are not healthy.
220 KV ICT Outages/Trippings							
220/100 KV 200 MVA ICT 4 @ KALWA	IntraState	06/07/2026	07:04	06/07/2026	15:00	T	Tripped on PRV optd.
220/33 KV 50MVA T/F - 2 @ MIRAJ	IntraState	06/07/2026	12:32	06/07/2026	16:57	T	Tripped on pole discrepancy optd. & Backup O/C & E/F optd.
220/132 KV 200 MVA ICT - 2 @ ALEPHATA	IntraState	06/07/2026	18:40			T	Tripped on differential protection.
220/33 KV 50 MVA T/F 3 @ MALEGAON	IntraState	07/07/2026	05:55			T	Tripped on differential protection.
220 KV BUSBAR Outages/Trippings							
MAIN BUS - 1 @ PRINT HOUSE	IntraState	08/05/2026	12:07			PO	For replacement of Tariff metering CT from 100/1A to 200/1A.
BUS - B @ PADGHE	IntraState	05/07/2026	14:11			T	Tripped due to 220kV Pal bay 29B isolator damaged observed on Bus-2.

State Load Despatch Center,Airoli (MSETCL)
Details of Line outages/Trippings for 06/Jul/2026

Statement-VII

Position as on 6.30 Hrs of 07/Jul/2026

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
110 KV LINE Outages/Trippings							
KALWA KALYAN	IntraState	09/01/2026	13:38			PO	For upgradation to 220 kV Kalwa Kalyan line project work
SALSETTE SAKI 4	IntraState	02/03/2026	09:06			PO	EHV cable termination to provide LILO arrangements at IIT Mumbai (Power supply to IIT) at Loc. 22-22B.
KALYAN KALWA SALSETTE 2	IntraState	06/07/2026	14:04	06/07/2026	14:54	EO	Tree trimming at loc 60-61

HT : Hand Tripping, T : Tripping, PO : Planned Outage, EO : Emergency Outage