

**State Load Despatch Center, Airoli (MSETCL) Statement I**  
**Daily system Report for 19/Aug/2026 WEDNESDAY**

| I GENERATION (MUs)  |                |                 | II EXCHANGES (MUs)             |                |                  |
|---------------------|----------------|-----------------|--------------------------------|----------------|------------------|
| A) MSPGCL           | Daily          | Monthly         | E) InterState Exchanges        | Daily          | Monthly          |
| 1) Thermal          | 171.295        | 2727.336        | 1) Gujrat                      | 9.375          | 0.089            |
| 2) Hydro            | 11.008         | 240.234         | 2) Madhya Pradesh              | 1.446          | 48.365           |
| 3) Gas              | 6.494          | 123.927         | 3) Chattisgarh                 | -0.460         | 10.720           |
| <b>Total MSPGCL</b> | <b>188.797</b> | <b>3091.497</b> | 4) Maharashtra                 | 178.349        | 3452.143         |
| B) 1) APML          | 55.194         | 917.183         | 5) Goa (Amona)                 | -1.519         | -26.045          |
| 2) JSWEL            | 21.138         | 432.759         | <b>Total</b>                   | <b>187.191</b> | <b>3485.272</b>  |
| 3) VIPL             | 13.918         | 232.907         | a) Mumbai Schedule             | 45.849         | 844.140          |
| 4) RPL(AMT)         | 31.392         | 491.364         | b) Mumbai Drawl                | 48.741         | 891.255          |
| 5) SWPGPL           | 9.005          | 160.776         | c) MSEDCL Bilateral *          | 116.515        | 2444.954         |
| 6) Other IPP        | 13.896         | 228.925         | Include PX                     | 0.000          | 0.000            |
| 7) PGPL             | 0.000          | 0.000           | d) Mumbai Bilateral *          | 45.849         | 844.140          |
| C) 1) TPCL Thermal  | 11.125         | 192.258         | Include PX                     | 0.000          | -0.548           |
| 2) TPCL Hydro       | 5.350          | 96.174          | Standby                        | 0.000          | 0.000            |
| 3) TPCL Gas         | 3.344          | 57.963          | <b>H) ENERGY CATERED (MUs)</b> |                |                  |
| 4) AEML Thermal     | 8.261          | 156.386         | 1) MSEDCL                      | 523.219        | 9218.061         |
| <b>D) STATE</b>     |                |                 | 2) Mumbai Discoms              | 76.821         | 1394.036         |
| 1) Thermal          | 335.224        | 5539.894        | 3) Other Discoms               | 14.377         | 263.457          |
| (A1+C1+C4+(B1-B6))  |                |                 | <b>TOTAL STATE</b>             | <b>614.417</b> | <b>10875.554</b> |
| 2) Hydro            | 16.358         | 336.408         |                                |                |                  |
| (A2+C2)             |                |                 |                                |                |                  |
| 3) Gas              | 9.838          | 181.890         |                                |                |                  |
| (A3+B7+C3)          |                |                 |                                |                |                  |
| 4) Wind             | 43.158         | 866.252         |                                |                |                  |
| 6) SOLAR            | 22.648         | 465.838         |                                |                |                  |
| <b>TOTAL STATE</b>  | <b>427.226</b> | <b>7390.282</b> |                                |                |                  |

\* Displayed for information, not added in total.

**DETAILS OF MAHARASHTRA STATE PEAK DEMAND(MW) Statement II**

| PARTICULARS                | A. Morning Peak at 11 Hrs | B. Day Peak at 16 Hrs | C. Evening Peak at 20 Hrs | D. Night Minimum at 3 Hrs |
|----------------------------|---------------------------|-----------------------|---------------------------|---------------------------|
| MSPGCL Thermal             | 6846                      | 6736                  | 8166                      | 6786                      |
| MSPGCL Hydro               | 299                       | 281                   | 1416                      | 299                       |
| MSPGCL Gas                 | 267                       | 254                   | 276                       | 275                       |
| MSPGCL Total Generation    | 7412                      | 7271                  | 9858                      | 7360                      |
| Central Sector Receipt     | 10113                     | 9234                  | 7253                      | 5716                      |
| WIND                       | 1647                      | 2021                  | 1950                      | 1878                      |
| CPP / IPP Thermal          | 5585                      | 5358                  | 6597                      | 6502                      |
| CPP / IPP Gas              | 0                         | 0                     | 0                         | 0                         |
| SOLAR                      | 2440                      | 2407                  | 0                         | 0                         |
| Exchange with Mumbai       | -2801                     | -2744                 | -1761                     | -1480                     |
| <b>MSEDCL DEMAND MET</b>   | <b>23760</b>              | <b>22906</b>          | <b>23250</b>              | <b>19484</b>              |
| Load Shedding              | 0                         | 0                     | 0                         | 0                         |
| MSEDCL DEMAND              | 23760                     | 22906                 | 23250                     | 19484                     |
| TPCL GENERATION            | 668                       | 672                   | 1232                      | 707                       |
| AEML GENERATION            | 274                       | 314                   | 468                       | 276                       |
| <b>MUMBAI DEMAND</b>       | <b>3743</b>               | <b>3730</b>           | <b>3461</b>               | <b>2463</b>               |
| <b>OTHER DISCOM DEMAND</b> | <b>636</b>                | <b>641</b>            | <b>647</b>                | <b>492</b>                |
| STATE DEMAND MET           | 28139                     | 27277                 | 27358                     | 22439                     |
| <b>STATE DEMAND</b>        | <b>28139</b>              | <b>27277</b>          | <b>27358</b>              | <b>22439</b>              |
| Frequency (Hz)             | 49.95                     | 49.96                 | 49.93                     | 49.96                     |

**FREQUENCY PARTICULARS**

| MAXIMUM FREQ.         | MINIMUM FREQ.         | AVERAGE FREQ. | FREQ. BELOW 49.4 Hz |
|-----------------------|-----------------------|---------------|---------------------|
| 50.21 Hz at 08.59 Hrs | 49.75 Hz at 19.25 Hrs | 49.99         | 0 % of Time(min)    |

Note : The report is based on Operational Data and is for statistical purpose only.

## Daily and Progressive Generation,Maximum,Minimum for 19/Aug/2026

| Generating unit    | Generation   |               |          |          |
|--------------------|--------------|---------------|----------|----------|
|                    | Daily (Mus)  | Monthly (Mus) | Max (MW) | Min (MW) |
| <b>Koradi</b>      |              |               |          |          |
| Unit 6             | 3.82         | 62.13         | 184      | 124      |
| Unit 8             | 12.07        | 219.98        | 555      | 393      |
| Unit 9             | 12.44        | 211.68        | 579      | 415      |
| Unit 10            | 10.88        | 165.52        | 500      | 400      |
| <b>Total</b>       | <b>39.20</b> | <b>659.32</b> |          |          |
| <b>Bhusawal</b>    |              |               |          |          |
| Unit 3             | 0.00         | 45.83         | 0        | 0        |
| Unit 4             | 8.84         | 151.58        | 485      | 285      |
| Unit 5             | 8.60         | 39.59         | 470      | 290      |
| Unit 6             | 13.30        | 238.48        | 623      | 378      |
| <b>Total</b>       | <b>30.73</b> | <b>475.48</b> |          |          |
| <b>Parli</b>       |              |               |          |          |
| Unit 6             | 3.90         | 73.73         | 216      | 144      |
| Unit 7             | 3.79         | 70.06         | 180      | 144      |
| Unit 8             | 3.86         | 76.75         | 205      | 144      |
| <b>Total</b>       | <b>11.54</b> | <b>220.55</b> |          |          |
| <b>Chandrapur</b>  |              |               |          |          |
| Unit 3             | 3.35         | 55.95         | 160      | 120      |
| Unit 4             | 3.09         | 52.04         | 158      | 109      |
| Unit 5             | 4.82         | 92.38         | 395      | 0        |
| Unit 6             | 8.65         | 141.42        | 455      | 290      |
| Unit 7             | 8.41         | 26.73         | 445      | 281      |
| Unit 8             | 9.14         | 150.52        | 460      | 298      |
| Unit 9             | 10.12        | 142.72        | 471      | 290      |
| <b>Total</b>       | <b>47.58</b> | <b>661.75</b> |          |          |
| <b>Paras</b>       |              |               |          |          |
| Unit 3             | 4.53         | 77.07         | 216      | 154      |
| Unit 4             | 4.59         | 82.77         | 230      | 150      |
| <b>Total</b>       | <b>9.12</b>  | <b>159.84</b> |          |          |
| <b>Khaparkheda</b> |              |               |          |          |
| Unit 1             | 3.09         | 54.64         | 145      | 105      |
| Unit 2             | 3.20         | 45.14         | 160      | 104      |
| Unit 3             | 4.01         | 62.14         | 184      | 134      |
| Unit 4             | 4.07         | 63.87         | 212      | 128      |
| Unit 5             | 9.71         | 169.62        | 445      | 300      |
| <b>Total</b>       | <b>24.08</b> | <b>395.42</b> |          |          |
| <b>Nasik</b>       |              |               |          |          |
| Unit 3             | 3.02         | 49.18         | 136      | 119      |
| Unit 4             | 3.09         | 58.81         | 139      | 119      |
| Unit 5             | 2.94         | 46.99         | 140      | 115      |
| <b>Total</b>       | <b>9.04</b>  | <b>154.98</b> |          |          |
| <b>Uran</b>        |              |               |          |          |
| All Units          | 6.49         | 123.93        | 277      | 254      |
| <b>Total</b>       | <b>6.49</b>  | <b>123.93</b> |          |          |
| <b>PGPL</b>        |              |               |          |          |
| Unit 1             | 0.00         | 0.00          | 0        | 0        |
| Unit 2             | 0.00         | 0.00          | 0        | 0        |
| <b>Total</b>       | <b>0.00</b>  | <b>0.00</b>   |          |          |
| <b>PENCH (MS)</b>  |              |               |          |          |
| Pench (MS)         | 0.51         | 5.80          | 34       | 21       |
| <b>Total</b>       | <b>0.51</b>  | <b>5.80</b>   |          |          |
| <b>Koyna</b>       |              |               |          |          |

| Generating unit | Generation    |                |          |          |
|-----------------|---------------|----------------|----------|----------|
|                 | Daily (Mus)   | Monthly (Mus)  | Max (MW) | Min (MW) |
| Stage 1-2       | 2.04          | 39.94          | 485      | 40       |
| Stage 4         | 0.24          | 29.51          | 236      | 0        |
| Stage 3         | 0.79          | 22.34          | 160      | 0        |
| <b>Total</b>    | <b>3.06</b>   | <b>91.80</b>   |          |          |
| <b>Hydro</b>    |               |                |          |          |
| KDPH            | 0.43          | 6.95           | 18       | 18       |
| VTRNA           | 0.32          | 9.65           | 59       | 0        |
| TILLARI         | 0.42          | 7.94           | 61       | 0        |
| BHIRA T.R.      | 0.35          | 7.54           | 80       | 0        |
| SMLHY_PTN       | 5.40          | 103.45         | 240      | 201      |
| GHATGHAR        | 1.02          | 12.92          | 125      | 0        |
| <b>Total</b>    | <b>7.95</b>   | <b>148.44</b>  |          |          |
| <b>Wind</b>     |               |                |          |          |
| Total           | 43.16         | 866.25         | 0        | 0        |
| <b>Total</b>    | <b>43.16</b>  | <b>866.25</b>  |          |          |
| <b>CPP</b>      |               |                |          |          |
| APML(Mus)       | 55.19         | 917.18         | 0        | 0        |
| JSWEL(Mus)      | 21.14         | 432.76         | 0        | 0        |
| VIPL(Mus)       | 13.92         | 232.91         | 0        | 0        |
| RPLAMT-Mus      | 31.39         | 491.36         | 0        | 0        |
| SWPGPL-Mus      | 9.00          | 160.78         | 0        | 0        |
| Dhariwal        | 0.00          | 0.00           | 0        | 0        |
| IEPL            | 5.87          | 83.78          | 269      | 151      |
| Other(Mus)      | 1.60          | 30.43          | 0        | 0        |
| JPL             | 6.01          | 97.96          | 278      | 192      |
| VMEPL           | 0.00          | 0.00           | 0        | 0        |
| LMEL            | 0.42          | 16.75          | 43       | 0        |
| <b>Total</b>    | <b>144.54</b> | <b>2463.91</b> |          |          |
| <b>SOLAR</b>    |               |                |          |          |
| Total           | 22.65         | 465.84         | 0        | 0        |
| <b>Total</b>    | <b>22.65</b>  | <b>465.84</b>  |          |          |
| <b>Tata</b>     |               |                |          |          |
| Trombay 5       | 7.38          | 133.28         | 471      | 255      |
| Trombay 6       | 0.00          | 0.00           | 0        | 0        |
| Trombay 7A      | 2.01          | 33.96          | 106      | 59       |
| Trombay 7B      | 1.33          | 24.00          | 62       | 48       |
| TATA Hydro      | 5.35          | 96.17          | 399      | 94       |
| Trombay 8       | 3.75          | 58.98          | 236      | 127      |
| <b>Total</b>    | <b>19.82</b>  | <b>346.40</b>  |          |          |
| <b>AEML</b>     |               |                |          |          |
| DTPS U-1&2      | 8.26          | 156.39         | 480      | 272      |
| <b>Total</b>    | <b>8.26</b>   | <b>156.39</b>  |          |          |

| * Infirm Power |             |         | Summary         |             |               | Summary             |             |               |
|----------------|-------------|---------|-----------------|-------------|---------------|---------------------|-------------|---------------|
| Particulars    | Daily (Mus) | Monthly | Particulars     | Daily (Mus) | Monthly (Mus) | Particulars         | Daily (Mus) | Monthly (Mus) |
|                |             |         | MSPGCL Thermal  | 171.30      | 2727.34       | MSPGCL Total        | 188.80      | 3091.50       |
|                |             |         | MSPGCL Thml+Gas | 177.79      | 2851.26       | Koyna 1,2 & 4 Total | 2.28        | 69.46         |
|                |             |         | MSPGCL Hydro    | 11.01       | 240.23        | State Total         | 427.23      | 7390.28       |

# State Load Despatch Center,Airoli (MSETCL)

## Annexure-2

### Hourly Load Data As on 19/Aug/2026

| TIME SR. NO. | MSPGCL GEN. |       |      | TOTAL  | WIND  | CPP / IPP |      | SOLAR | CS SHARE | CS RECPT | Mum. NET EXCH. | MSEDC L DEM. MET | Load Shedding |                          | MSEDC L DEM. WITH LS | MUMBAI DEMAND | OTHER DISCOM DEMAND | STATE DEMAND | FREQ. (Hz) |
|--------------|-------------|-------|------|--------|-------|-----------|------|-------|----------|----------|----------------|------------------|---------------|--------------------------|----------------------|---------------|---------------------|--------------|------------|
|              | THM         | HY    | GAS  |        |       | THM       | GAS  |       |          |          |                |                  | Planned       | *Transmission Constraint |                      |               |                     |              |            |
| 1            | 6826        | 418   | 273  | 7517   | 1951  | 6395      | 0    | 0     | 6505     | 6220     | -1598          | 19938            | 0             | 0                        | 19938                | 2860          | 547                 | 23345        | 50.01      |
| 2            | 6934        | 305   | 277  | 7516   | 1835  | 6526      | 0    | 0     | 6128     | 5866     | -1600          | 19623            | 0             | 0                        | 19623                | 2632          | 520                 | 22775        | 49.99      |
| 3            | 6786        | 299   | 275  | 7360   | 1878  | 6502      | 0    | 0     | 6175     | 5716     | -1480          | 19484            | 0             | 0                        | 19484                | 2463          | 492                 | 22439        | 49.96      |
| 4            | 6947        | 302   | 277  | 7526   | 1779  | 6515      | 0    | 0     | 6122     | 5979     | -1409          | 19890            | 0             | 0                        | 19890                | 2364          | 500                 | 22754        | 49.96      |
| 5            | 7281        | 297   | 276  | 7854   | 1589  | 6475      | 0    | 0     | 6311     | 6251     | -1382          | 20273            | 0             | 0                        | 20273                | 2326          | 514                 | 23113        | 50.01      |
| 6            | 7462        | 357   | 275  | 8094   | 1801  | 6542      | 0    | 0     | 6993     | 7106     | -1388          | 21647            | 0             | 0                        | 21647                | 2430          | 508                 | 24585        | 50.00      |
| 7            | 7491        | 944   | 277  | 8712   | 1490  | 6592      | 0    | 180   | 8012     | 8224     | -1502          | 23125            | 0             | 0                        | 23125                | 2639          | 571                 | 26335        | 49.94      |
| 8            | 7513        | 615   | 275  | 8403   | 1307  | 6316      | 0    | 641   | 9007     | 9300     | -1839          | 23548            | 0             | 0                        | 23548                | 2897          | 580                 | 27025        | 49.99      |
| 9            | 7206        | 396   | 273  | 7875   | 1286  | 6242      | 0    | 1235  | 9498     | 9164     | -2159          | 23024            | 0             | 0                        | 23024                | 3248          | 619                 | 26891        | 50.06      |
| 10           | 6721        | 298   | 273  | 7292   | 1521  | 5780      | 0    | 2008  | 10859    | 10443    | -2514          | 23907            | 0             | 1                        | 23907                | 3545          | 623                 | 28075        | 50.01      |
| 11           | 6846        | 299   | 267  | 7412   | 1647  | 5585      | 0    | 2440  | 10331    | 10113    | -2801          | 23760            | 0             | 1                        | 23760                | 3743          | 636                 | 28139        | 49.95      |
| 12           | 6451        | 280   | 261  | 6992   | 1649  | 4757      | 0    | 2767  | 10108    | 9803     | -2967          | 22368            | 0             | 0                        | 22368                | 3843          | 633                 | 26844        | 49.99      |
| 13           | 6047        | 280   | 255  | 6582   | 1745  | 4769      | 0    | 2981  | 9478     | 9255     | -2899          | 21777            | 0             | 0                        | 21777                | 3779          | 656                 | 26212        | 49.98      |
| 14           | 6008        | 292   | 266  | 6566   | 1712  | 4697      | 0    | 2812  | 8969     | 8744     | -2788          | 21124            | 0             | 1                        | 21124                | 3652          | 619                 | 25395        | 49.97      |
| 15           | 5990        | 345   | 261  | 6596   | 1658  | 4859      | 0    | 2699  | 9085     | 9467     | -2791          | 21861            | 0             | 2                        | 21861                | 3687          | 627                 | 26175        | 49.96      |
| 16           | 6736        | 281   | 254  | 7271   | 2021  | 5358      | 0    | 2407  | 9271     | 9234     | -2744          | 22906            | 0             | 1                        | 22906                | 3730          | 641                 | 27277        | 49.96      |
| 17           | 7086        | 338   | 258  | 7682   | 2104  | 5655      | 0    | 1638  | 8916     | 8744     | -2655          | 22521            | 0             | 0                        | 22521                | 3688          | 647                 | 26856        | 49.95      |
| 18           | 7407        | 340   | 271  | 8018   | 2066  | 5815      | 0    | 774   | 8568     | 8155     | -2421          | 21771            | 0             | 0                        | 21771                | 3583          | 636                 | 25990        | 50.01      |
| 19           | 7930        | 613   | 274  | 8817   | 1979  | 6453      | 0    | 66    | 8103     | 7854     | -2088          | 22429            | 0             | 0                        | 22429                | 3480          | 652                 | 26561        | 50.01      |
| 20           | 8166        | 1416  | 276  | 9858   | 1950  | 6597      | 0    | 0     | 7363     | 7253     | -1761          | 23250            | 0             | 0                        | 23250                | 3461          | 647                 | 27358        | 49.93      |
| 21           | 7973        | 733   | 275  | 8981   | 1949  | 6590      | 0    | 0     | 7093     | 6787     | -1588          | 22066            | 0             | 0                        | 22066                | 3333          | 653                 | 26052        | 50.01      |
| 22           | 7973        | 661   | 272  | 8906   | 2103  | 6509      | 0    | 0     | 6303     | 6165     | -1502          | 21555            | 0             | 0                        | 21555                | 3242          | 626                 | 25423        | 50.02      |
| 23           | 7953        | 515   | 277  | 8745   | 2126  | 6491      | 0    | 0     | 5846     | 5828     | -1466          | 21114            | 0             | 0                        | 21114                | 3140          | 610                 | 24864        | 50.00      |
| 24           | 7562        | 384   | 276  | 8222   | 2012  | 6523      | 0    | 0     | 5501     | 5520     | -1399          | 20257            | 0             | 0                        | 20257                | 3056          | 621                 | 23934        | 50.01      |
| MUs          | 171.29      | 11.01 | 6.49 | 188.80 | 43.16 | 144.54    | 0.00 | 22.65 | 190.55   | 187.19   | -48.74         | 523.22           | 0.00          | 0.01                     | 523.22               | 76.82         | 14.38               | 614.42       | 49.99      |

NOTE : ALL VALUES IN MW

Mumbai Net Exch is shown with reference to MSETCL system and (-) sign indicates MSETCL periphery to Mumbai system.

\*Load Shedding due to Transmission Constraint :-

132 Kv GHARGOAN T/F-1&2 L.V OVER LOAD DUE TO OVER LOADING (880A 40.48MW).

| Maximum Demand scenario for the date 19/Aug/2026 |                                  |                                   |
|--------------------------------------------------|----------------------------------|-----------------------------------|
| State Demand                                     | MSEDC Non-Coincident Peak Demand | Mumbai Non-Coincident Peak Demand |
| 28139 MW                                         | 23907 MW                         | 3843 MW                           |
| 11 Hrs                                           | 10 Hrs                           | 12 Hrs                            |
| Includes LS - 0 MW                               | Includes LS - 0 MW               | --                                |

**State Load Despatch Center,Airoli (MSETCL)      Statement-VI**  
**Details of Generating Unit Outages/Trippings for 19/Aug/2026**

Position as on 6.30 Hrs of 20/Aug/2026

| Generating Company                            | Name of Generating Unit | Capacity | Tripped Date | Tripped Time | Sync.Date  | Sync. Time | Reason of Outage                                              | Expected Date |
|-----------------------------------------------|-------------------------|----------|--------------|--------------|------------|------------|---------------------------------------------------------------|---------------|
| PLANNED OUTAGE                                |                         |          |              |              |            |            |                                                               |               |
| MSPGCL                                        |                         |          |              |              |            |            |                                                               |               |
| MSPGCL                                        | Koyna Unit 12           | 80       | 15/06/2026   | 10:00        |            | Continued. | COH                                                           | 31/08/2026    |
| Total Capacity MSPGCL                         |                         | 80       |              |              |            |            |                                                               |               |
| IPP                                           |                         |          |              |              |            |            |                                                               |               |
| IPP                                           | Adani U-2               | 660      | 20/07/2026   | 01:12        |            | Continued. | Planned COH, BLR.                                             | 23/08/2026    |
| IPP                                           | SWPGPL U-1              | 135      | 04/08/2026   | 01:20        |            | Continued. | Annual Overhaul                                               | 28/08/2026    |
| Total Capacity IPP                            |                         | 795      |              |              |            |            |                                                               |               |
| Total Capacity PLANNED OUTAGE                 |                         | 875      |              |              |            |            |                                                               |               |
| FORCED OUTAGE                                 |                         |          |              |              |            |            |                                                               |               |
| MSPGCL                                        |                         |          |              |              |            |            |                                                               |               |
| MSPGCL                                        | Uran Unit A0            | 120      | 21/04/2026   | 21:37        |            | Continued. | Gas Skid Trip                                                 | 31/12/2026    |
| MSPGCL                                        | Ghatghar Unit-1         | 125      | 17/05/2026   | 08:52        |            | Continued. | Stator Earth Fault                                            | 15/09/2026    |
| MSPGCL                                        | Koyna Unit 10           | 80       | 20/07/2026   | 20:25        |            | Continued. | B-phase Overcurrent and Overall Differential Relay protection | 20/09/2026    |
| MSPGCL                                        | Chandrapur Unit 5       | 500      | 12/08/2026   | 01:14        | 19/08/2026 | 08:58      | MAIN TURBINE OVER-SPEED PROTECTION                            | 19/08/2026    |
| Total Capacity MSPGCL                         |                         | 325      |              |              |            |            |                                                               |               |
| IPP                                           |                         |          |              |              |            |            |                                                               |               |
| IPP                                           | LMEL Unit 3             | 30       | 01/06/2026   | 00:04        |            | Continued. | steam unavailability                                          | 31/08/2026    |
| IPP                                           | VMEPL Unit 1            | 60       | 28/07/2026   | 05:00        |            | Continued. | bed drains chocked and bed height rising issue                | 31/08/2026    |
| IPP                                           | VMEPL Unit 2            | 60       | 30/07/2026   | 00:15        |            | Continued. | Boiler DCC RAV 2A & 2B jammed                                 | 31/08/2026    |
| IPP                                           | LMEL Unit 2             | 35       | 19/08/2026   | 10:12        | 19/08/2026 | 22:36      | Execution of LILO Work at 220 KV Matardevi Substation         |               |
| IPP                                           | LMEL Unit 1             | 35       | 19/08/2026   | 10:15        | 19/08/2026 | 22:45      | Execution of LILO Work at 220 KV Matardevi Substation         |               |
| Total Capacity IPP                            |                         | 150      |              |              |            |            |                                                               |               |
| Total Capacity FORCED OUTAGE                  |                         | 475      |              |              |            |            |                                                               |               |
| UNIT UNDER ZERO SCHEDULE / RSD                |                         |          |              |              |            |            |                                                               |               |
| MSPGCL                                        |                         |          |              |              |            |            |                                                               |               |
| MSPGCL                                        | Uran Unit 6             | 108      | 29/07/2026   | 22:00        |            | Continued. | No Schedule by buyer due to open cycle operation High cost.   |               |
| MSPGCL                                        | Uran Unit 5             | 108      | 30/07/2026   | 23:29        |            | Continued. | No Schedule by buyer due to open cycle operation High cost.   |               |
| MSPGCL                                        | Bhusawal Unit 3         | 210      | 14/08/2026   | 23:03        |            | Continued. | Zero schedule due to low demand                               |               |
| Total Capacity MSPGCL                         |                         | 426      |              |              |            |            |                                                               |               |
| Total Capacity UNIT UNDER ZERO SCHEDULE / RSD |                         | 426      |              |              |            |            |                                                               |               |
| FORCED OUTAGE DUE TO NO PPA                   |                         |          |              |              |            |            |                                                               |               |

**State Load Despatch Center,Airoli (MSETCL)      Statement-VI**  
**Details of Generating Unit Outages/Trippings for 19/Aug/2026**

**Position as on 6.30 Hrs of 20/Aug/2026**

| Generating Company                                | Name of Generating Unit | Capacity | Tripped Date | Tripped Time | Sync.Date | Sync. Time | Reason of Outage     | Expected Date |
|---------------------------------------------------|-------------------------|----------|--------------|--------------|-----------|------------|----------------------|---------------|
| <b>IPP</b>                                        |                         |          |              |              |           |            |                      |               |
| IPP                                               | PGPL U1                 | 262      | 07/02/2017   | 17.30        |           | Continued. | No Schedule (NO PPA) |               |
| IPP                                               | PGPL U2                 | 126      | 07/02/2017   | 17.30        |           | Continued. | No Schedule.(NO PPA) |               |
| <b>Total Capacity IPP</b>                         |                         | 388      |              |              |           |            |                      |               |
| <b>Total Capacity FORCED OUTAGE DUE TO NO PPA</b> |                         | 388      |              |              |           |            |                      |               |

\* Other generator generating power instead of contracted genertaor with tri-party agreement in between generatos & discom (Case-IV bidding)

**State Load Despatch Center,Airoli (MSETCL)**  
**Details of Line outages/Trippings for 19/Aug/2026**

**Statement-VII**

Position as on 6.30 Hrs of 20/Aug/2026

| Name of Line                                                           | Inter State / Intra State | Tripped Date | Tripped Time | Sync. Date | Sync. Time | Outage Type | Reason of Outage                                                                                                                                                           |
|------------------------------------------------------------------------|---------------------------|--------------|--------------|------------|------------|-------------|----------------------------------------------------------------------------------------------------------------------------------------------------------------------------|
| <b>400 KV MAINBAY Outages/Trippings</b>                                |                           |              |              |            |            |             |                                                                                                                                                                            |
| BUS COUPLER @ PARLI                                                    | IntraState                | 19/08/2026   | 11:22        | 19/08/2026 | 16:16      | EO          | FOR ATTENDING Y-PHCT HAVING HOT SPOT OF 245 DEGREES AT STUD CONNECTING JUMP.                                                                                               |
| <b>400 KV LR Outages/Trippings</b>                                     |                           |              |              |            |            |             |                                                                                                                                                                            |
| 50 MVAR LINE REACTOR OF 400KV KUMBHARGAON(NANDED) CKT 1 AT 400KV PARLI | IntraState                | 05/03/2025   | 20:45        |            |            | HT          | Due to Voltage constraint LR kept out at Parly ss.                                                                                                                         |
| <b>400 KV LINE Outages/Trippings</b>                                   |                           |              |              |            |            |             |                                                                                                                                                                            |
| 400KV-AURANGABAD-M (WALUJ)-PUNE-GIS-1                                  | InterState                | 14/08/2026   | 09:23        |            |            | HT          | H/T from Waluj end only for load management.                                                                                                                               |
| AURANGABAD(MS) - PUNE (GIS) CKT - 2                                    | IntraState                | 21/07/2026   | 23:46        |            |            | HT          | Load management                                                                                                                                                            |
| JAIGAD - KARAD CKT - 2                                                 | IntraState                | 18/08/2026   | 13:03        | 19/08/2026 | 09:18      | T           | Tripped on overvoltage.                                                                                                                                                    |
| KHADKA-AURANGABAD (WALUJ)                                              | IntraState                | 18/08/2026   | 21:26        | 19/08/2026 | 10:16      | HT          | O/V.                                                                                                                                                                       |
| KALWA - KHARGHAR                                                       | IntraState                | 19/08/2026   | 00:45        | 19/08/2026 | 05:06      | EO          | For attending hot spot                                                                                                                                                     |
| DABHOL - NAGOTHANE CKT - 1                                             | IntraState                | 19/08/2026   | 09:31        | 19/08/2026 | 18:27      | PO          | Insulator String Replacement work                                                                                                                                          |
| 400KV WARDHA PG -WARORA PG CKT                                         | IntraState                | 19/08/2026   | 11:20        | 19/08/2026 | 22:41      | EO          | Attending damaged R-phase 428-89B Isolator Rod and the B-phase CT stud pad of Tie Bay (428) of 400KV Wardha PGCIL- Warora (Nagri) PGCIL Line at Wardha (Deoli) PGCIL S/stn |
| KHARGHAR - TALEGAON (PG)                                               | IntraState                | 19/08/2026   | 12:55        | 19/08/2026 | 19:22      | PO          | Replacement of old Disc Insulators With AF Long rod Insulators                                                                                                             |
| JAIGAD - KARAD CKT - 2                                                 | IntraState                | 19/08/2026   | 12:58        |            |            | HT          | H/T for overvoltage.                                                                                                                                                       |
| KHADKA-AURANGABAD (WALUJ)                                              | IntraState                | 19/08/2026   | 20:53        |            |            | HT          | H/T FOR O/V..                                                                                                                                                              |
| DABHOL - NAGOTHANE CKT - 1                                             | IntraState                | 20/08/2026   | 09:05        |            |            | PO          | Insulator String Replacement work                                                                                                                                          |
| JEJURI- KOYNA STAGE-IV                                                 | IntraState                | 20/08/2026   | 10:30        |            |            | PO          | L-I lines : Insulator string replacement with antifog long rod insulators<br><br>Jejuri : Routine Testing & Maintenance Work                                               |
| JEJURI- KOYNA STAGE-IV                                                 | IntraState                | 20/08/2026   | 10:30        |            |            | PO          | Scheme of conversion existing SSN Hardware to DSN Hardware at various road crossing & Cold line washing                                                                    |
| <b>400 KV ICT Outages/Trippings</b>                                    |                           |              |              |            |            |             |                                                                                                                                                                            |
| STATION TF No 3 @ CHANDRAPUR GCR                                       | IntraState                | 01/03/2023   | 15:07        |            |            | PO          | 1) Oil filtration work<br>2) Testing of Station transformer<br>3) Preventive maintenance work.                                                                             |
| 400/220 KV 3X105 MVA ICT - 1 @ KHARGHAR                                | IntraState                | 21/07/2026   | 11:24        |            |            | EO          | Heavy oil leakage observed from ICT-1, B ph LV Bushing.                                                                                                                    |
| 400/220KV 500MVA ICT 3 @ AKOLA                                         | IntraState                | 19/08/2026   | 08:52        | 19/08/2026 | 18:55      | PO          | For Attending the Oil pumps & TCIV issues of TBEA make ICT 3 at 400kv R.S Akola                                                                                            |
| 400/220/33 KV 500 MVA ICT - 3 @ PARLI                                  | IntraState                | 19/08/2026   | 09:46        | 19/08/2026 | 18:28      | PO          | (1) Bay maintenance & CT Testing work.                                                                                                                                     |
| 400/132 KV 200 MVA ICT - 2 @ KHADKA                                    | IntraState                | 19/08/2026   | 12:01        | 19/08/2026 | 18:09      | EO          | emergency outage proposal on 400/132KV 200MVA ICT-II for attending hot spot at Rph CT Clamp Nut bolt CB Side on dtd.19/08/2026 at 400 KV Khadka Substation.                |
| 400/220/33KV 500 MVA ICT - 1 @ KUDUS                                   | IntraState                | 19/08/2026   | 19:19        | 20/08/2026 | 00:51      | EO          | 1) To attend hotspot on B ph LV (RRS 89T) isolator. 2) To attend hot spot on Y ph 89-D Isolator.                                                                           |

**State Load Despatch Center, Airoli (MSETCL)**  
**Details of Line outages/Trippings for 19/Aug/2026**

**Statement-VII**

Position as on 6.30 Hrs of 20/Aug/2026

| Name of Line                                  | Inter State / Intra State | Tripped Date | Tripped Time | Sync. Date | Sync. Time | Outage Type | Reason of Outage                                                                                                                                                                                                   |
|-----------------------------------------------|---------------------------|--------------|--------------|------------|------------|-------------|--------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|
| 400/220KV 315 MVA ICT - 1 @ NEW KOYNA         | IntraState                | 20/08/2026   | 10:06        |            |            | PO          | Electromechanical LBB relay replaced by Numerical LBB relay work                                                                                                                                                   |
| <b>400 KV BR Outages/Trippings</b>            |                           |              |              |            |            |             |                                                                                                                                                                                                                    |
| 80 MVAR BUS REACTOR @ PADGHE                  | IntraState                | 24/07/2025   | 22:05        |            |            | HT          | Sparking observed                                                                                                                                                                                                  |
| <b>220 KV TIEBAY Outages/Trippings</b>        |                           |              |              |            |            |             |                                                                                                                                                                                                                    |
| BUS COUPLER @ KUDUS                           | IntraState                | 08/07/2026   | 08:10        |            |            | HT          | Load management.                                                                                                                                                                                                   |
| BUS COUPLER @ PHURSUNGI                       | IntraState                | 24/07/2026   | 13:02        |            |            | HT          | For Load management.                                                                                                                                                                                               |
| <b>220 KV MAINBAY Outages/Trippings</b>       |                           |              |              |            |            |             |                                                                                                                                                                                                                    |
| BUS SECTION BREAKER @ TROMBAY                 | IntraState                | 18/08/2026   | 13:35        | 19/08/2026 | 05:30      | EO          | Heavy oil leakage from the B phase CT stud (TIE-1 side)                                                                                                                                                            |
| <b>220 KV LINE Outages/Trippings</b>          |                           |              |              |            |            |             |                                                                                                                                                                                                                    |
| NARANGWADI - SOLAPUR PG CKT - 2               | InterState                | 01/08/2026   | 11:29        |            |            | PO          | Replacement of existing 0.4 ACSR Conductor of 220kV Narangwadi-Solapur (PG) Ckt-2 by HPC conductor under Sanction Scheme.                                                                                          |
| WAGHIVALI (MSETCL) - ULWE GIS CKT - 2         | IntraState                | 25/06/2024   | 08:05        |            |            | T           | Tripped on differential protection                                                                                                                                                                                 |
| WAGHIVALI (MSETCL) - WAGHIVALI (TATA) CKT - 1 | IntraState                | 30/12/2024   | 10:44        |            |            | HT          | Hand tripped only at Waghivali (TATA ) End only For load management on 220kV Ulwe - Waghivali ckt -1                                                                                                               |
| WAGHIVALI (MSETCL) - WAGHIVALI (TATA) CKT - 2 | IntraState                | 30/12/2024   | 10:44        |            |            | HT          | Hand tripped only at Waghivali (TATA ) End only For load management on 220kV Ulwe - Waghivali ckt -1                                                                                                               |
| KHANDESHWAR - TIMBER MARKET CKT - 1           | IntraState                | 12/02/2026   | 14:37        |            |            | T           | Tripped on distance protection.                                                                                                                                                                                    |
| GT - 5 @ EKLAHRE (GCR)                        | IntraState                | 23/02/2026   | 00:39        |            | Continued. | EO          | Y Phase CT P2 stud oil leakage attending work.                                                                                                                                                                     |
| 220KV GIS DCHI - COLOURCHEM                   | IntraState                | 12/05/2026   | 20:08        |            |            | T           | Tripped on distance protection.                                                                                                                                                                                    |
| BHOSARI-1(GIS)-Microsoft-II GIS (PNQ27 CKT-1) | IntraState                | 25/06/2026   | 07:26        |            |            | T           | Distance Protection.                                                                                                                                                                                               |
| 220 KV NTT GLOBAL (Estella)-MANKOLI           | IntraState                | 06/07/2026   | 05:01        |            |            | T           | Differential Prot. B-ph fault current 14.57kA dIST 9.5KM FROM NTT Global                                                                                                                                           |
| MAIN BUS SECTION - 1 @ MAHAPE                 | IntraState                | 15/07/2026   | 11:16        |            |            | PO          | for reconfiguring default setting, changing busbar setting and testing work on CTR make numerical bus bar protection system.                                                                                       |
| EKLAHARE (OCR) - PADGHE                       | IntraState                | 19/07/2026   | 18:47        |            |            | HT          | Load management                                                                                                                                                                                                    |
| LONIKAND1-LONIKAND2 (INTER CONNECTOR)         | IntraState                | 24/07/2026   | 22:42        | 20/08/2026 | 06:18      | HT          | For Load Management.                                                                                                                                                                                               |
| CHINCHWAD-2 - TELCO                           | IntraState                | 27/07/2026   | 11:55        |            |            | PO          | Bunching of 220kV Chinchwad2-Telco & 220kV Chinchwad2-Chakan line @ T.L.No. :- 43-44                                                                                                                               |
| CHAKAN - CHINCHWAD 2                          | IntraState                | 27/07/2026   | 12:17        |            |            | PO          | 1) Bunching between loc no 43 - 44. 2) removal of jump on tower loc no 43 of 220 kv Chinchwad 2 - Chakan Line 3) Replacement of existing 0.4 ACSR conductor by HTLS work from Chinchwad2 ss Gantry to TL No. : -43 |
| ALKUD - MENDHEGIRI CKT - 2                    | IntraState                | 31/07/2026   | 13:54        |            |            | T           | Distance Protection.                                                                                                                                                                                               |

**State Load Despatch Center, Airoli (MSETCL)**  
**Details of Line outages/Trippings for 19/Aug/2026**

**Statement-VII**

Position as on 6.30 Hrs of 20/Aug/2026

| Name of Line                            | Inter State / Intra State | Tripped Date | Tripped Time | Sync. Date | Sync. Time | Outage Type | Reason of Outage                                                                                                                                                                                                                                                                                            |
|-----------------------------------------|---------------------------|--------------|--------------|------------|------------|-------------|-------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|
| SALSETTE - VIKHROLI (GIS) CKT - 2       | IntraState                | 06/08/2026   | 07:56        |            |            | PO          | Metro 4 Project work (Line Raising Job at Shangrilla Crossing, Bhandup) :<br>1. Tower Erection at loc. 3 & 4 of TS RoW.<br>2. Conductor / OPGW Shifting at New loc. 3 & 4<br>3. Conductor stringing in span 3(New)-3(Old)<br>4. Old loc. 4 tower dismantling                                                |
| 220KV TAPTITANDA- AMRAPUR CKT I         | IntraState                | 08/08/2026   | 04:11        |            |            | T           | A - Z1, RPH, 29 KM, 3.5 KA.                                                                                                                                                                                                                                                                                 |
| KALMESHVAR-PANDHURNA                    | IntraState                | 18/08/2026   | 19:16        |            |            | HT          | H/T AT PANDHURNA END.                                                                                                                                                                                                                                                                                       |
| NAGOTHANE - IPCL                        | IntraState                | 19/08/2026   | 02:16        | 19/08/2026 | 14:04      | T           | Distance Protection.                                                                                                                                                                                                                                                                                        |
| KARAD - OGALEWADI CKT 1                 | IntraState                | 19/08/2026   | 09:28        | 19/08/2026 | 18:55      | PO          | Back up and LBB relay retrofitting Work by agency                                                                                                                                                                                                                                                           |
| CHAKAN-BHOSARI 1                        | IntraState                | 19/08/2026   | 09:31        | 19/08/2026 | 10:43      | HT          | For Load management.                                                                                                                                                                                                                                                                                        |
| URAN - APTA 3                           | IntraState                | 19/08/2026   | 10:00        | 19/08/2026 | 19:25      | PO          | Insulator replacement work under Scheme                                                                                                                                                                                                                                                                     |
| VITA - MIRAJ                            | IntraState                | 19/08/2026   | 10:15        | 19/08/2026 | 12:19      | PO          | Diagnostic Testing Work                                                                                                                                                                                                                                                                                     |
| TEMBHURNI - VITTHAL SUGAR CO GEN (VSSK) | IntraState                | 19/08/2026   | 10:30        | 19/08/2026 | 14:35      | PO          | Outage is required for Quarterly Maintenance                                                                                                                                                                                                                                                                |
| BARAMATI - KURKUMBH                     | IntraState                | 19/08/2026   | 10:50        |            |            | PO          | Replacement of 220KV CB under LE Scheme                                                                                                                                                                                                                                                                     |
| MIRAJ - ICHALKARANJI                    | IntraState                | 19/08/2026   | 12:27        | 19/08/2026 | 13:07      | PO          | Diagnostic Testing Work                                                                                                                                                                                                                                                                                     |
| BHALVANI - VARKUTI                      | IntraState                | 19/08/2026   | 13:15        | 19/08/2026 | 19:00      | PO          | For Checking of Auto Reclose working operations                                                                                                                                                                                                                                                             |
| Aux Bus @ SOUTH SOLAPUR (KUMBHARI)      | IntraState                | 19/08/2026   | 15:50        | 19/08/2026 | 17:20      | PO          | Outage is required for Quarterly Maintenance                                                                                                                                                                                                                                                                |
| NEW KOYNA - PEDAMBE                     | IntraState                | 19/08/2026   | 17:16        | 19/08/2026 | 21:40      | PO          | Old electromechanical LBB relay replace with Numerical relay                                                                                                                                                                                                                                                |
| VAIRAG - AVAADA SOLAPUR (PANGAON)       | IntraState                | 19/08/2026   | 17:30        | 19/08/2026 | 20:17      | PO          | Outage is required for Quarterly Maintenance                                                                                                                                                                                                                                                                |
| 220KV KUDUS-BORIVALI(M) CKT - 1         | IntraState                | 19/08/2026   | 19:04        | 20/08/2026 | 00:58      | EO          | Due to system constraint of ICTs Loading, We requires hand-trip of 220kV Kudus-Borivali- 1 along with ICT-1 for laod management on ICT-2 during outage period.                                                                                                                                              |
| SOUTH SOLAPUR - TP SOURYA BAY           | IntraState                | 19/08/2026   | 19:05        | 19/08/2026 | 20:03      | PO          | Outage is required for Quarterly Maintenance                                                                                                                                                                                                                                                                |
| TBC @ SOUTH SOLAPUR                     | IntraState                | 19/08/2026   | 19:55        | 19/08/2026 | 17:25      | PO          | Outage is required for Quarterly Maintenance                                                                                                                                                                                                                                                                |
| BABLESHWAR- ALEPHATA CKT - 1            | IntraState                | 20/08/2026   | 06:53        | 20/08/2026 | 08:58      | EO          | To replace faulty insulator Disc found in PID report at tower loc 90 & 92.<br>At loc 90<br>220 kV BBR Alephata ∠ R phase 4 disc faulty ( C-4,7,8,12)<br>220 kV Utech Khed City ∠ Y phase ∠ 4 disc faulty ( A-4,6,9,12 )<br>At Loc 92<br>220 kV Utech Khed City ∠ Y phase ∠ 5 disc faulty (A-4, C-5,7,11,12) |

**State Load Despatch Center,Airoli (MSETCL)**  
**Details of Line outages/Trippings for 19/Aug/2026**

**Statement-VII**

Position as on 6.30 Hrs of 20/Aug/2026

| Name of Line                            | Inter State / Intra State | Tripped Date | Tripped Time | Sync. Date | Sync. Time | Outage Type | Reason of Outage                                                                                                                                                                                                                                                                                                     |
|-----------------------------------------|---------------------------|--------------|--------------|------------|------------|-------------|----------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|
| UTECH SUGAR - KHED CITY                 | IntraState                | 20/08/2026   | 06:56        | 20/08/2026 | 08:43      | EO          | 2 Reason To replace faulty insulator Disc found in PID report at tower loc 90 & 92.<br>At loc 90<br>220 kV BBR Alephata ∠ R phase 4 disc faulty ( C-4,7,8,12)<br>220 kV Utech Khed City ∠ Y phase ∠ 4 disc faulty ( A-4,6,9,12 )<br>At Loc 92<br>220 kV Utech Khed City ∠ Y phase ∠ 5 disc faulty (A-4, C-5,7,11,12) |
| KARAD - OGALEWADI CKT 1                 | IntraState                | 20/08/2026   | 08:58        |            |            | PO          | Back up and LBB relay retrofitting Work by agency                                                                                                                                                                                                                                                                    |
| <b>220 KV ICT Outages/Trippings</b>     |                           |              |              |            |            |             |                                                                                                                                                                                                                                                                                                                      |
| 220/132 KV 100MVA ICT 2 @ SOUTH SOLAPUR | IntraState                | 31/07/2026   | 09:37        |            |            | PO          | For 200MVA 220/132KV BBL ICT Augmentation Work                                                                                                                                                                                                                                                                       |
| 220/22 KV 50 MVA PTR 2 @ TALOJA         | IntraState                | 16/08/2026   | 04:27        |            |            | T           | Fire                                                                                                                                                                                                                                                                                                                 |
| 220/33KV 50MVA PTR 3 @ VITA             | IntraState                | 19/08/2026   | 10:15        | 19/08/2026 | 16:10      | PO          | For relay testing work                                                                                                                                                                                                                                                                                               |
| 220/33 KV 50 MVA PTR 2 @ HAMIDWADA      | IntraState                | 19/08/2026   | 10:30        | 19/08/2026 | 14:00      | PO          | Quarterly Maintenance work, attending oil leakage on TF Top & Diagnostic testing work                                                                                                                                                                                                                                |
| 220/132KV 200MVA ICT 2 @ JEUR           | IntraState                | 19/08/2026   | 10:30        | 19/08/2026 | 12:10      | PO          | Tan-delta testing of HV/LV bushings & Wdgs by MTU, Pune                                                                                                                                                                                                                                                              |
| 220/132 KV 100 MVA ICT 1 @ BHENDA       | IntraState                | 19/08/2026   | 16:30        | 19/08/2026 | 18:50      | EO          | for observation and check of NIFPS NRPV due to line fault PNRV Indication                                                                                                                                                                                                                                            |
| 220/132KV 200MVA ICT 2 @ PANDHARPUR     | IntraState                | 20/08/2026   | 10:10        |            |            | PO          | Replacement of Two nos of higher Tan deltaValue LV CT ( R phase and B phase)                                                                                                                                                                                                                                         |
| <b>220 KV BUSBAR Outages/Trippings</b>  |                           |              |              |            |            |             |                                                                                                                                                                                                                                                                                                                      |
| NTT NEON (DC 13)-BUS-1                  | IntraState                | 25/07/2026   | 11:50        |            |            | PO          | 220 KV BUS-1, CT (100/1 to 200/1 ) replacement work                                                                                                                                                                                                                                                                  |
| MAIN BUS - 2 @ PRINT HOUSE              | IntraState                | 31/07/2026   | 17:12        |            |            | PO          | 1)For Installation of bus-2 link to newly erected 220kV GIS bay for commissioning of TF 3<br>2) Bus bar Protection out for new bay integration                                                                                                                                                                       |
| MAIN BUS SECTION-2 @ MAHAPE             | IntraState                | 08/08/2026   | 07:00        |            |            | PO          | Strengthening of Auxilliary bus by HTLS conductor.                                                                                                                                                                                                                                                                   |
| <b>132 KV LINE Outages/Trippings</b>    |                           |              |              |            |            |             |                                                                                                                                                                                                                                                                                                                      |
| MANSAR-PENCH                            | InterState                | 20/08/2026   | 05:17        | 20/08/2026 | 07:47      | T           | Distance Protection.                                                                                                                                                                                                                                                                                                 |
| <b>110 KV LINE Outages/Trippings</b>    |                           |              |              |            |            |             |                                                                                                                                                                                                                                                                                                                      |
| KALWA KALYAN                            | IntraState                | 09/01/2026   | 13:38        |            |            | PO          | For upgradation to 220 kV Kalwa Kalyan line project work                                                                                                                                                                                                                                                             |
| SALSETTE SAKI 4                         | IntraState                | 02/03/2026   | 09:06        |            |            | PO          | EHV cable termination to provide LILO arrangements at IIT Mumbai (Power supply to IIT) at Loc. 22-22B.                                                                                                                                                                                                               |
| SALSETTE VIKHROLI CKT - 1               | IntraState                | 31/07/2026   | 07:24        |            |            | PO          | Metro 4 Project work (Line Raising Job at Shangrilla Crossing, Bhandup):<br>1. Diversion of 220 kV Kalwa Salsette 3 Line on 110kV Salsette Vikhroli 1 Line (TDS bottom Circuit) in section between Bhandup village to loc. 92 (Salsette) for tower erection work at loc. 3 & 4 of TS RoW                             |

**State Load Despatch Center,Airoli (MSETCL)**  
**Details of Line outages/Trippings for 19/Aug/2026**

**Statement-VII**

Position as on 6.30 Hrs of 20/Aug/2026

| Name of Line                | Inter State /<br>Intra State | Tripped<br>Date | Tripped<br>Time | Sync. Date | Sync.<br>Time | Outage<br>Type | Reason of Outage                                                                                                                                                                                                                                                                     |
|-----------------------------|------------------------------|-----------------|-----------------|------------|---------------|----------------|--------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|
| SALSETTE - VIKHROLI CKT - 2 | IntraState                   | 31/07/2026      | 07:24           |            |               | PO             | Metro 4 Project work (Line Raising Job at Shangrilla Crossing, Bhandup):2. Diversion of 220 kV Kalwa Salsette 4 Line on 110kV Salsette Vikhroli 2 Line (TDS bottom Circuit) in section between Bhandup village to loc. 92 (Salsette) for tower erection work at loc. 3 & 4 of TS RoW |

HT : Hand Tripping, T : Tripping, PO : Planned Outage, EO : Emergency Outage