

**State Load Despatch Center, Airoli (MSETCL) Statement I**  
**Daily system Report for 22/Jul/2026 WEDNESDAY**

| I GENERATION (MUs)  |                |                 | II EXCHANGES (MUs)             |                |                  |
|---------------------|----------------|-----------------|--------------------------------|----------------|------------------|
| A) MSPGCL           | Daily          | Monthly         | E) InterState Exchanges        | Daily          | Monthly          |
| 1) Thermal          | 140.236        | 3153.811        | 1) Gujrat                      | -4.059         | -17.621          |
| 2) Hydro            | 8.213          | 243.541         | 2) Madhya Pradesh              | 2.579          | 60.140           |
| 3) Gas              | 6.388          | 141.831         | 3) Chattisgarh                 | 1.910          | 10.040           |
| <b>Total MSPGCL</b> | <b>154.837</b> | <b>3539.183</b> | 4) Maharashtra                 | 181.780        | 3689.588         |
| B) 1) APLM          | 40.659         | 1153.696        | 5) Goa (Amona)                 | -1.905         | -25.781          |
| 2) JSWEL            | 17.276         | 399.404         | <b>Total</b>                   | <b>180.305</b> | <b>3716.366</b>  |
| 3) VIPL             | 12.861         | 276.697         | a) Mumbai Schedule             | 49.733         | 977.102          |
| 4) RPL(AMT)         | 24.186         | 554.248         | b) Mumbai Drawl                | 51.172         | 1025.277         |
| 5) SWPGPL           | 8.142          | 205.861         | c) MSEDCL Bilateral *          | 139.501        | 2744.867         |
| 6) Other IPP        | 11.331         | 293.005         | Include PX                     | 0.000          | 0.002            |
| 7) PGPL             | 0.000          | 0.000           | d) Mumbai Bilateral *          | 49.733         | 977.102          |
| C) 1) TPCL Thermal  | 9.839          | 239.336         | Include PX                     | 0.000          | 0.000            |
| 2) TPCL Hydro       | 4.146          | 85.556          | Standby                        | 0.000          | 0.000            |
| 3) TPCL Gas         | 1.100          | 63.395          | <b>H) ENERGY CATERED (MUs)</b> |                |                  |
| 4) AEML Thermal     | 7.650          | 192.534         | 1) MSEDCL                      | 471.106        | 10588.580        |
| <b>D) STATE</b>     |                |                 | 2) Mumbai Discoms              | 73.907         | 1606.098         |
| 1) Thermal          | 272.180        | 6468.592        | 3) Other Discoms               | 13.396         | 297.014          |
| (A1+C1+C4+(B1-B6))  |                |                 | <b>TOTAL STATE</b>             | <b>558.409</b> | <b>12491.692</b> |
| 2) Hydro            | 12.359         | 329.097         |                                |                |                  |
| (A2+C2)             |                |                 |                                |                |                  |
| 3) Gas              | 7.488          | 205.226         |                                |                |                  |
| (A3+B7+C3)          |                |                 |                                |                |                  |
| 4) Wind             | 73.985         | 1264.964        |                                |                |                  |
| 6) SOLAR            | 12.092         | 507.447         |                                |                |                  |
| <b>TOTAL STATE</b>  | <b>378.104</b> | <b>8775.326</b> |                                |                |                  |

\* Displayed for information, not added in total.

**DETAILS OF MAHARASHTRA STATE PEAK DEMAND(MW) Statement II**

| PARTICULARS                | A. Morning Peak at 10 Hrs | B. Day Peak at 18 Hrs | C. Evening Peak at 20 Hrs | D. Night Minimum at 4 Hrs |
|----------------------------|---------------------------|-----------------------|---------------------------|---------------------------|
| MSPGCL Thermal             | 6102                      | 5894                  | 6311                      | 5900                      |
| MSPGCL Hydro               | 344                       | 362                   | 473                       | 274                       |
| MSPGCL Gas                 | 266                       | 268                   | 268                       | 265                       |
| MSPGCL Total Generation    | 6712                      | 6524                  | 7052                      | 6439                      |
| Central Sector Receipt     | 9080                      | 8360                  | 8226                      | 5812                      |
| WIND                       | 3195                      | 2921                  | 2997                      | 2940                      |
| CPP / IPP Thermal          | 4791                      | 4730                  | 5578                      | 4811                      |
| CPP / IPP Gas              | 0                         | 0                     | 0                         | 0                         |
| SOLAR                      | 1042                      | 432                   | 0                         | 0                         |
| Exchange with Mumbai       | -2623                     | -2509                 | -2009                     | -1423                     |
| <b>MSEDCL DEMAND MET</b>   | <b>21621</b>              | <b>19876</b>          | <b>21257</b>              | <b>18096</b>              |
| Load Shedding              | 0                         | 0                     | 0                         | 0                         |
| MSEDCL DEMAND              | 21621                     | 19876                 | 21257                     | 18096                     |
| TPCL GENERATION            | 516                       | 577                   | 908                       | 609                       |
| AEML GENERATION            | 273                       | 308                   | 410                       | 283                       |
| <b>MUMBAI DEMAND</b>       | <b>3412</b>               | <b>3394</b>           | <b>3327</b>               | <b>2315</b>               |
| <b>OTHER DISCOM DEMAND</b> | <b>576</b>                | <b>582</b>            | <b>587</b>                | <b>483</b>                |
| STATE DEMAND MET           | 25609                     | 23852                 | 25171                     | 20894                     |
| <b>STATE DEMAND</b>        | <b>25609</b>              | <b>23852</b>          | <b>25171</b>              | <b>20894</b>              |
| Frequency (Hz)             | 50.04                     | 50.01                 | 50.02                     | 50.02                     |

**FREQUENCY PARTICULARS**

| MAXIMUM FREQ.         | MINIMUM FREQ.         | AVERAGE FREQ. | FREQ. BELOW 49.4 Hz |
|-----------------------|-----------------------|---------------|---------------------|
| 50.34 Hz at 18.02 Hrs | 49.76 Hz at 02.36 Hrs | 50            | 0 % of Time(min)    |

Note : The report is based on Operational Data and is for statistical purpose only.

## Daily and Progressive Generation,Maximum,Minimum for 22/Jul/2026

| Generating unit    | Generation   |               |          |          |
|--------------------|--------------|---------------|----------|----------|
|                    | Daily (Mus)  | Monthly (Mus) | Max (MW) | Min (MW) |
| <b>Koradi</b>      |              |               |          |          |
| Unit 6             | 2.50         | 68.78         | 144      | 59       |
| Unit 8             | 9.98         | 210.43        | 512      | 346      |
| Unit 9             | 9.97         | 245.28        | 487      | 363      |
| Unit 10            | 9.32         | 239.46        | 450      | 330      |
| <b>Total</b>       | <b>31.77</b> | <b>763.95</b> |          |          |
| <b>Bhusawal</b>    |              |               |          |          |
| Unit 3             | 3.12         | 61.12         | 140      | 120      |
| Unit 4             | 8.24         | 187.55        | 465      | 290      |
| Unit 5             | 0.00         | 33.86         | 0        | 0        |
| Unit 6             | 12.92        | 222.62        | 607      | 379      |
| <b>Total</b>       | <b>24.28</b> | <b>505.15</b> |          |          |
| <b>Parli</b>       |              |               |          |          |
| Unit 6             | 3.61         | 90.55         | 159      | 135      |
| Unit 7             | 3.70         | 86.67         | 180      | 144      |
| Unit 8             | 3.92         | 95.78         | 231      | 145      |
| <b>Total</b>       | <b>11.24</b> | <b>273.00</b> |          |          |
| <b>Chandrapur</b>  |              |               |          |          |
| Unit 3             | 2.82         | 65.28         | 129      | 103      |
| Unit 4             | 2.61         | 58.94         | 128      | 85       |
| Unit 5             | 7.06         | 163.79        | 330      | 264      |
| Unit 6             | 7.21         | 151.28        | 345      | 263      |
| Unit 7             | 0.00         | 27.69         | 0        | 0        |
| Unit 8             | 8.64         | 181.10        | 430      | 273      |
| Unit 9             | 8.73         | 192.70        | 432      | 294      |
| <b>Total</b>       | <b>37.06</b> | <b>840.78</b> |          |          |
| <b>Paras</b>       |              |               |          |          |
| Unit 3             | 0.00         | 79.93         | 0        | 0        |
| Unit 4             | 4.10         | 91.13         | 203      | 150      |
| <b>Total</b>       | <b>4.10</b>  | <b>171.06</b> |          |          |
| <b>Khaparkheda</b> |              |               |          |          |
| Unit 1             | 3.18         | 70.42         | 160      | 115      |
| Unit 2             | 2.73         | 67.57         | 132      | 98       |
| Unit 3             | 3.37         | 73.75         | 163      | 129      |
| Unit 4             | 3.56         | 11.68         | 178      | 128      |
| Unit 5             | 10.05        | 216.16        | 460      | 320      |
| <b>Total</b>       | <b>22.88</b> | <b>439.58</b> |          |          |
| <b>Nasik</b>       |              |               |          |          |
| Unit 3             | 2.96         | 42.60         | 129      | 119      |
| Unit 4             | 3.14         | 53.58         | 157      | 125      |
| Unit 5             | 2.80         | 64.10         | 138      | 109      |
| <b>Total</b>       | <b>8.90</b>  | <b>160.28</b> |          |          |
| <b>Uran</b>        |              |               |          |          |
| All Units          | 6.39         | 141.83        | 271      | 263      |
| <b>Total</b>       | <b>6.39</b>  | <b>141.83</b> |          |          |
| <b>PGPL</b>        |              |               |          |          |
| Unit 1             | 0.00         | 0.00          | 0        | 0        |
| Unit 2             | 0.00         | 0.00          | 0        | 0        |
| <b>Total</b>       | <b>0.00</b>  | <b>0.00</b>   |          |          |
| <b>PENCH (MS)</b>  |              |               |          |          |
| Pench (MS)         | 0.23         | 2.30          | 21       | 0        |
| <b>Total</b>       | <b>0.23</b>  | <b>2.30</b>   |          |          |
| <b>Koyna</b>       |              |               |          |          |

| Generating unit | Generation    |                |          |          |
|-----------------|---------------|----------------|----------|----------|
|                 | Daily (Mus)   | Monthly (Mus)  | Max (MW) | Min (MW) |
| Stage 1-2       | 1.07          | 38.61          | 50       | 40       |
| Stage 4         | 0.00          | 47.54          | 0        | 0        |
| Stage 3         | 0.62          | 29.14          | 122      | 0        |
| <b>Total</b>    | <b>1.69</b>   | <b>115.29</b>  |          |          |
| <b>Hydro</b>    |               |                |          |          |
| KDPH            | 0.00          | 0.00           | 0        | 0        |
| VTRNA           | 0.46          | 5.75           | 60       | 0        |
| TILLARI         | 0.45          | 5.52           | 62       | 0        |
| BHIRA T.R.      | 0.40          | 7.99           | 80       | 0        |
| SMLHY_PTN       | 5.21          | 96.19          | 240      | 189      |
| GHATGHAR        | 0.00          | 12.80          | 0        | 0        |
| <b>Total</b>    | <b>6.52</b>   | <b>128.25</b>  |          |          |
| <b>Wind</b>     |               |                |          |          |
| Total           | 73.98         | 1264.96        | 0        | 0        |
| <b>Total</b>    | <b>73.98</b>  | <b>1264.96</b> |          |          |
| <b>CPP</b>      |               |                |          |          |
| APML(Mus)       | 40.66         | 1153.70        | 0        | 0        |
| JSWEL(Mus)      | 17.28         | 399.40         | 0        | 0        |
| VIPL(Mus)       | 12.86         | 276.70         | 0        | 0        |
| RPLAMT-Mus      | 24.19         | 554.25         | 0        | 0        |
| SWPGPL-Mus      | 8.14          | 205.86         | 0        | 0        |
| Dhariwal        | 0.00          | 0.00           | 0        | 0        |
| IEPL            | 5.36          | 117.13         | 254      | 158      |
| Other(Mus)      | 1.60          | 35.58          | 0        | 0        |
| JPL             | 3.18          | 117.03         | 138      | 118      |
| <b>Total</b>    | <b>113.27</b> | <b>2859.65</b> |          |          |
| <b>SOLAR</b>    |               |                |          |          |
| Total           | 12.09         | 507.45         | 0        | 0        |
| <b>Total</b>    | <b>12.09</b>  | <b>507.45</b>  |          |          |
| <b>Tata</b>     |               |                |          |          |
| Trombay 5       | 6.51          | 157.39         | 394      | 250      |
| Trombay 6       | 0.00          | 0.00           | 0        | 0        |
| Trombay 7A      | 0.76          | 36.93          | 110      | 0        |
| Trombay 7B      | 0.34          | 26.47          | 53       | 0        |
| TATA Hydro      | 4.15          | 85.56          | 341      | 91       |
| Trombay 8       | 3.33          | 81.95          | 223      | 125      |
| <b>Total</b>    | <b>15.08</b>  | <b>388.29</b>  |          |          |
| <b>AEML</b>     |               |                |          |          |
| DTPS U-1&2      | 7.65          | 192.53         | 455      | 270      |
| <b>Total</b>    | <b>7.65</b>   | <b>192.53</b>  |          |          |

| * Infirm Power |             |         | Summary         |             |               | Summary             |             |               |
|----------------|-------------|---------|-----------------|-------------|---------------|---------------------|-------------|---------------|
| Particulars    | Daily (Mus) | Monthly | Particulars     | Daily (Mus) | Monthly (Mus) | Particulars         | Daily (Mus) | Monthly (Mus) |
|                |             |         | MSPGCL Thermal  | 140.24      | 3153.81       | MSPGCL Total        | 154.84      | 3539.18       |
|                |             |         | MSPGCL Thml+Gas | 146.62      | 3295.64       | Koyna 1,2 & 4 Total | 1.07        | 86.15         |
|                |             |         | MSPGCL Hydro    | 8.21        | 243.54        | State Total         | 378.10      | 8775.33       |

# State Load Despatch Center,Airoli (MSETCL)

## Annexure-2

Hourly Load Data As on 22/Jul/2026

| TIME SR. NO. | MSPGCL GEN. |      |      | TOTAL  | WIND  | CPP / IPP |      | SOLAR | CS SHARE | CS RECPT | Mum. NET EXCH. | MSEDC L DEM. MET | Load Shedding |                          | MSEDC L DEM. WITH LS | MUMBAI DEMAND | OTHER DISCOM DEMAND | STATE DEMAND | FREQ. (Hz) |
|--------------|-------------|------|------|--------|-------|-----------|------|-------|----------|----------|----------------|------------------|---------------|--------------------------|----------------------|---------------|---------------------|--------------|------------|
|              | THM         | HY   | GAS  |        |       | THM       | GAS  |       |          |          |                |                  | Planned       | *Transmission Constraint |                      |               |                     |              |            |
| 1            | 5922        | 253  | 264  | 6439   | 3034  | 4989      | 0    | 0     | 6495     | 6209     | -1580          | 18572            | 0             | 0                        | 18572                | 2789          | 519                 | 21880        | 49.94      |
| 2            | 5705        | 229  | 266  | 6200   | 2913  | 4782      | 0    | 0     | 6498     | 6315     | -1601          | 18113            | 0             | 0                        | 18113                | 2583          | 496                 | 21192        | 49.96      |
| 3            | 5866        | 253  | 264  | 6383   | 2912  | 4797      | 0    | 0     | 6049     | 5978     | -1547          | 18025            | 0             | 0                        | 18025                | 2439          | 498                 | 20962        | 49.92      |
| 4            | 5900        | 274  | 265  | 6439   | 2940  | 4811      | 0    | 0     | 6227     | 5812     | -1423          | 18093            | 0             | 0                        | 18093                | 2315          | 486                 | 20894        | 50.02      |
| 5            | 5862        | 261  | 264  | 6387   | 3076  | 4766      | 0    | 0     | 6477     | 6136     | -1388          | 18478            | 0             | 0                        | 18478                | 2257          | 499                 | 21234        | 49.98      |
| 6            | 5640        | 296  | 263  | 6199   | 3252  | 4771      | 0    | 0     | 7731     | 7242     | -1495          | 19474            | 0             | 0                        | 19474                | 2336          | 495                 | 22305        | 50.02      |
| 7            | 5725        | 417  | 269  | 6411   | 3099  | 4784      | 0    | 75    | 8278     | 8282     | -1619          | 20495            | 0             | 0                        | 20495                | 2509          | 537                 | 23541        | 50.00      |
| 8            | 6083        | 454  | 266  | 6803   | 3141  | 4770      | 0    | 322   | 8026     | 8933     | -1946          | 21467            | 0             | 0                        | 21467                | 2747          | 556                 | 24770        | 49.95      |
| 9            | 6136        | 457  | 267  | 6860   | 3206  | 4756      | 0    | 660   | 8659     | 8971     | -2314          | 21572            | 0             | 0                        | 21572                | 3083          | 567                 | 25222        | 50.03      |
| 10           | 6102        | 344  | 266  | 6712   | 3195  | 4791      | 0    | 1042  | 9319     | 9080     | -2623          | 21617            | 0             | 0                        | 21617                | 3412          | 580                 | 25609        | 50.04      |
| 11           | 5373        | 338  | 265  | 5976   | 3317  | 4162      | 0    | 1393  | 10041    | 9706     | -2936          | 21027            | 0             | 0                        | 21027                | 3706          | 591                 | 25324        | 50.03      |
| 12           | 5222        | 350  | 266  | 5838   | 3204  | 4126      | 0    | 1688  | 9503     | 8890     | -3081          | 20077            | 0             | 0                        | 20077                | 3862          | 588                 | 24527        | 49.99      |
| 13           | 5179        | 282  | 266  | 5727   | 3263  | 3899      | 0    | 1701  | 8483     | 7774     | -3017          | 18763            | 0             | 0                        | 18763                | 3806          | 584                 | 23153        | 49.93      |
| 14           | 5131        | 267  | 265  | 5663   | 3281  | 3719      | 0    | 1699  | 7707     | 8332     | -2890          | 19237            | 0             | 0                        | 19237                | 3663          | 567                 | 23467        | 50.08      |
| 15           | 5315        | 252  | 266  | 5833   | 3126  | 4015      | 0    | 1360  | 7898     | 7696     | -2757          | 18685            | 0             | 0                        | 18685                | 3562          | 588                 | 22835        | 49.98      |
| 16           | 5453        | 241  | 264  | 5958   | 3123  | 4213      | 0    | 971   | 8271     | 8190     | -2639          | 19238            | 0             | 0                        | 19238                | 3449          | 578                 | 23265        | 50.01      |
| 17           | 6040        | 311  | 265  | 6616   | 2965  | 4601      | 0    | 710   | 8203     | 7660     | -2600          | 19374            | 0             | 0                        | 19374                | 3407          | 578                 | 23359        | 50.01      |
| 18           | 5894        | 362  | 268  | 6524   | 2921  | 4730      | 0    | 432   | 8279     | 8360     | -2509          | 19872            | 0             | 0                        | 19872                | 3394          | 586                 | 23852        | 50.01      |
| 19           | 6393        | 447  | 267  | 7107   | 3031  | 5545      | 0    | 39    | 7743     | 7866     | -2023          | 20980            | 0             | 0                        | 20980                | 3387          | 585                 | 24952        | 50.11      |
| 20           | 6311        | 473  | 268  | 7052   | 2997  | 5578      | 0    | 0     | 8520     | 8226     | -2009          | 21253            | 0             | 0                        | 21253                | 3327          | 591                 | 25171        | 50.02      |
| 21           | 6349        | 433  | 267  | 7049   | 2935  | 5661      | 0    | 0     | 7590     | 7219     | -1949          | 20340            | 0             | 0                        | 20340                | 3186          | 575                 | 24101        | 50.02      |
| 22           | 6449        | 418  | 267  | 7134   | 3011  | 5860      | 0    | 0     | 6797     | 6049     | -1800          | 19648            | 0             | 0                        | 19648                | 3017          | 606                 | 23271        | 50.01      |
| 23           | 6173        | 442  | 269  | 6884   | 3035  | 5287      | 0    | 0     | 6372     | 5752     | -1783          | 18588            | 0             | 0                        | 18588                | 2890          | 587                 | 22065        | 49.99      |
| 24           | 6013        | 359  | 271  | 6643   | 3008  | 5042      | 0    | 0     | 6213     | 5627     | -1643          | 18119            | 0             | 0                        | 18119                | 2781          | 558                 | 21458        | 50.01      |
| MUs          | 140.24      | 8.21 | 6.39 | 154.84 | 73.98 | 114.45    | 0.00 | 12.09 | 185.38   | 180.31   | -51.17         | 471.11           | 0.00          | 0.00                     | 471.11               | 73.91         | 13.40               | 558.41       | 50.00      |

NOTE : ALL VALUES IN MW

Mumbai Net Exch is shown with reference to MSETCL system and (-) sign indicates MSETCL periphery to Mumbai system.

\*Load Shedding due to Transmission Constraint :-

| Maximum Demand scenario for the date 22/Jul/2026 |                                    |                                   |
|--------------------------------------------------|------------------------------------|-----------------------------------|
| State Demand                                     | MSEDC L Non-Coincident Peak Demand | Mumbai Non-Coincident Peak Demand |
| 25609 MW                                         | 21617 MW                           | 3862 MW                           |
| 10 Hrs                                           | 10 Hrs                             | 12 Hrs                            |
| Includes LS - 0 MW                               | Includes LS - 0 MW                 | --                                |

**State Load Despatch Center,Airoli (MSETCL)      Statement-VI**  
**Details of Generating Unit Outages/Trippings for 22/Jul/2026**

**Position as on 6.30 Hrs of 23/Jul/2026**

| Generating Company            | Name of Generating Unit | Capacity | Tripped Date | Tripped Time | Sync.Date  | Sync. Time | Reason of Outage                                                                            | Expected Date |
|-------------------------------|-------------------------|----------|--------------|--------------|------------|------------|---------------------------------------------------------------------------------------------|---------------|
| PLANNED OUTAGE                |                         |          |              |              |            |            |                                                                                             |               |
| MSPGCL                        |                         |          |              |              |            |            |                                                                                             |               |
| MSPGCL                        | Koyna Unit 12           | 80       | 15/06/2026   | 10:00        |            | Continued. | COH                                                                                         | 13/08/2026    |
| MSPGCL                        | Bhusawal Unit 5         | 500      | 05/07/2026   | 01:01        |            | Continued. | Capital Overhaul for 35 days                                                                | 09/08/2026    |
| MSPGCL                        | Chandrapur Unit 7       | 500      | 06/07/2026   | 14:13        |            | Continued. | COH                                                                                         | 10/08/2026    |
| Total Capacity MSPGCL         |                         | 1080     |              |              |            |            |                                                                                             |               |
| IPP                           |                         |          |              |              |            |            |                                                                                             |               |
| IPP                           | SWPGPL U-2              | 135      | 11/07/2026   | 23:38        |            | Continued. | AOH                                                                                         | 30/07/2026    |
| IPP                           | Adani U-2               | 660      | 20/07/2026   | 01:12        |            | Continued. | Planned COH .                                                                               | 10/08/2026    |
| IPP                           | RPL(AMT) U-1            | 270      | 21/07/2026   | 00:00        |            | Continued. | withdrawn for Boiler licence renewal & other maintenance work.                              | 01/08/2026    |
| Total Capacity IPP            |                         | 1065     |              |              |            |            |                                                                                             |               |
| Total Capacity PLANNED OUTAGE |                         | 2145     |              |              |            |            |                                                                                             |               |
| FORCED OUTAGE                 |                         |          |              |              |            |            |                                                                                             |               |
| MSPGCL                        |                         |          |              |              |            |            |                                                                                             |               |
| MSPGCL                        | Uran Unit A0            | 120      | 21/04/2026   | 21:37        |            | Continued. | Gas Skid Trip                                                                               | 31/12/2026    |
| MSPGCL                        | Ghatghar Unit-1         | 125      | 17/05/2026   | 08:52        |            | Continued. | Stator Earth Fault                                                                          | 15/08/2026    |
| MSPGCL                        | Paras Unit 3            | 250      | 20/07/2026   | 18:45        | 23/07/2026 | 03:11      | due to both BFP Tripped                                                                     | 23/07/2026    |
| MSPGCL                        | Koyna Unit 10           | 80       | 20/07/2026   | 20:25        |            | Continued. | Tripped on Over current                                                                     |               |
| MSPGCL                        | Chandrapur Unit 3       | 210      | 23/07/2026   | 03:24        |            | Continued. | APH-3B both AC and DC motor 2decoupled and flue gas temperature increased                   | 24/07/2026    |
| Total Capacity MSPGCL         |                         | 535      |              |              |            |            |                                                                                             |               |
| TPC-G                         |                         |          |              |              |            |            |                                                                                             |               |
| TPC-G                         | Trombay 7A              | 120      | 22/07/2026   | 05:43        | 22/07/2026 | 19:09      | Oil leak from GTG Lube oil system.                                                          |               |
| TPC-G                         | Trombay 7B              | 60       | 22/07/2026   | 05:43        | 22/07/2026 | 22:08      | Oil leak from GTG Lube oil system.                                                          |               |
| Total Capacity TPC-G          |                         | 0        |              |              |            |            |                                                                                             |               |
| IPP                           |                         |          |              |              |            |            |                                                                                             |               |
| IPP                           | LMEL Unit 3             | 30       | 01/06/2026   | 00:04        |            | Continued. | steam unavailability                                                                        | 31/08/2026    |
| IPP                           | JSW (J) U1              | 300      | 06/07/2026   | 16:43        |            | Continued. | Turbine bearing Vabration high                                                              | 31/07/2026    |
| IPP                           | JPL Unit 1              | 150      | 20/07/2026   | 23:47        | 22/07/2026 | 23:32      | withdrawn due to a bottom ash conveying issue caused by a breakdown of the clinker grinder. |               |
| IPP                           | VMEPL Unit 1            | 60       | 21/07/2026   | 08:23        | 22/07/2026 | 10:45      | Boiler Issue                                                                                |               |
| IPP                           | VMEPL Unit 1            | 60       | 22/07/2026   | 12:18        |            | Continued. | Boiler Issue                                                                                |               |
| IPP                           | VMEPL Unit 2            | 60       | 22/07/2026   | 15:03        | 22/07/2026 | 18:29      | Boiler Issue                                                                                |               |
| Total Capacity IPP            |                         | 390      |              |              |            |            |                                                                                             |               |
| Total Capacity FORCED OUTAGE  |                         | 925      |              |              |            |            |                                                                                             |               |

**State Load Despatch Center,Airoli (MSETCL)      Statement-VI**  
**Details of Generating Unit Outages/Trippings for 22/Jul/2026**

Position as on 6.30 Hrs of 23/Jul/2026

| Generating Company                            | Name of Generating Unit | Capacity | Tripped Date | Tripped Time | Sync.Date | Sync. Time | Reason of Outage                                                                                                                                            | Expected Date |
|-----------------------------------------------|-------------------------|----------|--------------|--------------|-----------|------------|-------------------------------------------------------------------------------------------------------------------------------------------------------------|---------------|
| UNIT UNDER ZERO SCHEDULE / RSD                |                         |          |              |              |           |            |                                                                                                                                                             |               |
| MSPGCL                                        |                         |          |              |              |           |            |                                                                                                                                                             |               |
| MSPGCL                                        | Uran Unit 5             | 108      | 17/07/2026   | 07:56        |           | Continued. | No Schedule by buyer due to open cycle operation High cost.                                                                                                 |               |
| MSPGCL                                        | Uran Unit 6             | 108      | 19/07/2026   | 06:50        |           | Continued. | No Schedule by buyer due to open cycle operation High cost.                                                                                                 |               |
| Total Capacity MSPGCL                         |                         | 216      |              |              |           |            |                                                                                                                                                             |               |
| Total Capacity UNIT UNDER ZERO SCHEDULE / RSD |                         | 216      |              |              |           |            |                                                                                                                                                             |               |
| FORCED OUTAGE DUE TO NO PPA                   |                         |          |              |              |           |            |                                                                                                                                                             |               |
| IPP                                           |                         |          |              |              |           |            |                                                                                                                                                             |               |
| IPP                                           | PGPL U1                 | 262      | 07/02/2017   | 17.30        |           | Continued. | No Schedule (NO PPA)                                                                                                                                        |               |
| IPP                                           | PGPL U2                 | 126      | 07/02/2017   | 17.30        |           | Continued. | No Schedule.(NO PPA)                                                                                                                                        |               |
| Total Capacity IPP                            |                         | 388      |              |              |           |            |                                                                                                                                                             |               |
| Total Capacity FORCED OUTAGE DUE TO NO PPA    |                         | 388      |              |              |           |            |                                                                                                                                                             |               |
| OUTAGE DUE TO FUEL SHORTAGE                   |                         |          |              |              |           |            |                                                                                                                                                             |               |
| MSPGCL                                        |                         |          |              |              |           |            |                                                                                                                                                             |               |
| MSPGCL                                        | Koyna Unit 1            | 70       | 18/07/2026   | 13:15        |           | Continued. | Vide CE, Koyna email dtd. 18.07.2026, Koyna Units cannot be operated for power generation until further permission from WRD.( 5 MW is on bar for spinning ) |               |
| MSPGCL                                        | Koyna Unit 8            | 80       | 18/07/2026   | 13:15        |           | Continued. | Vide CE, Koyna email dtd. 18.07.2026, Koyna Units cannot be operated for power generation until further permission from WRD.( 5 MW is on bar for spinning ) |               |
| MSPGCL                                        | Koyna Unit 7            | 80       | 18/07/2026   | 13:15        |           | Continued. | Vide CE, Koyna email dtd. 18.07.2026, Koyna Units cannot be operated for power generation until further permission from WRD.( 5 MW is on bar for spinning ) |               |
| MSPGCL                                        | Koyna STG-IV Unit-4     | 250      | 18/07/2026   | 13:15        |           | Continued. | Vide CE, Koyna email dtd. 18.07.2026, Koyna Units cannot be operated for power generation until further permission from WRD.                                |               |
| MSPGCL                                        | Koyna STG-IV Unit-3     | 250      | 18/07/2026   | 13:15        |           | Continued. | Vide CE, Koyna email dtd. 18.07.2026, Koyna Units cannot be operated for power generation until further permission from WRD.                                |               |
| MSPGCL                                        | Koyna Unit 2            | 70       | 18/07/2026   | 13:15        |           | Continued. | Vide CE, Koyna email dtd. 18.07.2026, Koyna Units cannot be operated for power generation until further permission from                                     |               |

**State Load Despatch Center, Airoli (MSETCL)      Statement-VI**  
**Details of Generating Unit Outages/Trippings for 22/Jul/2026**

**Position as on 6.30 Hrs of 23/Jul/2026**

| Generating Company                                | Name of Generating Unit | Capacity | Tripped Date | Tripped Time | Sync.Date | Sync. Time | Reason of Outage                                                                                                                                            | Expected Date |
|---------------------------------------------------|-------------------------|----------|--------------|--------------|-----------|------------|-------------------------------------------------------------------------------------------------------------------------------------------------------------|---------------|
|                                                   |                         |          |              |              |           |            | WRD.( 5 MW is on bar for spinning )                                                                                                                         |               |
| MSPGCL                                            | Koyna STG-IV Unit-1     | 250      | 18/07/2026   | 13:15        |           | Continued. | Vide CE, Koyna email dtd. 18.07.2026, Koyna Units cannot be operated for power generation until further permission from WRD.                                |               |
| MSPGCL                                            | Koyna Unit 4            | 70       | 18/07/2026   | 13:15        |           | Continued. | Vide CE, Koyna email dtd. 18.07.2026, Koyna Units cannot be operated for power generation until further permission from WRD.( 5 MW is on bar for spinning ) |               |
| MSPGCL                                            | Koyna Unit 5            | 80       | 18/07/2026   | 13:15        |           | Continued. | Vide CE, Koyna email dtd. 18.07.2026, Koyna Units cannot be operated for power generation until further permission from WRD.( 5 MW is on bar for spinning ) |               |
| MSPGCL                                            | Koyna Unit 6            | 80       | 18/07/2026   | 13:15        |           | Continued. | Vide CE, Koyna email dtd. 18.07.2026, Koyna Units cannot be operated for power generation until further permission from WRD.( 5 MW is on bar for spinning ) |               |
| MSPGCL                                            | Koyna Unit 3            | 70       | 18/07/2026   | 13:15        |           | Continued. | Vide CE, Koyna email dtd. 18.07.2026, Koyna Units cannot be operated for power generation until further permission from WRD.( 5 MW is on bar for spinning ) |               |
| MSPGCL                                            | Koyna STG-IV Unit-2     | 250      | 18/07/2026   | 13:16        |           | Continued. | Vide CE, Koyna email dtd. 18.07.2026, Koyna Units cannot be operated for power generation until further permission from WRD.                                |               |
| <b>Total Capacity MSPGCL</b>                      |                         | 1600     |              |              |           |            |                                                                                                                                                             |               |
| <b>Total Capacity OUTAGE DUE TO FUEL SHORTAGE</b> |                         | 1600     |              |              |           |            |                                                                                                                                                             |               |

\* Other generator generating power instead of contracted genertaor with tri-party agreement in between generatos & discom (Case-IV bidding)

**State Load Despatch Center,Airoli (MSETCL)**  
**Details of Line outages/Trippings for 22/Jul/2026**

**Statement-VII**

Position as on 6.30 Hrs of 23/Jul/2026

| Name of Line                                                           | Inter State / Intra State | Tripped Date | Tripped Time | Sync. Date | Sync. Time | Outage Type | Reason of Outage                                                                                                                                                                                                 |
|------------------------------------------------------------------------|---------------------------|--------------|--------------|------------|------------|-------------|------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|
| <b>765 KV ICT Outages/Trippings</b>                                    |                           |              |              |            |            |             |                                                                                                                                                                                                                  |
| 765/400KV 1500MVA ICT @ AKOLA 2                                        | IntraState                | 22/07/2026   | 04:25        | 22/07/2026 | 10:35      | T           | tripped on Y_PRD1_MAIN operated                                                                                                                                                                                  |
| <b>400 KV TIEBAY Outages/Trippings</b>                                 |                           |              |              |            |            |             |                                                                                                                                                                                                                  |
| TIE BAY (411) LINE - 1 OF KORADI-2 @ KORADI 3                          | IntraState                | 22/07/2026   | 13:02        | 22/07/2026 | 21:37      | HT          | To attend z-1 differential current alarm (phase-1 & phase-3) rectification work. In tie bay(411) - 400kv-koradi-ii-koradi-iii-1 and future at koradi-iii - 400kv at koradi.                                      |
| <b>400 KV MAINBAY Outages/Trippings</b>                                |                           |              |              |            |            |             |                                                                                                                                                                                                                  |
| MAIN BAY - 404 OF STATION TF-3 @ KORADI 2                              | InterState                | 21/07/2026   | 19:23        | 22/07/2026 | 18:22      | T           | Tripped on PDR optd.                                                                                                                                                                                             |
| <b>400 KV LR Outages/Trippings</b>                                     |                           |              |              |            |            |             |                                                                                                                                                                                                                  |
| 50 MVAR LINE REACTOR OF 400KV KUMBHARGAON(NANDED) CKT 1 AT 400KV PARLI | IntraState                | 05/03/2025   | 20:45        |            |            | HT          | Due to Voltage constraint LR kept out at Parly ss.                                                                                                                                                               |
| <b>400 KV LINE Outages/Trippings</b>                                   |                           |              |              |            |            |             |                                                                                                                                                                                                                  |
| DHULE - SSNNL CKT - 2                                                  | InterState                | 22/07/2026   | 05:12        | 22/07/2026 | 15:15      | T           | Distance protection on R phase.                                                                                                                                                                                  |
| TALANDGE - KOLHAPUR (PG) CKT - 1                                       | InterState                | 22/07/2026   | 13:36        | 22/07/2026 | 13:48      | T           | Distance protection.                                                                                                                                                                                             |
| JAIGAD - KARAD CKT - 2                                                 | IntraState                | 29/03/2026   | 10:27        |            |            | T           | Tripped on distance protection.                                                                                                                                                                                  |
| KHADKA-AURANGABAD (WALUJ)                                              | IntraState                | 20/07/2026   | 23:00        |            |            | HT          | H/T due to overvoltage.                                                                                                                                                                                          |
| BABHALESHWAR - PADGHE CKT-1                                            | IntraState                | 21/07/2026   | 22:58        | 22/07/2026 | 08:53      | T           | Decapping at Loc No.116 B ph                                                                                                                                                                                     |
| JAIGAD - KARAD CKT - 1                                                 | IntraState                | 22/07/2026   | 15:41        | 22/07/2026 | 19:33      | EO          | To attend oil seepage of GIS CB drive mechanism                                                                                                                                                                  |
| <b>400 KV ICT Outages/Trippings</b>                                    |                           |              |              |            |            |             |                                                                                                                                                                                                                  |
| STATION TF No 3 @ CHANDRAPUR GCR                                       | IntraState                | 01/03/2023   | 15:07        |            |            | PO          | 1) Oil filtration work<br>2) Testing of Station transformer<br>3) Preventive maintenance work.                                                                                                                   |
| 400/220 KV 3X105 MVA ICT - 1 @ KHARGHAR                                | IntraState                | 21/07/2026   | 11:24        |            |            | EO          | Heavy oil leakage observed from ICT-1, B ph LV Bushing.                                                                                                                                                          |
| 400/220KV 501MVA ICT III@TAPTITANDA                                    | IntraState                | 22/07/2026   | 09:10        | 22/07/2026 | 17:20      | T           | Tripped on NDR.                                                                                                                                                                                                  |
| 400/220/33 KV 500 MVA ICT - 4 @ JEJURI                                 | IntraState                | 23/07/2026   | 09:14        |            |            | PO          | Earth blade gear box fixing work of 29T & 29A isolator of 411 bay & ICT Y Ph neutral patti foundation changing work & Testing work.                                                                              |
| 400/220 KV 105MVA SPARE ICT @ LONIKAND-400 KV                          | IntraState                | 23/07/2026   | 10:41        |            |            | PO          | Pre-commissioning work in view of RRS project                                                                                                                                                                    |
| <b>400 KV BR Outages/Trippings</b>                                     |                           |              |              |            |            |             |                                                                                                                                                                                                                  |
| 80 MVAR BUS REACTOR @ PADGHE                                           | IntraState                | 24/07/2025   | 22:05        |            |            | HT          | Sparking observed                                                                                                                                                                                                |
| <b>220 KV TIEBAY Outages/Trippings</b>                                 |                           |              |              |            |            |             |                                                                                                                                                                                                                  |
| BUS COUPLER @ PHURSUNGI                                                | IntraState                | 27/06/2026   | 06:30        |            |            | HT          | Load management                                                                                                                                                                                                  |
| BUS COUPLER @ KUDUS                                                    | IntraState                | 08/07/2026   | 08:10        |            |            | HT          | Load management.                                                                                                                                                                                                 |
| <b>220 KV MAINBAY Outages/Trippings</b>                                |                           |              |              |            |            |             |                                                                                                                                                                                                                  |
| BUS COUPLER @ BABHALESHWAR                                             | IntraState                | 22/07/2026   | 14:15        | 22/07/2026 | 17:45      | PO          | B/U relay, CB DCRM/Timing, CT tan delta,LBB relay.                                                                                                                                                               |
| MAIN BUS SECTION - 1 @ SHIRSUPHAL                                      | IntraState                | 23/07/2026   | 10:13        |            |            | PO          | 1)To carry out jump replacement work of 220kV Main Bus Section-1 R-Ph Isolator.<br>2)To repair damaged B-Ph Conductor of 220kV Main Bus Section-1.<br>3)To carry out 220kV Kurkumbh Bay diagnostic testing work. |
| <b>220 KV LINE Outages/Trippings</b>                                   |                           |              |              |            |            |             |                                                                                                                                                                                                                  |



**State Load Despatch Center,Airoli (MSETCL)**  
**Details of Line outages/Trippings for 22/Jul/2026**

**Statement-VII**

Position as on 6.30 Hrs of 23/Jul/2026

| Name of Line                                  | Inter State / Intra State | Tripped Date | Tripped Time | Sync. Date | Sync. Time | Outage Type | Reason of Outage                                                                                                                               |
|-----------------------------------------------|---------------------------|--------------|--------------|------------|------------|-------------|------------------------------------------------------------------------------------------------------------------------------------------------|
| 220 KV CHAKAN PHASE II- TALEGAON (PG) CKT-2   | InterState                | 20/07/2026   | 10:31        | 22/07/2026 | 17:48      | PO          | SCADA testing work for 220kV bay no.202(Talegaon PGCIL Ckt-II)                                                                                 |
| 220 KV CHAKAN PHASE II- TALEGAON (PG) CKT-1   | InterState                | 20/07/2026   | 10:31        | 22/07/2026 | 17:47      | PO          | SCADA testing work for 220kV bay no.201(Talegaon PGCIL Ckt-I).                                                                                 |
| 220KV-SHIKARAPUR(PG)-KHEDCITY-1               | InterState                | 22/07/2026   | 15:19        | 23/07/2026 | 05:10      | T           | Tripped on differential protection.                                                                                                            |
| WAGHIVALI (MSETCL) - ULWE GIS CKT - 2         | IntraState                | 25/06/2024   | 08:05        |            |            | T           | Tripped on differential protection                                                                                                             |
| WAGHIVALI (MSETCL) - WAGHIVALI (TATA) CKT - 1 | IntraState                | 30/12/2024   | 10:44        |            |            | HT          | Hand tripped only at Waghivali (TATA ) End only For load management on 220kV Ulwe - Waghivali ckt -1                                           |
| WAGHIVALI (MSETCL) - WAGHIVALI (TATA) CKT - 2 | IntraState                | 30/12/2024   | 10:44        |            |            | HT          | Hand tripped only at Waghivali (TATA ) End only For load management on 220kV Ulwe - Waghivali ckt -1                                           |
| KHANDESHWAR - TIMBER MARKET CKT - 1           | IntraState                | 12/02/2026   | 14:37        |            |            | T           | Tripped on distance protection.                                                                                                                |
| AMRAPUR - TAPTITANDA CKT - 1                  | IntraState                | 22/04/2026   | 15:33        |            |            | T           | AT T E= B PH, IF=3.3KA, D=48.50KM                                                                                                              |
| 220KV GIS DCHI - COLOURCHEM                   | IntraState                | 12/05/2026   | 20:08        |            |            | T           | Tripped on distance protection.                                                                                                                |
| LONIKAND1-LONIKAND2 (INTER CONNECTOR)         | IntraState                | 22/06/2026   | 20:07        |            |            | HT          | H/T for load management.                                                                                                                       |
| BHOSARI-1(GIS)-Microsoft-II GIS (PNQ27 CKT-1) | IntraState                | 25/06/2026   | 07:26        |            |            | T           | Distance Protection.                                                                                                                           |
| 220 KV NTT GLOBAL (Estella)-MANKOLI           | IntraState                | 06/07/2026   | 05:01        |            |            | T           | Diffrential Prot. B-ph fault current 14.57kA dIST 9.5KM FROM NTT Global                                                                        |
| KALMESHWAR-PANDHURNA                          | IntraState                | 11/07/2026   | 08:02        |            |            | HT          | For Controlled loading.                                                                                                                        |
| MAIN BUS SECTION - 1 @ MAHAPE                 | IntraState                | 15/07/2026   | 11:16        |            |            | PO          | for reconfiguring default setting, changing busbar setting and testing work on CTR make numerical bus bar protection system.                   |
| EKLAHARE (OCR) - PADGHE                       | IntraState                | 19/07/2026   | 18:47        |            |            | HT          | Load management                                                                                                                                |
| PANCHANAND-GRAMERCY TECH PARK                 | IntraState                | 20/07/2026   | 13:12        | 22/07/2026 | 19:10      | PO          | For replacement of old conductor with equivalent High Performance conductor from TL NO. 653/1 to TL.No. 652 & TL.No. 652 to Panchanand gantry. |
| 220KV TAPTITANDA- AMRAPUR CKT I               | IntraState                | 21/07/2026   | 19:59        |            |            | T           | Tripped on distance protection.                                                                                                                |
| BOMBAY DYEING - SAHARA                        | IntraState                | 21/07/2026   | 23:46        | 22/07/2026 | 02:35      | T           | Distance protection on R phase.                                                                                                                |
| WASHALA - GHATGHAR                            | IntraState                | 22/07/2026   | 03:01        | 22/07/2026 | 04:07      | T           | Distance protection on R phase.                                                                                                                |
| GIGAPLEX (PDG) - NTT NEON (DC 13) CKT         | IntraState                | 22/07/2026   | 03:38        | 22/07/2026 | 08:54      | T           | Differential protection Y phase fault.                                                                                                         |
| BOMBAY DYEING - SAHARA                        | IntraState                | 22/07/2026   | 04:06        |            |            | T           | Distance protection on R phase.                                                                                                                |
| TALANDGE - SAWANTWADI                         | IntraState                | 22/07/2026   | 06:08        | 22/07/2026 | 11:07      | T           | Distance protection on B phase.                                                                                                                |
| ADLABS - PEDAMBE                              | IntraState                | 22/07/2026   | 08:58        | 22/07/2026 | 12:18      | PO          | 220 KV, Pedambe Adlab line, Circuit breaker to line side Isolator R phase conductor strands broken                                             |
| MUMEWADI -HALKARNI 1 LINE                     | IntraState                | 22/07/2026   | 09:11        | 22/07/2026 | 15:44      | PO          | Polymer insulator replacement                                                                                                                  |
| KARAD -NIGADE                                 | IntraState                | 22/07/2026   | 09:36        | 22/07/2026 | 14:50      | PO          | To attend hot spot at loc No. 9 B ph                                                                                                           |
| THEUR-PHURSUNGI CKT II                        | IntraState                | 22/07/2026   | 09:47        | 22/07/2026 | 16:26      | PO          | Half yearly maintenance and DT work                                                                                                            |
| 220 KV KUDUS-ROMA                             | IntraState                | 22/07/2026   | 23:20        |            |            | T           | Distance Protection                                                                                                                            |
| 220 KV BHAVEGHAR-KUDUS                        | IntraState                | 23/07/2026   | 03:48        | 23/07/2026 | 06:16      | T           | Distance Protection                                                                                                                            |

**State Load Despatch Center,Airoli (MSETCL)**  
**Details of Line outages/Trippings for 22/Jul/2026**

**Statement-VII**

Position as on 6.30 Hrs of 23/Jul/2026

| Name of Line                          | Inter State / Intra State | Tripped Date | Tripped Time | Sync. Date | Sync. Time | Outage Type | Reason of Outage                                                                                       |
|---------------------------------------|---------------------------|--------------|--------------|------------|------------|-------------|--------------------------------------------------------------------------------------------------------|
| 220KV KUDUS-TARAPUR                   | IntraState                | 23/07/2026   | 04:43        | 23/07/2026 | 06:18      | T           | Distance Protection                                                                                    |
| <b>220 KV ICT Outages/Trippings</b>   |                           |              |              |            |            |             |                                                                                                        |
| 220/132 KV 200 MVA ICT - 2 @ ALEPHATA | IntraState                | 06/07/2026   | 18:40        |            |            | T           | Tripped on differential protection.                                                                    |
| 220/100 KV 200 MVA ICT 1 @ KOLSHET    | IntraState                | 22/07/2026   | 10:55        | 22/07/2026 | 13:40      | EO          | To attend DC Leakage from ICT-1 HV CB                                                                  |
| 220/33 KV 50 MVA TF - 2@BELWANDI      | IntraState                | 22/07/2026   | 11:49        | 22/07/2026 | 13:45      | PO          | For Attending oil leakage form top plate.<br>N.A.                                                      |
| <b>110 KV LINE Outages/Trippings</b>  |                           |              |              |            |            |             |                                                                                                        |
| KALWA KALYAN                          | IntraState                | 09/01/2026   | 13:38        |            |            | PO          | For upgradation to 220 kV Kalwa Kalyan line project work                                               |
| SALSETTE SAKI 4                       | IntraState                | 02/03/2026   | 09:06        |            |            | PO          | EHV cable termination to provide LILO arrangements at IIT Mumbai (Power supply to IIT) at Loc. 22-22B. |
| KARANJADE - BHOKARPADA                | IntraState                | 22/07/2026   | 10:15        | 22/07/2026 | 18:01      | T           | Distance Protection.                                                                                   |

HT : Hand Tripping, T : Tripping, PO : Planned Outage, EO : Emergency Outage