

State Load Despatch Center, Airoli (MSETCL) Statement I
Daily system Report for 23/Jul/2026 THURSDAY

I GENERATION (MUs)			II EXCHANGES (MUs)		
A) MSPGCL	Daily	Monthly	E) InterState Exchanges	Daily	Monthly
1) Thermal	138.769	3292.580	1) Gujrat	-4.991	-22.612
2) Hydro	9.159	252.700	2) Madhya Pradesh	0.164	60.304
3) Gas	6.394	148.225	3) Chattisgarh	1.630	11.670
Total MSPGCL	154.322	3693.505	4) Maharashtra	164.465	3854.053
B) 1) APLM	38.934	1192.630	5) Goa (Amona)	-1.973	-27.754
2) JSWEL	17.440	416.844	Total	159.295	3875.661
3) VIPL	11.750	288.447	a) Mumbai Schedule	46.762	1023.864
4) RPL(AMT)	22.471	576.719	b) Mumbai Drawl	49.147	1074.424
5) SWPGPL	8.118	213.979	c) MSEDCL Bilateral *	127.070	2871.937
6) Other IPP	12.733	305.738	Include PX	0.000	0.002
7) PGPL	0.000	0.000	d) Mumbai Bilateral *	46.762	1023.864
C) 1) TPCL Thermal	9.832	249.168	Include PX	0.000	0.000
2) TPCL Hydro	4.099	89.655	Standby	0.000	0.000
3) TPCL Gas	2.909	66.304	H) ENERGY CATERED (MUs)		
4) AEML Thermal	6.598	199.132	1) MSEDCL	455.974	11044.554
D) STATE			2) Mumbai Discoms	72.585	1678.683
1) Thermal	266.645	6735.237	3) Other Discoms	13.214	310.228
(A1+C1+C4+(B1-B6))			TOTAL STATE	541.773	13033.465
2) Hydro	13.258	342.355			
3) Gas	9.303	214.529			
4) Wind	75.822	1340.786			
6) SOLAR	17.450	524.897			
TOTAL STATE	382.478	9157.804			

* Displayed for information, not added in total.

DETAILS OF MAHARASHTRA STATE PEAK DEMAND(MW) Statement II

PARTICULARS	A. Morning Peak at 9 Hrs	B. Day Peak at 18 Hrs	C. Evening Peak at 20 Hrs	D. Night Minimum at 4 Hrs
MSPGCL Thermal	5646	5428	6519	5375
MSPGCL Hydro	479	336	762	264
MSPGCL Gas	266	266	268	268
MSPGCL Total Generation	6391	6030	7549	5907
Central Sector Receipt	8117	8243	7559	5425
WIND	3161	3251	3232	3046
CPP / IPP Thermal	4715	4353	5607	4809
CPP / IPP Gas	0	0	0	0
SOLAR	1240	659	0	0
Exchange with Mumbai	-2250	-2506	-2127	-1362
MSEDCL DEMAND MET	20779	19436	21222	17358
Load Shedding	0	0	0	0
MSEDCL DEMAND	20779	19436	21222	17358
TPCL GENERATION	577	624	937	594
AEML GENERATION	291	272	272	274
MUMBAI DEMAND	3118	3402	3336	2230
OTHER DISCOM DEMAND	595	594	598	467
STATE DEMAND MET	24492	23432	25156	20055
STATE DEMAND	24492	23432	25156	20055
Frequency (Hz)	50.02	50.06	50.05	50.04

FREQUENCY PARTICULARS

MAXIMUM FREQ.	MINIMUM FREQ.	AVERAGE FREQ.	FREQ. BELOW 49.4 Hz
50.32 Hz at 13:00 Hrs	49.64 Hz at 10:23 Hrs	50.01	0 % of Time(min)

Note : The report is based on Operational Data and is for statistical purpose only.

Daily and Progressive Generation,Maximum,Minimum for 23/Jul/2026

Generating unit	Generation			
	Daily (Mus)	Monthly (Mus)	Max (MW)	Min (MW)
Koradi				
Unit 6	2.67	71.44	142	87
Unit 8	11.15	221.58	618	372
Unit 9	10.60	255.88	502	370
Unit 10	10.50	249.96	510	375
Total	34.92	798.87		
Bhusawal				
Unit 3	3.14	64.26	145	120
Unit 4	7.82	195.37	410	290
Unit 5	0.00	33.86	0	0
Unit 6	11.34	233.95	600	381
Total	22.30	527.44		
Parli				
Unit 6	3.76	94.31	190	145
Unit 7	3.54	90.20	194	119
Unit 8	3.73	99.51	208	141
Total	11.02	284.02		
Chandrapur				
Unit 3	0.42	65.69	118	0
Unit 4	2.86	61.81	138	98
Unit 5	6.51	170.30	305	180
Unit 6	6.34	157.62	315	185
Unit 7	0.00	27.69	0	0
Unit 8	8.17	189.27	435	281
Unit 9	8.03	200.73	432	285
Total	32.33	873.11		
Paras				
Unit 3	3.46	83.39	218	0
Unit 4	4.02	95.15	202	148
Total	7.48	178.54		
Khaparkheda				
Unit 1	2.65	73.07	135	95
Unit 2	2.92	70.49	134	101
Unit 3	3.40	77.15	169	130
Unit 4	3.63	15.31	180	132
Unit 5	9.37	225.54	440	305
Total	21.97	461.56		
Nasik				
Unit 3	2.91	45.52	127	105
Unit 4	3.07	56.64	139	117
Unit 5	2.78	66.88	122	110
Total	8.76	169.04		
Uran				
All Units	6.39	148.22	268	261
Total	6.39	148.22		
PGPL				
Unit 1	0.00	0.00	0	0
Unit 2	0.00	0.00	0	0
Total	0.00	0.00		
PENCH (MS)				
Pench (MS)	0.18	2.48	21	0
Total	0.18	2.48		
Koyna				

Generating unit	Generation			
	Daily (Mus)	Monthly (Mus)	Max (MW)	Min (MW)
Stage 1-2	1.04	39.65	50	40
Stage 4	0.00	47.54	0	0
Stage 3	0.87	30.01	160	0
Total	1.91	117.20		
Hydro				
KDPH	0.00	0.00	0	0
VTRNA	0.44	6.19	60	0
TILLARI	0.36	5.89	60	0
BHIRA T.R.	0.34	8.33	80	0
SMLHY_PTN	5.49	101.68	245	216
GHATGHAR	0.61	13.41	125	0
Total	7.25	135.50		
Wind				
Total	75.82	1340.79	0	0
Total	75.82	1340.79		
CPP				
APML(Mus)	38.93	1192.63	0	0
JSWEL(Mus)	17.44	416.84	0	0
VIPL(Mus)	11.75	288.45	0	0
RPLAMT-Mus	22.47	576.72	0	0
SWPGPL-Mus	8.12	213.98	0	0
Dhariwal	0.00	0.00	0	0
IEPL	4.84	121.97	267	151
Other(Mus)	1.59	37.17	0	0
JPL	5.10	122.13	265	144
VMEPL	0.31	6.79	25	6
LMEL	0.89	17.67	47	28
Total	111.45	2994.36		
SOLAR				
Total	17.45	524.90	0	0
Total	17.45	524.90		
Tata				
Trombay 5	6.52	163.91	350	253
Trombay 6	0.00	0.00	0	0
Trombay 7A	1.67	38.60	105	59
Trombay 7B	1.24	27.71	62	48
TATA Hydro	4.10	89.66	354	87
Trombay 8	3.31	85.26	174	126
Total	16.84	405.13		
AEML				
DTPS U-1&2	6.60	199.13	291	271
Total	6.60	199.13		

* Infirm Power			Summary			Summary		
Particulars	Daily (Mus)	Monthly	Particulars	Daily (Mus)	Monthly (Mus)	Particulars	Daily (Mus)	Monthly (Mus)
			MSPGCL Thermal	138.77	3292.58	MSPGCL Total	154.32	3693.50
			MSPGCL Thml+Gas	145.16	3440.80	Koyna 1,2 & 4 Total	1.04	87.20
			MSPGCL Hydro	9.16	252.70	State Total	382.48	9157.80

State Load Despatch Center,Airoli (MSETCL)

Annexure-2

Hourly Load Data As on 23/Jul/2026

TIME SR. NO.	MSPGCL GEN.			TOTAL	WIND	CPP / IPP		SOLAR	CS SHARE	CS RECPT	Mum. NET EXCH.	MSEDC L DEM. MET	Load Shedding		MSEDC L DEM. WITH LS	MUMBAI DEMAND	OTHER DISCOM DEMAND	STATE DEMAND	FREQ. (Hz)
	THM	HY	GAS			THM	GAS						Planned	*Transmission Constraint					
1	5930	274	267	6471	3191	4938	0	0	5673	5253	-1626	17697	0	0	17697	2629	530	20856	49.99
2	5638	275	268	6181	3329	4796	0	0	5392	5149	-1530	17430	0	0	17430	2449	495	20374	49.97
3	5377	262	268	5907	3125	4801	0	0	5425	5358	-1423	17318	0	0	17318	2303	450	20071	49.97
4	5375	264	268	5907	3046	4809	0	0	5402	5425	-1362	17355	0	0	17355	2230	470	20055	50.04
5	5672	266	268	6206	2998	4938	0	0	5359	5593	-1326	17924	0	0	17924	2214	485	20623	49.99
6	6334	291	266	6891	3066	5155	0	0	6120	5945	-1401	19171	0	0	19171	2304	486	21960	50.03
7	6294	421	268	6983	3027	5396	0	172	7341	7014	-1486	20584	0	0	20584	2488	522	23594	50.00
8	6231	364	268	6863	3091	5046	0	647	7889	7287	-1855	20525	0	0	20525	2745	555	23824	50.00
9	5646	479	266	6391	3161	4715	0	1240	8038	8117	-2250	20775	0	0	20775	3118	599	24492	50.02
10	5411	424	266	6101	3280	4319	0	1927	8262	7791	-2522	20292	0	0	20292	3398	604	24294	50.06
11	5324	367	266	5957	3273	3807	0	2229	8222	7616	-2741	19545	0	0	19545	3619	597	23760	49.90
12	5285	280	266	5831	3383	3710	0	2244	7387	7368	-2799	19154	0	0	19154	3661	582	23398	49.94
13	5257	261	266	5784	3117	3647	0	2288	6833	6560	-2733	18082	0	0	18082	3610	580	22273	50.05
14	5276	267	266	5809	2752	3678	0	1782	6472	5784	-2533	16731	0	0	16731	3449	541	20721	50.06
15	5426	272	265	5963	2731	3863	0	1402	6836	6585	-2542	17459	0	0	17459	3432	543	21434	49.93
16	5304	274	261	5839	3081	3748	0	1525	7142	7259	-2509	18386	0	0	18386	3440	556	22383	49.95
17	5271	287	266	5824	3237	3876	0	1254	7265	7323	-2505	18438	0	0	18438	3429	571	22438	50.03
18	5428	336	266	6030	3251	4353	0	659	7772	8243	-2506	19432	0	0	19432	3402	599	23432	50.06
19	6388	486	266	7140	3383	5176	0	81	7416	7585	-2260	20516	0	0	20516	3382	590	24487	50.05
20	6519	762	268	7549	3232	5607	0	0	7556	7559	-2127	21218	0	0	21218	3336	602	25156	50.05
21	6300	735	266	7301	3252	5180	0	0	7544	7602	-2063	20695	0	0	20695	3185	577	24457	50.03
22	6492	612	265	7369	3163	5494	0	0	6461	6182	-1795	19835	0	0	19835	3050	578	23463	50.04
23	6444	479	266	7189	3310	5277	0	0	6109	5480	-1631	19056	0	0	19056	2909	569	22534	50.03
24	6147	421	268	6836	3343	5117	0	0	5816	5217	-1622	18359	0	0	18359	2803	532	21694	50.01
MUs	138.77	9.16	6.39	154.32	75.82	111.45	0.00	17.45	163.73	159.30	-49.15	455.97	0.00	0.00	455.97	72.58	13.21	541.77	50.01

NOTE : ALL VALUES IN MW

Mumbai Net Exch is shown with reference to MSETCL system and (-) sign indicates MSETCL periphery to Mumbai system.

*Load Shedding due to Transmission Constraint :-

Maximum Demand scenario for the date 23/Jul/2026		
State Demand	MSEDC Non-Coincident Peak Demand	Mumbai Non-Coincident Peak Demand
25156 MW	21218 MW	3661 MW
20 Hrs	20 Hrs	12 Hrs
Includes LS - 0 MW	Includes LS - 0 MW	--

State Load Despatch Center,Airoli (MSETCL) Statement-VI
Details of Generating Unit Outages/Trippings for 23/Jul/2026

Position as on 6.30 Hrs of 24/Jul/2026

Generating Company	Name of Generating Unit	Capacity	Tripped Date	Tripped Time	Sync.Date	Sync. Time	Reason of Outage	Expected Date
PLANNED OUTAGE								
MSPGCL								
MSPGCL	Koyna Unit 12	80	15/06/2026	10:00		Continued.	COH	13/08/2026
MSPGCL	Bhusawal Unit 5	500	05/07/2026	01:01		Continued.	Capital Overhaul for 35 days	09/08/2026
MSPGCL	Chandrapur Unit 7	500	06/07/2026	14:13		Continued.	COH	10/08/2026
Total Capacity MSPGCL		1080						
IPP								
IPP	SWPGPL U-2	135	11/07/2026	23:38		Continued.	AOH	30/07/2026
IPP	Adani U-2	660	20/07/2026	01:12		Continued.	Planned COH .	10/08/2026
IPP	RPL(AMT) U-1	270	21/07/2026	00:00		Continued.	withdrawn for Boiler licence renewal & other maintenance work.	01/08/2026
Total Capacity IPP		1065						
Total Capacity PLANNED OUTAGE		2145						
FORCED OUTAGE								
MSPGCL								
MSPGCL	Uran Unit A0	120	21/04/2026	21:37		Continued.	Gas Skid Trip	31/12/2026
MSPGCL	Ghatghar Unit-1	125	17/05/2026	08:52		Continued.	Stator Earth Fault	15/08/2026
MSPGCL	Paras Unit 3	250	20/07/2026	18:45	23/07/2026	03:11	due to both BFP Tripped	23/07/2026
MSPGCL	Koyna Unit 10	80	20/07/2026	20:25		Continued.	B-phase Overcurrent and Overall Differential Relay protection	20/09/2026
MSPGCL	Chandrapur Unit 3	210	23/07/2026	03:24		Continued.	APH-3B both AC and DC motor 2decoupled and flue gas temperature increased	24/07/2026
Total Capacity MSPGCL		535						
IPP								
IPP	LMEL Unit 3	30	01/06/2026	00:04		Continued.	steam unavailability	31/08/2026
IPP	JSW (J) U1	300	06/07/2026	16:43		Continued.	Turbine bearing Vabration high	31/07/2026
IPP	VMEPL Unit 1	60	22/07/2026	12:18		Continued.	Boiler Issue	
Total Capacity IPP		390						
Total Capacity FORCED OUTAGE		925						
UNIT UNDER ZERO SCHEDULE / RSD								
MSPGCL								
MSPGCL	Uran Unit 5	108	17/07/2026	07:56		Continued.	No Schedule by buyer due to open cycle operation High cost.	
MSPGCL	Uran Unit 6	108	19/07/2026	06:50		Continued.	No Schedule by buyer due to open cycle operation High cost.	
Total Capacity MSPGCL		216						
Total Capacity UNIT UNDER ZERO SCHEDULE / RSD		216						

State Load Despatch Center,Airoli (MSETCL) Statement-VI
Details of Generating Unit Outages/Trippings for 23/Jul/2026

Position as on 6.30 Hrs of 24/Jul/2026

Generating Company	Name of Generating Unit	Capacity	Tripped Date	Tripped Time	Sync.Date	Sync. Time	Reason of Outage	Expected Date
FORCED OUTAGE DUE TO NO PPA								
IPP								
IPP	PGPL U1	262	07/02/2017	17.30		Continued.	No Schedule (NO PPA)	
IPP	PGPL U2	126	07/02/2017	17.30		Continued.	No Schedule.(NO PPA)	
Total Capacity IPP		388						
Total Capacity FORCED OUTAGE DUE TO NO PPA		388						
OUTAGE DUE TO FUEL SHORTAGE								
MSPGCL								
MSPGCL	Koyna Unit 5	80	18/07/2026	13:15		Continued.	Vide CE, Koyna email dtd. 18.07.2026, Koyna Units cannot be operated for power generation until further permission from WRD.(5 MW is on bar for spinning)	
MSPGCL	Koyna Unit 4	70	18/07/2026	13:15		Continued.	Vide CE, Koyna email dtd. 18.07.2026, Koyna Units cannot be operated for power generation until further permission from WRD.(5 MW is on bar for spinning)	
MSPGCL	Koyna Unit 3	70	18/07/2026	13:15		Continued.	Vide CE, Koyna email dtd. 18.07.2026, Koyna Units cannot be operated for power generation until further permission from WRD.(5 MW is on bar for spinning)	
MSPGCL	Koyna Unit 2	70	18/07/2026	13:15		Continued.	Vide CE, Koyna email dtd. 18.07.2026, Koyna Units cannot be operated for power generation until further permission from WRD.(5 MW is on bar for spinning)	
MSPGCL	Koyna Unit 8	80	18/07/2026	13:15		Continued.	Vide CE, Koyna email dtd. 18.07.2026, Koyna Units cannot be operated for power generation until further permission from WRD.(5 MW is on bar for spinning)	
MSPGCL	Koyna STG-IV Unit-4	250	18/07/2026	13:15		Continued.	Vide CE, Koyna email dtd. 18.07.2026, Koyna Units cannot be operated for power generation until further permission from WRD.	
MSPGCL	Koyna STG-IV Unit-3	250	18/07/2026	13:15		Continued.	Vide CE, Koyna email dtd. 18.07.2026, Koyna Units cannot be operated for power generation until further permission from WRD.	
MSPGCL	Koyna Unit 6	80	18/07/2026	13:15		Continued.	Vide CE, Koyna email dtd. 18.07.2026, Koyna Units cannot be operated for power generation until further permission from WRD.(5 MW is on bar for	

State Load Despatch Center,Airoli (MSETCL) Statement-VI
Details of Generating Unit Outages/Trippings for 23/Jul/2026

Position as on 6.30 Hrs of 24/Jul/2026

Generating Company	Name of Generating Unit	Capacity	Tripped Date	Tripped Time	Sync.Date	Sync. Time	Reason of Outage	Expected Date
							spinning)	
MSPGCL	Koyna Unit 7	80	18/07/2026	13:15		Continued.	Vide CE, Koyna email dtd. 18.07.2026, Koyna Units cannot be operated for power generation until further permission from WRD.(5 MW is on bar for spinning)	
MSPGCL	Koyna Unit 1	70	18/07/2026	13:15		Continued.	Vide CE, Koyna email dtd. 18.07.2026, Koyna Units cannot be operated for power generation until further permission from WRD.(5 MW is on bar for spinning)	
MSPGCL	Koyna STG-IV Unit-1	250	18/07/2026	13:15		Continued.	Vide CE, Koyna email dtd. 18.07.2026, Koyna Units cannot be operated for power generation until further permission from WRD.	
MSPGCL	Koyna STG-IV Unit-2	250	18/07/2026	13:16		Continued.	Vide CE, Koyna email dtd. 18.07.2026, Koyna Units cannot be operated for power generation until further permission from WRD.	
Total Capacity MSPGCL		1600						
Total Capacity OUTAGE DUE TO FUEL SHORTAGE		1600						

* Other generator generating power instead of contracted genertaor with tri-party agreement in between generatos & discom (Case-IV bidding)

State Load Despatch Center,Airoli (MSETCL)
Details of Line outages/Trippings for 23/Jul/2026

Statement-VII

Position as on 6.30 Hrs of 24/Jul/2026

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
400 KV LR Outages/Trippings							
50 MVAR LINE REACTOR OF 400KV KUMBHARGAON(NANDED) CKT 1 AT 400KV PARLI	IntraState	05/03/2025	20:45			HT	Due to Voltage constraint LR kept out at Parly ss.
400 KV LINE Outages/Trippings							
JAIGAD - KARAD CKT - 2	IntraState	29/03/2026	10:27			T	Tripped on distance protection.
KHADKA-AURANGABAD (WALUJ)	IntraState	20/07/2026	23:00			HT	H/T due to overvoltage.
JEJURI - KARAD	IntraState	23/07/2026	15:37	23/07/2026	20:58	EO	E.O. required due to sparking observed at Yph, 89A isolator of 413 bay
400 KV ICT Outages/Trippings							
STATION TF No 3 @ CHANDRAPUR GCR	IntraState	01/03/2023	15:07			PO	1) Oil filtration work 2) Testing of Station transformer 3) Preventive maintenance work.
400/220 KV 3X105 MVA ICT - 1 @ KHARGHAR	IntraState	21/07/2026	11:24			EO	Heavy oil leakage observed from ICT-1, B ph LV Bushing.
400/220/33 KV 500 MVA ICT - 4 @ JEJURI	IntraState	23/07/2026	09:14	23/07/2026	19:35	PO	Earth blade gear box fixing work of 29T & 29A isolator of 411 bay & ICT Y Ph neutral patti foundation changing work & Testing work.
400/220 KV 105MVA SPARE ICT @ LONIKAND-400 KV	IntraState	23/07/2026	10:41	23/07/2026	15:15	PO	Pre-commissioning work in view of RRS project
400 KV BR Outages/Trippings							
80 MVAR BUS REACTOR @ PADGHE	IntraState	24/07/2025	22:05			HT	Sparking observed
220 KV TIEBAY Outages/Trippings							
BUS COUPLER @ PHURSUNGI	IntraState	27/06/2026	06:30			HT	Load management
BUS COUPLER @ KUDUS	IntraState	08/07/2026	08:10			HT	Load management.
220 KV MAINBAY Outages/Trippings							
MAIN BUS SECTION - 1 @ SHIRSUPHAL	IntraState	23/07/2026	10:13	23/07/2026	17:52	PO	1)To carry out jump replacement work of 220kV Main Bus Section-1 R-Ph Isolator. 2)To repair damaged B-Ph Conductor of 220kV Main Bus Section-1. 3)To carry out 220kV Kurkumbh Bay diagnostic testing work.
220 KV LINE Outages/Trippings							
220KV-SHIKARAPUR(PG)-KHEDCITY-1	InterState	22/07/2026	15:19	23/07/2026	05:10	T	Tripped on differential protection.
WAGHIVALI (MSETCL) - ULWE GIS CKT - 2	IntraState	25/06/2024	08:05			T	Tripped on differential protection
WAGHIVALI (MSETCL) - WAGHIVALI (TATA) CKT - 1	IntraState	30/12/2024	10:44			HT	Hand tripped only at Waghivali (TATA) End only For load management on 220kV Ulwe - Waghivali ckt -1
WAGHIVALI (MSETCL) - WAGHIVALI (TATA) CKT - 2	IntraState	30/12/2024	10:44			HT	Hand tripped only at Waghivali (TATA) End only For load management on 220kV Ulwe - Waghivali ckt -1
KHANDESHWAR - TIMBER MARKET CKT - 1	IntraState	12/02/2026	14:37			T	Tripped on distance protection.
AMRAPUR - TAPTITANDA CKT - 1	IntraState	22/04/2026	15:33			T	AT T E= B PH, IF=3.3KA, D=48.50KM
220KV GIS DCHI - COLOURCHEM	IntraState	12/05/2026	20:08			T	Tripped on distance protection.
LONIKAND1-LONIKAND2 (INTER CONNECTOR)	IntraState	22/06/2026	20:07			HT	H/T for load management.
BHOSARI-1(GIS)-Microsoft-II GIS (PNQ27 CKT-1)	IntraState	25/06/2026	07:26			T	Distance Protection.

State Load Despatch Center, Airoli (MSETCL)
Details of Line outages/Trippings for 23/Jul/2026

Statement-VII

Position as on 6.30 Hrs of 24/Jul/2026

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
220 KV NTT GLOBAL (Estella)-MANKOLI	IntraState	06/07/2026	05:01			T	Differential Prot. B-ph fault current 14.57kA dIST 9.5KM FROM NTT Global
KALMESHVAR-PANDHURNA	IntraState	11/07/2026	08:02			HT	For Controlled loading.
MAIN BUS SECTION - 1 @ MAHAPE	IntraState	15/07/2026	11:16			PO	for reconfiguring default setting, changing busbar setting and testing work on CTR make numerical bus bar protection system.
EKLAHARE (OCR) - PADGHE	IntraState	19/07/2026	18:47			HT	Load management
220KV TAPTITANDA- AMRAPUR CKT I	IntraState	21/07/2026	19:59			T	Tripped on distance protection.
BOMBAY DYEING - SAHARA	IntraState	22/07/2026	04:06			T	Distance protection on R phase.
220 KV KUDUS-ROMA	IntraState	22/07/2026	23:20	23/07/2026	12:20	T	Distance Protection
220 KV BHAVEGHAR-KUDUS	IntraState	23/07/2026	03:48	23/07/2026	06:16	T	Distance Protection
220KV KUDUS-TARAPUR	IntraState	23/07/2026	04:43	23/07/2026	06:18	T	Distance Protection
220KV KUDUS-TARAPUR	IntraState	23/07/2026	07:43	23/07/2026	22:42	T	Distance Protection.
BHOSARI- BHOSARI 2	IntraState	23/07/2026	11:49	23/07/2026	15:23	PO	For emergency tree pruning work between Loc No. 64 - 65
PIRANGUT - HINJAWADI 2	IntraState	23/07/2026	23:18			T	Tripped on distance protection.
WASHALA - GHATGHAR	IntraState	23/07/2026	23:31			T	Tripped on distance protection.
RAYMOND - WASHALA	IntraState	23/07/2026	23:41	24/07/2026	02:00	T	Tripped on Back-up protection.
LONIKAND 2 - VSNL	IntraState	24/07/2026	00:02	24/07/2026	03:44	EO	Y phase CT replacement work due to heavy oil leakage
220 KV ICT Outages/Trippings							
220/132 KV 200 MVA ICT - 2 @ ALEPHATA	IntraState	06/07/2026	18:40			T	Tripped on differential protection.
220 KV BUSBAR Outages/Trippings							
BUS-1@STT GLOBAL GIS	IntraState	23/07/2026	13:00	23/07/2026	17:05	PO	Investigation work of abnormal sound observed from Y phase metering check PT and secondary terminal tightness.
110 KV LINE Outages/Trippings							
KALWA KALYAN	IntraState	09/01/2026	13:38			PO	For upgradation to 220 kV Kalwa Kalyan line project work
SALSETTE SAKI 4	IntraState	02/03/2026	09:06			PO	EHV cable termination to provide LILO arrangements at IIT Mumbai (Power supply to IIT) at Loc. 22-22B.

HT : Hand Tripping, T : Tripping, PO : Planned Outage, EO : Emergency Outage