CC Number -	KDMC /TPD/ BP/ DOM / 2018-19/04/396 Date: 17/12/2021.
Ward -	H Ward
Landowner or Applicant Name –	ONKARESHWAR DEVELOPERS
Licensed Architect or Engineer Name-	Mr. Tibin T. Thomas (M/s De-Con Associates)
Village Name -	Gaondevi Dombivali (West)
Survey No. -	S. No. 131 (Old) 49 (New)
House No. -	H. No. 5/1, 6, 7, 8, 13
Taluka Name. -	Tal - Kalyan

INFORMATION OF BUILDING PROPOSAL AS PER PLANS ATTACHED

Building No.	**Building No 1 - Wing B**
Property Address	Balaji Siddhivinayak
Landmark	Near Gopinath Chowk Jagdamba Mandir
ARE ALL CONNECTIONS ON SITE DISCONNECTED FROM THE MAIN LINE ?	
YES	
IS A SEWAGE TREATMENT PLANT PROPOSED FOR THE PROPOSAL?	
NO	

1	PROPOSED WATER REQUIREMENT FOR RESIDENCES (IN LITRE)
	91,000 LTR
2	PROPOSED WATER REQUIREMENT FOR SHOPS (IN LITRE)
	NA
3	PROPOSED WATER REQUIREMENT FOR OFFICES (IN LITRE)
	NA
4	TOTAL QUANTITY OF WATER REQUIRED (IN LITRE)
	91,000 LTR
3	ARE THE SIZES AND CAPACITIES OF THE OH AND UG TANKS SUFFICIENT?
	Yes
4	LENGTH OF UG TANK PROPOSED
	4.70 Mtr.
5	WIDTH OF UG TANK PROPOSED
	4.30 Mtr.
6	DEPTH OF UG TANK PROPOSED
	3.2 Mtr. (Water Depth)
7	SIZE AND CAPACITY OF UG TANK PROPOSED (IN LITRE)
	UGT 01 – Size - 4.70 x 4.30 x 3.2 Mtr. Capacity – 64,000 Ltr UGT 02 – Size - 4.70 x 4.30 x 3.2 Mtr. Capacity – 64,000 Ltr Total Capacity – 1,28,000 Ltr.
8	LENGTH OF OH TANK PROPOSED
	OHT-01 – 7.15 Mtr. OHT-02 – 7.23 Mtr. Total – 14.38 Mtr.
9	WIDTH OF OH TANK PROPOSED
	OHT-01 – 4.49 Mtr. OHT-02 – 6.32 Mtr. Total – 10.81 Mtr.
10	HEIGHT OF OH TANK PROPOSED
	2.70 Mtr. (Water Depth)
11	SIZE AND CAPACITY OF OH TANK PROPOSED (IN LITRE)
	Size OHT 01– 7.15 x 4.49 x 2.70 Capacity – 86,679 Ltr. Size OHT 02– 7.23 x 6.32 x 2.70 Capacity – 1,23,372 Ltr. Total – 2,10,051 Ltr.

12	DISTANCE OF UG TANK FROM SUPPLY LINE (IN METRE)
	100 Mtr.
13	UPLOAD CC CERTIFICATE
14	UPLOAD MUNICIPAL PLAN
15	UPLOAD OTHER DOCUMENT
16	UPLOAD DECLARATION CERTIFICATE

THOMAS AUGUSTIN
KDMC / WS / PL No./116
Block No.B/202, Yashwant Arcade
Co -op. Hsg. Society, Rethi Bander
Road, Dombivli (West) 421202

SIGNATURE OF LICENCED PLUMBER

Name – Mr. Thomas

Licensed No. - KDMC/WS/PLNO/116

M/S. ONKARESHWAR DEVELOPERS

PARTNER

SIGNATURE OF BUILDER & DEVELOPER