| | |
|---|---|
| **CC Number -** | KDMC /TPD/ BP/ DOM / 2021-22/42/257<br><br>Date: 08/09/2022. |
| **Ward -** | F Ward |
| **Landowner or Applicant Name –** | SAI BALAJI ENTERPRISES |
| **Licensed Architect or Engineer Name-** | Mr. Shirish G. Nachane (M/s Sthapatya Nirmaan) |
| **Village Name -** | Kanchangaon Dombivali |
| **Survey No. -** | S. No. 30 |
| **House No. -** | H. No. 2(Pt), 3/A, 3/B, 4, 5, 6 |
| **Taluka Name. -** | Tal - Kalyan |

**INFORMATION OF BUILDING PROPOSAL AS PER PLANS ATTACHED**

| | |
|---|---|
| **Building No.** | **Wing B** |
| **Property Address** | Balaji Govind B Wing |
| **Landmark** | Near Rubina Bakery |
| **ARE ALL CONNECTIONS ON SITE DISCONNECTED FROM THE MAIN LINE ?** | |
| YES | |
| **IS A SEWAGE TREATMENT PLANT PROPOSED FOR THE PROPOSAL?** | |
| NO | |

| | |
|---|---|
| 1 | PROPOSED WATER REQUIREMENT FOR RESIDENCES (IN LITRE) |
| | 75,000 LTR |
| 2 | PROPOSED WATER REQUIREMENT FOR SHOPS (IN LITRE) |
| | NA |
| 3 | PROPOSED WATER REQUIREMENT FOR OFFICES (IN LITRE) |
| | NA |
| 4 | TOTAL QUANTITY OF WATER REQUIRED (IN LITRE) |
| | 75,000 LTR |
| 3 | ARE THE SIZES AND CAPACITIES OF THE OH AND UG TANKS SUFFICIENT? |
| | Yes |
| 4 | LENGTH OF UG TANK PROPOSED |
| | 11.8 Mtr. |
| 5 | WIDTH OF UG TANK PROPOSED |
| | 10.6 Mtr. |
| 6 | DEPTH OF UG TANK PROPOSED |
| | 3.0 Mtr. (Water Depth) |
| 7 | SIZE AND CAPACITY OF UG TANK PROPOSED (IN LITRE) |
| | Size -8.05 x 5.05 x 3.0 Mtr.<br>Capacity – 1,22,000 Ltr. |
| 8 | LENGTH OF OH TANK PROPOSED |
| | OHT-01 – 6.73 Mtr.<br>OHT-02 – 6.73 Mtr.<br>Total – 13.46 Mtr. |
| 9 | WIDTH OF OH TANK PROPOSED |
| | OHT-01 – 2.55 Mtr.<br>OHT-02 – 2.55 Mtr.<br>Total – 5.1 Mtr. |
| 10 | HEIGHT OF OH TANK PROPOSED |
| | 2.26 Mtr. (Water Depth) |
| 11 | SIZE AND CAPACITY OF OH TANK PROPOSED (IN LITRE) |
| | Size OHT 01– 6.73 x 2.55 x 2.26 Capacity – 38,780 Ltr.<br>Size OHT 02– 6.73 x 2.55 x 2.26 Capacity – 38,780 Ltr.<br>Total – 77,560 Ltr. |

| | |
|---|---|
| 12 | DISTANCE OF UG TANK FROM SUPPLY LINE (IN METRE) |
| | 95 Mtr. |
| 13 | UPLOAD CC CERTIFICATE |
| 14 | UPLOAD MUNICIPAL PLAN |
| 15 | UPLOAD OTHER DOCUMENT |
| 16 | UPLOAD DECLARATION CERTIFICATE |

THOMAS AUGUSTIN
KDMC / WS / PL No./116
Block No.B/202, Yashwant Arcade
Co -op. Hsg. Society, Rethi Bander
Road, Dombivli (West) 421202.

SIGNATURE OF LICENCED PLUMBER

**Name** – Mr. Thomas

**Licensed No.** - KDMC/WS/PLNO/116

For SAI BALAJI ENTERPRISES

Partner

SIGNATURE OF BUILDER & DEVELOPER