NIRMAL ARTS

Architects, Interior Designers & Project Consultants.

Off. : L-002, Sanghavi Estate, New RTO Road, Khadakpada, Near Cinemax, Kalyan (W) 421301
Office Contact: 0251-2232510, 7900093679, **Mob.** : 9820565376, **Email :-** nirmalarts2016@gmai.com
Resi. Add : "Sitaram Niwas" Near Datta Mandir, Golavali Village, Kalyan-Shil Road, MIDC, Dombivli (E.) - 421 203

Ref.:- NA/KD/22/26 **Date**: - 17/02/2026

Report

To,

The Executive Engineer,
Water Supply Department.
Kalyan Dombivali Municipal Corporation
Shankarrao Chowk, Kalyan (W).

Sub:- Building proposal in Gaothan, on land bearing C.T.S. No.989, at.Village- Kalyan, Tal. Kalyan. Dist. Thane, admeasuring area 406.40 sq.mt.

Ref:- BPMS Project Code : KDMCC-25-138686_535305.

Respected Sir,

I undersigned, Ar. Sandeep P. Patil, as an Architect for the building proposal in Gaothan, on land bearing C.T.S. No.989, at. Village-Kalyan, Tal. Kalyan. Dist. Thane, admeasuring area 406.40 sq.mt. has applied for Water Technical NOC.

Since the proposed plot area is very small, i.e., 406.40 sq.mt, a detailed MEP (Mechanical, Electrical, and Plumbing) design is not required for this plot. The building has been designed as a stilt (pt), ground (pt) + 1st to 5th floor structure comprising 10 flats. Therefore, quantity of water required is as follows :

As per the designed plan there are 10 flats, thus we assume 5 persons in each flat that is 10 × 5 = 50 persons. The amount of water required per person is 135 liters, therefore 135 × 50 = 6,750 liters. For one shop we need 500 liters. The total amount of water required for the proposed building is 7,250 liters.

Hence, I request you to issue the Water Technical NOC at the earliest, considering this report.

Yours Faithfully,

Ar. Sandeep Patil
Reg. No. CA/2008/42512