VITAN CONSULTANTS

ARCHITECTS & INTERIOR DESIGNERS

5TH FLOOR, MIDTOWN EMBASSY, BEHIND VASANT VALLEY BUS DEPOT,
OPP. NARAYANA SCHOOL, VASANT VALLEY, GANDHARE KALYAN (W).

TEJAS ANIL NIRGUDE
B. ARCH & INTERIOR DESIGNER

E-mail : vitanconsultants@yahoo.com
M.:8451985999

संदर्भ क्र.८७२
दि.१६/०३/२०२६

प्रति,
मा.कार्यकारी अभियंता
पाणी पुरवठा विभाग
क.डो.म.पा
कल्याण.

विषय :- स.नं.२६/२/१ मौजे: भाल,ता.कल्याण,मे.पी.व्ही व्हेंचर तर्फे भागिदार साहिल अनिल बठीजा यांच्या भुखंडावर बांधण्यात येणाऱ्या इमारतीच्या बांधकाम परवानगीच्या दाखल्यासाठी जलनि:सारण विभागचा नाहरकत दाखला मिळणे बाबत.

१) भूखंडाचे विवरण- स.नं.२६/२/१ मौजे: भाल,
२) विकसीत करावयाचे क्षेत्र ५०९१५.४३४ चौ.मी. भूखंडाचे क्षेत्र १७,९००.०० चौ.मी. प्रस्तावित सदनिका ७३० व्यावसायिक गाळे १७ व ऑफीस १७ आहेत.
३) आवश्यक पाणी पुरवठा २,९७,१८०.०० लिटर
४) STP मधुन Recycle द्वारे वापरात येणारे पाणी १५१७९.००लिटर
५) महापालिकेकडून आवश्यक पाणी पुरवठा २८२००१.०० लिटर
६) पाण्याच्या टाकीची लांबी १६.० मी.
७) पाण्याच्या टाकीची रुंदी ५.० मि.
८) पाण्याच्या टाकीची उंची ३.० मि.
९) इमारती वरील पाण्याच्या टाकीची लांबी - ८.० मी.
१०) इमारती वरील पाण्याच्या टाकीची रुंदी ४.०.मी.
११) इमारती वरील पाण्याच्या टाकीची उंची- ३. मी.
१२) पाणी पुरवठा लाईन पासुन U.G Tnak चे अंतर २४.मी.

वितान कन्सल्टंट करिता

वास्तुशिल्पकार.

Registered Office Addre
2803 & 2804, Plan-S Business Park,
Plot No.D-108/1,MIDC Industrial Area,
Opposite D.Y. Patil Stadium , Nerul, Navi Mumbai
Direct Line: (+91) 022-20871359 Hand Held (+91)-9833.00.6842
Email Id- Aquacorp20@gmail.com

Aqua Corp

Name of Client : PV VENTURES
Name of Project : PROPOSED RESIDENTIAL CUM COMMERCIAL DEVELOPMENT AT VILLAGE BHAL, DOMBIVILI (EAST).

WATER CONSUMPTION DATA

SR. NO.	TYPE OF PREMISES	TOTAL UNITS (NOS.)	TOTAL AREA (Sqm)	OCCUPANCY / UNIT OR AREA (Sqm)	TOTAL OCCUPANCY	WATER REQUIREMENT (LPCD) DOM.	(LPCD) FLUSH.	(m3/day) DOM.	(m3/day) FLUSH.	(m3/day) TOTAL
A	**TOWER-A**									
1	1 BHK Flats	111	-	4	444	90	45	39.96	19.98	59.94
2	2 BHK Flats	114		5	570	90	45	51.3	25.65	76.95
	Total of Tower-A	**225**			**1014**			**91.26**	**45.63**	**136.89**
B	**TOWER-B**									
1	1 BHK Flats	136	-	4	544	90	45	48.96	24.48	73.44
2	2 BHK Flats	144		5	720	90	45	64.8	32.40	97.20
	Total of Tower-B	**280**			**1264**			**113.76**	**56.88**	**170.64**
C	**TOWER-C**									
1	1 BHK Flats	111	-	4	444	90	45	39.96	19.98	59.94
2	2 BHK Flats	116		5	580	90	45	52.2	26.10	78.30
	Total of Tower-C	**227**			**1024**			**92.16**	**46.08**	**138.24**
D	**COMMERCIAL**									
1	Shops (G+1st Floor)		1600	0.1	160	25	20	4	3.20	7.20
	Total of Commercial				**160**			**4.00**	**3.20**	**7.20**
		TOTAL WATER REQUIREMENT IN KLD						**301.18**	**151.79**	**452.97**

WATER STORAGE CAPACITY

SR. NO.	Water Tank	Daily Water Req. (m3/day)	UG TANKS @ 1.5day Capacity (m3)	UG TANKS Storage Given (m3)	OH TANKS @ .5day Capacity (m3)	OH TANKS Storage Given (m3)
1	Tower-A Domestic Tank	91.26	136.89	150	45.63	60
2	Tower-B Domestic Tank	113.76	170.64	170	56.88	65
3	Tower-C Domestic Tank	92.16	138.24	150	46.08	60
4	Commercial Domestic Tank	4.00	6	17.5	2	5
5	Tower-A Flushing Tank	45.63	68.445	85	22.815	30
6	Tower-B Flushing Tank	56.88	85.32	90	28.44	35
7	Tower-C Flushing Tank	46.08	69.12	81	23.04	30
8	Commercial Domestic Tank	3.20	4.8	11.5	1.6	5
9	Rain Water Harvesting Tank			110		
10	Fire Tank			560		150
11	Fire Break Tank			100		

Assumptions &

A. Water demand for Residential Population=
Domestic Use = 90 LPCD, Flushing Use = 45 LPCD
LPCD : Litters Per Capita Per Day

B. Water demand for Shops /Retail (Mall)
Domestic Use = 25 LPCD, Flushing Use = 20 LPCD
KLD : Kilo Litters Per Day

Thanking You,
Yours faithfully,

AQUA CORP NAVI MUMBAI

Shri. Sourabh Ashok Sheth.