

DWG	SHEET TITLE	SPECIAL REQUIREMENTS AND NOTES
300.01	METHOD OF PIPE INSTALLATION – METHOD A	
310.02	PARALLEL PIPE END SECTION–PRECAST CONCRETE FOR 15" TO 24" PIPE	REQUIRED IN RIGHT OF WAY WITHIN THE ETJ
310.03	CROSS PIPE END SECTION–PRECAST CONCRETE FOR 18" TO 30" PIPE	REQUIRED IN RIGHT OF WAY WITHIN THE ETJ
310.10	DRIVEWAY PIPE CONSTRUCTION USING NO SPECIAL END SECTIONS	ONLY AT LOCATIONS APPROVED BY THE COUNTY ENGINEER
815.03	PIPE UNDERDRAIN AND BLIND DRAIN	
816.03	GEOCOMPOSITE SHOULDER DRAIN	
838.01	CONCRETE ENDWALL FOR SINGLE AND DOUBLE PIPE CULVERTS	NOTE 1
	15" THRU 48" PIPE 90° SKEW	
838.02	CONCRETE ENDWALL AND SLUICE GATE 15" THRU 36" PIPE–90° SKEW	NOTE 1
838.04	CONCRETE ENDWALL FOR SINGLE AND DOUBLE PIPE CULVERTS	NOTE 1
	17"X13" THRU 71"X47" PIPE ARCH 90° SKEW	
838.05	CONCRETE "L" ENDWALL FOR SINGLE PIPE CULVERTS 15" THRU 48" PIPE	NOTE 1
838.06	CONCRETE "L" ENDWALL FOR SINGLE PIPE CULVERTS 17"X13" THRU 71"X47"	NOTE 1
	PIPE ARCH	
838.07	CONCRETE ENDWALL FOR SINGLE AND DOUBLE PIPE CULVERTS	NOTE 1
	40"X31" THRU 66"X51" PIPE ARCH 90° SKEW	
838.08	CONCRETE "L" ENDWALL FOR SINGLE PIPE CULVERTS 40"X31"	NOTE 1
	THRU 66"X51" PIPE ARCH	
838.10	CONCRETE ENDWALL FOR OUTFALL 4", 6" OR 8" PIPE	NOTE 1
838.11	BRICK ENDWALL FOR SINGLE AND DOUBLE PIPE CULVERTS	
	15" THRU 48" 90° SKEW	
838.14	BRICK ENDWALL FOR SINGLE AND DOUBLE PIPE CULVERTS 17"X13"	
	THRU 71"X47" PIPE ARCH 90° SKEW	
838.15	BRICK "L" ENDWALL FOR SINGLE PIPE CULVERTS 15" THRU 48" PIPE	
838.16	BRICK "L" ENDWALL FOR SINGLE PIPE CULVERTS 17"X13" THRU	
	71"X47" PIPE ARCH	
838.17	BRICK ENDWALL FOR SINGLE AND DOUBLE PIPE CULVERTS 40"X31"	
	THRU 66"X51" PIPE ARCH 90° SKEW	
838.18	BRICK ENDWALL FOR SINGLE PIPE CULVERTS 40"X31" THRU	
	66"X51" PIPE ARCH	
838.20	BRICK ENDWALL FOR OUTFALL 4", 6" OR 8" PIPE	
838.21	REINFORCED CONCRETE ENDWALL FOR SINGLE 54" PIPE 90° SKEW	NOTE 1 SEE MCIDS 20.17 FOR SPLASH PAD
838.22	REINFORCED CONCRETE ENDWALL FOR DOUBLE & TRIPLE 54" PIPES 90° SKEW	NOTE 1 SEE MCIDS 20.17 FOR SPLASH PAD
838.27	REINFORCED CONCRETE ENDWALL FOR SINGLE 60" PIPE 90° SKEW	NOTE 1 SEE MCIDS 20.17 FOR SPLASH PAD
838.28	REINFORCED CONCRETE ENDWALL FOR DOUBLE & TRIPLE 60" PIPES 90° SKEW	NOTE 1 SEE MCIDS 20.17 FOR SPLASH PAD
838.33	REINFORCED CONCRETE ENDWALL FOR SINGLE 66" PIPE 90° SKEW	NOTE 1 SEE MCIDS 20.17 FOR SPLASH PAD
838.34	REINFORCED CONCRETE ENDWALL FOR DOUBLE & TRIPLE 66" PIPES 90° SKEW	NOTE 1 SEE MCIDS 20.17 FOR SPLASH PAD
838.39	REINFORCED CONCRETE ENDWALL FOR SINGLE 72" PIPE 90° SKEW	NOTE 1 SEE MCIDS 20.17 FOR SPLASH PAD
838.40	REINFORCED CONCRETE ENDWALL FOR DOUBLE & TRIPLE 72" PIPES 90° SKEW	NOTE 1 SEE MCIDS 20.17 FOR SPLASH PAD

NOTE 1: FOR ALL STRUCTURES – NCDOT REQUIRES CLASS B CONCRETE (2500PSI). THE COUNTY REQUIRES 3600 PSI CONCRETE STRENGTH @ 28 DAYS. 3600 PSI CONCRETE SHALL BE USED IN ALL PROJECTS.

APPROVED DATE: 02/2007

MECKLENBURG COUNTY
LAND DEVELOPMENT
STANDARDS



NCDOT STANDARDS
APPROVED FOR USE IN MECKLENBURG COUNTY
AND TOWNS, INCLUDING ETJ

STD. NO.	REV.
20.00A	