



SOMERSET THERAPEUTICS LIMITED

DATA REPORT - SVP1 AND AMPOULE LINE EMS

AMPOULE WASHING AREA

Date Time	RH	Temperature	Differential Pressure
DD-MM-YYYY HH:MM:SS	Ampoule Washing Area (NMT 80%)	Ampoule Washing Area (NMT 30°C)	Ampoule Washing Area w.r.t Ampoule Decartoning Room (NLT 12 Pa)
10-06-2022 18:42:00	67.5	19	79
10-06-2022 18:57:00	67.6	18.8	80
10-06-2022 19:12:00	68.2	18.7	80
10-06-2022 19:27:00	67.6	18.7	80
10-06-2022 19:42:00	67.6	18.7	81
10-06-2022 19:57:00	67.8	18.6	81
10-06-2022 20:12:00	67.8	18.6	81
10-06-2022 20:27:00	67.9	18.6	82
10-06-2022 20:42:00	68.1	18.6	81
10-06-2022 20:57:00	68.2	18.6	80
10-06-2022 21:12:00	68	18.6	80
10-06-2022 21:27:00	69.5	18.7	78
10-06-2022 21:42:00	68.8	18.7	82
10-06-2022 21:57:00	68.2	18.6	81
10-06-2022 22:12:00	68.5	18.6	80
10-06-2022 22:27:00	68.3	18.6	80
10-06-2022 22:42:00	72.2	18.8	80
10-06-2022 22:57:00	74.6	19.2	79
10-06-2022 23:12:00	71.9	19.3	81
10-06-2022 23:27:00	70.2	19.2	77
10-06-2022 23:42:00	72.4	19.2	82
10-06-2022 23:57:00	74.6	19.4	81
11-06-2022 00:12:00	73	19.4	81
11-06-2022 00:27:00	69.8	19.4	81

ACTIVITY	NAME	SIGNATURE AND DATE
REVIEWED BY USER		
REVIEWED BY QA		



SOMERSET THERAPEUTICS LIMITED

DATA REPORT - SVP1 AND AMPOULE LINE EMS

AMPOULE WASHING AREA

Date Time	RH	Temperature	Differential Pressure
DD-MM-YYYY HH:MM:SS	Ampoule Washing Area (NMT 80%)	Ampoule Washing Area (NMT 30°C)	Ampoule Washing Area w.r.t Ampoule Decartoning Room (NLT 12 Pa)
11-06-2022 00:42:00	70.1	19.2	81
11-06-2022 00:57:00	69.6	19.1	80
11-06-2022 01:12:00	70	19	82
11-06-2022 01:27:00	69.4	19	80
11-06-2022 01:42:00	69.3	19	81
11-06-2022 01:57:00	69.4	19	82
11-06-2022 02:12:00	69.3	18.9	78
11-06-2022 02:27:00	69.4	19	80
11-06-2022 02:42:00	69.1	19	80
11-06-2022 02:57:00	69.7	19	82
11-06-2022 03:12:00	69.6	19	82
11-06-2022 03:27:00	68.7	18.9	81
11-06-2022 03:42:00	68.3	18.8	78
11-06-2022 03:57:00	69.3	18.8	82
11-06-2022 04:12:00	69	18.8	84
11-06-2022 04:27:00	69.4	18.8	82
11-06-2022 04:42:00	68.8	18.8	81
11-06-2022 04:57:00	69.8	18.8	82
11-06-2022 05:12:00	69.3	18.8	82
11-06-2022 05:27:00	69.4	18.8	83
11-06-2022 05:42:00	69.4	18.8	82
11-06-2022 05:57:00	69.2	18.7	82
11-06-2022 06:12:00	68.7	18.7	81
11-06-2022 06:27:00	70	18.8	79

ACTIVITY	NAME	SIGNATURE AND DATE
REVIEWED BY USER		
REVIEWED BY QA		



SOMERSET THERAPEUTICS LIMITED

DATA REPORT - SVP1 AND AMPOULE LINE EMS

AMPOULE WASHING AREA

Date Time	RH	Temperature	Differential Pressure
DD-MM-YYYY HH:MM:SS	Ampoule Washing Area (NMT 80%)	Ampoule Washing Area (NMT 30°C)	Ampoule Washing Area w.r.t Ampoule Decartoning Room (NLT 12 Pa)
11-06-2022 06:42:00	70.6	18.8	78
11-06-2022 06:57:00	70.8	19	79
11-06-2022 07:12:00	72.4	19	80
11-06-2022 07:27:00	72.4	19.2	81
11-06-2022 07:42:00	72.3	19.3	81
11-06-2022 07:57:00	72.8	19.3	81
11-06-2022 08:12:00	72.7	19.3	81
11-06-2022 08:27:00	70.7	19.3	81
11-06-2022 08:42:00	69.6	19.1	81
11-06-2022 08:57:00	69.8	19	72
11-06-2022 09:12:00	69.8	18.9	82
11-06-2022 09:27:00	69.6	18.9	81
11-06-2022 09:42:00	70.2	18.9	81
11-06-2022 09:57:00	70.1	18.9	82
11-06-2022 10:12:00	70	18.9	81
11-06-2022 10:27:00	69.8	18.9	79
11-06-2022 10:42:00	69.8	18.9	79
11-06-2022 10:57:00	71.4	19	79
11-06-2022 11:12:00	72.7	19.1	79
11-06-2022 11:27:00	72.4	19.2	78
11-06-2022 11:42:00	72.3	19.1	80
11-06-2022 11:57:00	72.2	19.1	78
11-06-2022 12:12:00	72.4	19.2	82
11-06-2022 12:27:00	72.5	19.2	83

ACTIVITY	NAME	SIGNATURE AND DATE
REVIEWED BY USER		
REVIEWED BY QA		



SOMERSET THERAPEUTICS LIMITED

DATA REPORT - SVP1 AND AMPOULE LINE EMS

AMPOULE WASHING AREA

Date Time	RH	Temperature	Differential Pressure
DD-MM-YYYY HH:MM:SS	Ampoule Washing Area (NMT 80%)	Ampoule Washing Area (NMT 30°C)	Ampoule Washing Area w.r.t Ampoule Decartoning Room (NLT 12 Pa)
11-06-2022 12:42:00	71.2	19.2	79
11-06-2022 12:57:00	70.7	19.2	82
11-06-2022 13:12:00	70.5	19	81
11-06-2022 13:27:00	69.6	18.9	82
11-06-2022 13:42:00	70.1	18.8	82
11-06-2022 13:57:00	70.5	18.8	81
11-06-2022 14:12:00	70.4	18.8	80
11-06-2022 14:27:00	71.4	18.8	82
11-06-2022 14:42:00	70.1	18.8	79
11-06-2022 14:57:00	72	18.9	81
11-06-2022 15:12:00	71.9	19	78
11-06-2022 15:27:00	76.2	19.2	80
11-06-2022 15:42:00	72.4	19.3	82
11-06-2022 15:57:00	73.6	19.3	81
11-06-2022 16:12:00	71.5	19.3	82
11-06-2022 16:27:00	71.5	19.2	82
11-06-2022 16:42:00	72.8	19.2	82
11-06-2022 16:57:00	70.8	19.2	83
11-06-2022 17:12:00	70.7	19.1	82
11-06-2022 17:27:00	70.1	19	84
11-06-2022 17:42:00	70.2	18.9	83
11-06-2022 17:57:00	70.8	19	83
11-06-2022 18:12:00	71	19	82
11-06-2022 18:27:00	70.8	19	82

ACTIVITY	NAME	SIGNATURE AND DATE
REVIEWED BY USER		
REVIEWED BY QA		



SOMERSET THERAPEUTICS LIMITED

DATA REPORT - SVP1 AND AMPOULE LINE EMS

AMPOULE WASHING AREA

Date Time	RH	Temperature	Differential Pressure
DD-MM-YYYY HH:MM:SS	Ampoule Washing Area (NMT 80%)	Ampoule Washing Area (NMT 30°C)	Ampoule Washing Area w.r.t Ampoule Decartoning Room (NLT 12 Pa)
11-06-2022 18:42:00	70.3	19	82

End Of Report : From 10-06-2022 18:42:27 To 11-06-2022 18:42:27

ACTIVITY	NAME	SIGNATURE AND DATE
REVIEWED BY USER		
REVIEWED BY QA		