



# SOMERSET THERAPEUTICS LIMITED

## DATA REPORT - SVP1 AND AMPOULE LINE EMS

### WASHING AND STERILIZATION AREA

Date Time	Temperature	RH	Diffrential Pressure	Diffrential Pressure	Diffrential Pressure
DD-MM-YYYY HH:MM:SS	Washing and Sterilization Area (NMT 30°C)	Washing and Sterilization Area (NMT 80%)	Washing and Sterilization Area w.r.t Unit Preparation Room (NLT 6 Pa)	Washing and Sterilization Area w.r.t Ampoule Decartoning Room (NLT 12 Pa)	Washing and Sterilization Area w.r.t Injectable main corridor (NLT 12 Pa)
06-05-2022 09:32:00	19.3	81.6	0	4	17
06-05-2022 10:02:00	19	77.9	0	14	40
06-05-2022 10:32:00	18.9	78.6	13	15	41
06-05-2022 11:02:00	18.9	78.2	0	5	18
06-05-2022 11:32:00	19.5	78.1	19	17	47
06-05-2022 12:02:00	19.7	80.7	5	14	35
06-05-2022 12:32:00	19.3	79	0	13	39
06-05-2022 13:02:00	19.2	78.6	0	15	42
06-05-2022 13:32:00	19.3	79.5	0	18	48
06-05-2022 14:02:00	19.2	79	0	15	44
06-05-2022 14:32:00	19.4	78.1	0	14	40
06-05-2022 15:02:00	19.4	79.3	0	15	43
06-05-2022 15:32:00	19.4	79.2	0	15	44
06-05-2022 16:02:00	20.1	77.5	0	15	42
06-05-2022 16:32:00	19.5	78.5	0	15	44
06-05-2022 17:02:00	19.6	79	0	13	44
06-05-2022 17:32:00	19.8	79	0	14	42
06-05-2022 18:02:00	19.4	77.5	0	9	29
06-05-2022 18:32:00	19.1	76.8	0	10	30
06-05-2022 19:02:00	18.9	77	0	16	44
06-05-2022 19:32:00	18.9	76.2	22	18	46
06-05-2022 20:02:00	18.8	77	0	16	44
06-05-2022 20:32:00	19	76.8	0	15	43
06-05-2022 21:02:00	18.8	75.3	0	15	44

ACTIVITY	NAME	SIGNATURE AND DATE
REVIEWED BY USER		
REVIEWED BY QA		



# SOMERSET THERAPEUTICS LIMITED

## DATA REPORT - SVP1 AND AMPOULE LINE EMS

### WASHING AND STERILIZATION AREA

Date Time	Temperature	RH	Diffrential Pressure	Diffrential Pressure	Diffrential Pressure
DD-MM-YYYY HH:MM:SS	Washing and Sterilization Area (NMT 30°C)	Washing and Sterilization Area (NMT 80%)	Washing and Sterilization Area w.r.t Unit Preparation Room (NLT 6 Pa)	Washing and Sterilization Area w.r.t Ampoule Decartoning Room (NLT 12 Pa)	Washing and Sterilization Area w.r.t Injectable main corridor (NLT 12 Pa)
06-05-2022 21:32:00	18.4	75.4	0	15	44
06-05-2022 22:02:00	18.4	75.9	0	16	44
06-05-2022 22:32:00	18.4	77.6	0	15	43
06-05-2022 23:02:00	19	77.6	0	15	43
06-05-2022 23:32:00	19.3	79.1	24	-1	46
07-05-2022 00:02:00	18.9	76.9	21	19	46
07-05-2022 00:32:00	18.6	76.5	21	13	44
07-05-2022 01:02:00	18.6	76	22	18	46
07-05-2022 01:32:00	18.6	75.7	22	18	45
07-05-2022 02:02:00	18.4	75.9	23	17	45
07-05-2022 02:32:00	18.2	75.5	22	17	45
07-05-2022 03:02:00	18.1	77.4	0	14	39
07-05-2022 03:32:00	18.2	75.8	19	14	37
07-05-2022 04:02:00	17.7	75.9	20	16	42
07-05-2022 04:32:00	17.6	75.6	19	16	40
07-05-2022 05:02:00	17.5	75.7	20	16	42
07-05-2022 05:32:00	17.6	76.4	17	15	40
07-05-2022 06:02:00	17.5	76.5	22	17	42
07-05-2022 06:32:00	17.3	76.8	21	16	43
07-05-2022 07:02:00	17.4	78.3	0	13	41
07-05-2022 07:32:00	17.7	80.5	0	13	40
07-05-2022 08:02:00	22.7	91	0	14	40
07-05-2022 08:32:00	24.7	83.2	0	14	40
07-05-2022 09:02:00	25.9	78.4	0	14	41

ACTIVITY	NAME	SIGNATURE AND DATE
REVIEWED BY USER		
REVIEWED BY QA		



## SOMERSET THERAPEUTICS LIMITED

### DATA REPORT - SVP1 AND AMPOULE LINE EMS

#### WASHING AND STERILIZATION AREA

Date Time	Temperature	RH	Diffrential Pressure	Diffrential Pressure	Diffrential Pressure
DD-MM-YYYY HH:MM:SS	Washing and Sterilization Area (NMT 30°C)	Washing and Sterilization Area (NMT 80%)	Washing and Sterilization Area w.r.t Unit Preparation Room (NLT 6 Pa)	Washing and Sterilization Area w.r.t Ampoule Decartoning Room (NLT 12 Pa)	Washing and Sterilization Area w.r.t Injectable main corridor (NLT 12 Pa)
07-05-2022 09:32:00	****	****	****	****	****

End Of Report : From 06-05-2022 15:02:29 To 07-05-2022 15:02:29

ACTIVITY	NAME	SIGNATURE AND DATE
REVIEWED BY USER		
REVIEWED BY QA		