



## SOMERSET THERAPEUTICS LIMITED

### DATA REPORT - SVP1 AND AMPOULE LINE EMS

#### AMPOULE WASHING AREA

| Date Time           | RH                             | Temperature                     | Differential Pressure   |
|---------------------|--------------------------------|---------------------------------|---|
| DD-MM-YYYY HH:MM:SS | Ampoule Washing Area (NMT 80%) | Ampoule Washing Area (NMT 30°C) | Ampoule Washing Area w.r.t Ampoule Decartoning Room (NLT 12 Pa) |
| 10-06-2022 17:43:00 | 69                             | 19.4                            | 81  |
| 10-06-2022 18:13:00 | 69.9                           | 19.3                            | 79  |
| 10-06-2022 18:43:00 | 67.5                           | 18.9                            | 81  |
| 10-06-2022 19:13:00 | 68.2                           | 18.7                            | 80  |
| 10-06-2022 19:43:00 | 67.6                           | 18.7                            | 80  |
| 10-06-2022 20:13:00 | 67.8                           | 18.6                            | 77  |
| 10-06-2022 20:43:00 | 68                             | 18.6                            | 81  |
| 10-06-2022 21:13:00 | 67.9                           | 18.6                            | 79  |
| 10-06-2022 21:43:00 | 68.8                           | 18.7                            | 81  |
| 10-06-2022 22:13:00 | 68.6                           | 18.6                            | 79  |
| 10-06-2022 22:43:00 | 72.5                           | 18.8                            | 80  |
| 10-06-2022 23:13:00 | 71.9                           | 19.3                            | 80  |
| 10-06-2022 23:43:00 | 72.5                           | 19.2                            | 81  |
| 11-06-2022 00:13:00 | 73.1                           | 19.4                            | 80  |
| 11-06-2022 00:43:00 | 70.1                           | 19.1                            | 82  |
| 11-06-2022 01:13:00 | 70                             | 19                              | 80  |
| 11-06-2022 01:43:00 | 69.2                           | 19                              | 81  |
| 11-06-2022 02:13:00 | 69.3                           | 18.9                            | 81  |
| 11-06-2022 02:43:00 | 69.1                           | 19                              | 83  |
| 11-06-2022 03:13:00 | 69.4                           | 19                              | 83  |
| 11-06-2022 03:43:00 | 68.2                           | 18.8                            | 81  |
| 11-06-2022 04:13:00 | 68.9                           | 18.8                            | 83  |
| 11-06-2022 04:43:00 | 68.8                           | 18.8                            | 82  |
| 11-06-2022 05:13:00 | 69.3                           | 18.8                            | 84  |

| ACTIVITY         | NAME | SIGNATURE AND DATE |
|------------------|------|--------------------|
| REVIEWED BY USER |      |                    |
| REVIEWED BY QA   |      |                    |



# SOMERSET THERAPEUTICS LIMITED

## DATA REPORT - SVP1 AND AMPOULE LINE EMS

### AMPOULE WASHING AREA

| Date Time           | RH                             | Temperature                     | Differential Pressure   |
|---------------------|--------------------------------|---------------------------------|---|
| DD-MM-YYYY HH:MM:SS | Ampoule Washing Area (NMT 80%) | Ampoule Washing Area (NMT 30°C) | Ampoule Washing Area w.r.t Ampoule Decartoning Room (NLT 12 Pa) |
| 11-06-2022 05:43:00 | 69.6                           | 18.8                            | 82  |
| 11-06-2022 06:13:00 | 68.7                           | 18.7                            | 82  |
| 11-06-2022 06:43:00 | 71.2                           | 18.9                            | 78  |
| 11-06-2022 07:13:00 | 72.7                           | 19.1                            | 81  |
| 11-06-2022 07:43:00 | 72.3                           | 19.3                            | 80  |
| 11-06-2022 08:13:00 | 72.4                           | 19.3                            | 80  |
| 11-06-2022 08:43:00 | 69.7                           | 19.1                            | 81  |
| 11-06-2022 09:13:00 | 69.8                           | 18.9                            | 81  |
| 11-06-2022 09:43:00 | 70.2                           | 18.9                            | 81  |
| 11-06-2022 10:13:00 | 70.1                           | 18.9                            | 80  |
| 11-06-2022 10:43:00 | 69.9                           | 18.9                            | 81  |
| 11-06-2022 11:13:00 | 72.6                           | 19.1                            | 81  |
| 11-06-2022 11:43:00 | 72.2                           | 19.1                            | 81  |
| 11-06-2022 12:13:00 | 72.5                           | 19.1                            | 82  |
| 11-06-2022 12:43:00 | 71.2                           | 19.2                            | 84  |
| 11-06-2022 13:13:00 | 70.3                           | 19                              | 82  |
| 11-06-2022 13:43:00 | 70.1                           | 18.8                            | 82  |
| 11-06-2022 14:13:00 | 70.4                           | 18.8                            | 83  |
| 11-06-2022 14:43:00 | 70                             | 18.8                            | 79  |
| 11-06-2022 15:13:00 | 71.8                           | 19                              | 82  |
| 11-06-2022 15:43:00 | 72.2                           | 19.3                            | 81  |
| 11-06-2022 16:13:00 | 71.4                           | 19.3                            | 80  |
| 11-06-2022 16:43:00 | 74                             | 19.2                            | 81  |
| 11-06-2022 17:13:00 | 70.5                           | 19.1                            | 81  |

| ACTIVITY         | NAME | SIGNATURE AND DATE |
|------------------|------|--------------------|
| REVIEWED BY USER |      |                    |
| REVIEWED BY QA   |      |                    |



# SOMERSET THERAPEUTICS LIMITED

## DATA REPORT - SVP1 AND AMPOULE LINE EMS

### AMPOULE WASHING AREA

| Date Time           | RH                             | Temperature                     | Differential Pressure   |
|---------------------|--------------------------------|---------------------------------|---|
| DD-MM-YYYY HH:MM:SS | Ampoule Washing Area (NMT 80%) | Ampoule Washing Area (NMT 30°C) | Ampoule Washing Area w.r.t Ampoule Decartoning Room (NLT 12 Pa) |
| 11-06-2022 17:43:00 | 70.8                           | 19                              | 82  |
| 11-06-2022 18:13:00 | 70.9                           | 19                              | 82  |
| 11-06-2022 18:43:00 | 70.2                           | 18.9                            | 84  |
| 11-06-2022 19:13:00 | 70.8                           | 18.9                            | 82  |
| 11-06-2022 19:43:00 | 70.3                           | 18.8                            | 81  |
| 11-06-2022 20:13:00 | 70.7                           | 18.9                            | 83  |
| 11-06-2022 20:43:00 | 71.3                           | 18.9                            | 84  |
| 11-06-2022 21:13:00 | 70.9                           | 18.9                            | 80  |
| 11-06-2022 21:43:00 | 72.6                           | 19.3                            | 81  |
| 11-06-2022 22:13:00 | 71.3                           | 19.1                            | 74  |
| 11-06-2022 22:43:00 | 70                             | 18.9                            | 82  |
| 11-06-2022 23:13:00 | 68.8                           | 19                              | 82  |
| 11-06-2022 23:43:00 | 65.7                           | 20.4                            | 79  |
| 12-06-2022 00:13:00 | 63.8                           | 21.2                            | 83  |
| 12-06-2022 00:43:00 | 64.1                           | 21.5                            | 80  |
| 12-06-2022 01:13:00 | 62.7                           | 21.4                            | 92  |
| 12-06-2022 01:43:00 | 61.5                           | 21.6                            | 79  |
| 12-06-2022 02:13:00 | 60.1                           | 21.9                            | 79  |
| 12-06-2022 02:43:00 | 59.2                           | 22                              | 86  |
| 12-06-2022 03:13:00 | 58.6                           | 22.1                            | 87  |
| 12-06-2022 03:43:00 | 58.8                           | 22                              | 79  |
| 12-06-2022 04:13:00 | 59.1                           | 21.6                            | 78  |
| 12-06-2022 04:43:00 | 60.8                           | 20.9                            | 71  |
| 12-06-2022 05:13:00 | 62.2                           | 20.2                            | 77  |

| ACTIVITY         | NAME | SIGNATURE AND DATE |
|------------------|------|--------------------|
| REVIEWED BY USER |      |                    |
| REVIEWED BY QA   |      |                    |



## SOMERSET THERAPEUTICS LIMITED

### DATA REPORT - SVP1 AND AMPOULE LINE EMS

#### AMPOULE WASHING AREA

| Date Time           | RH                             | Temperature                     | Differential Pressure   |
|---------------------|--------------------------------|---------------------------------|---|
| DD-MM-YYYY HH:MM:SS | Ampoule Washing Area (NMT 80%) | Ampoule Washing Area (NMT 30°C) | Ampoule Washing Area w.r.t Ampoule Decartoning Room (NLT 12 Pa) |
| 12-06-2022 05:43:00 | 64.6                           | 19.7                            | 68  |
| 12-06-2022 06:13:00 | 65.5                           | 19.3                            | 79  |
| 12-06-2022 06:43:00 | 65.6                           | 19                              | 77  |
| 12-06-2022 07:13:00 | 66.9                           | 18.8                            | 79  |
| 12-06-2022 07:43:00 | 68                             | 18.7                            | 79  |
| 12-06-2022 08:13:00 | 67                             | 18.5                            | 79  |
| 12-06-2022 08:43:00 | 67.2                           | 18.4                            | 77  |
| 12-06-2022 09:13:00 | 67.6                           | 18.3                            | 78  |
| 12-06-2022 09:43:00 | 67.5                           | 18.3                            | 78  |
| 12-06-2022 10:13:00 | 67.6                           | 18.2                            | 79  |
| 12-06-2022 10:43:00 | 67.7                           | 18.3                            | 79  |
| 12-06-2022 11:13:00 | 72.3                           | 18.2                            | 57  |
| 12-06-2022 11:43:00 | 69                             | 18.2                            | 80  |
| 12-06-2022 12:13:00 | 68.5                           | 18.1                            | 76  |
| 12-06-2022 12:43:00 | 68.3                           | 18.1                            | 82  |
| 12-06-2022 13:13:00 | 68.3                           | 18                              | 81  |
| 12-06-2022 13:43:00 | 68.3                           | 18                              | 81  |
| 12-06-2022 14:13:00 | 67.6                           | 18                              | 87  |
| 12-06-2022 14:43:00 | 68.7                           | 18                              | 82  |
| 12-06-2022 15:13:00 | 69.4                           | 18                              | 81  |
| 12-06-2022 15:43:00 | 68.7                           | 18                              | 82  |
| 12-06-2022 16:13:00 | 68.9                           | 18                              | 82  |
| 12-06-2022 16:43:00 | 69                             | 18                              | 80  |
| 12-06-2022 17:13:00 | 68.9                           | 18                              | 82  |

| ACTIVITY         | NAME | SIGNATURE AND DATE |
|------------------|------|--------------------|
| REVIEWED BY USER |      |                    |
| REVIEWED BY QA   |      |                    |



## SOMERSET THERAPEUTICS LIMITED

### DATA REPORT - SVP1 AND AMPOULE LINE EMS

#### AMPOULE WASHING AREA

| Date Time           | RH                             | Temperature                     | Differential Pressure   |
|---------------------|--------------------------------|---------------------------------|---|
| DD-MM-YYYY HH:MM:SS | Ampoule Washing Area (NMT 80%) | Ampoule Washing Area (NMT 30°C) | Ampoule Washing Area w.r.t Ampoule Decartoning Room (NLT 12 Pa) |
| 12-06-2022 17:43:00 | 68.7                           | 17.9                            | 81  |
| 12-06-2022 18:13:00 | 69                             | 18                              | 81  |
| 12-06-2022 18:43:00 | 68.9                           | 17.9                            | 80  |
| 12-06-2022 19:13:00 | 69.3                           | 17.9                            | 81  |
| 12-06-2022 19:43:00 | 69.4                           | 17.9                            | 79  |
| 12-06-2022 20:13:00 | 70.5                           | 18                              | 79  |
| 12-06-2022 20:43:00 | 70.8                           | 18.2                            | 81  |
| 12-06-2022 21:13:00 | 70.2                           | 18.2                            | 78  |
| 12-06-2022 21:43:00 | 69.9                           | 18.1                            | 72  |
| 12-06-2022 22:13:00 | 70.2                           | 18.1                            | 78  |
| 12-06-2022 22:43:00 | 69.9                           | 18.1                            | 81  |
| 12-06-2022 23:13:00 | 70                             | 18.1                            | 81  |
| 12-06-2022 23:43:00 | 70                             | 18.1                            | 80  |
| 13-06-2022 00:13:00 | 71.9                           | 18.3                            | 80  |
| 13-06-2022 00:43:00 | 70.7                           | 18.3                            | 81  |
| 13-06-2022 01:13:00 | 70.5                           | 18.2                            | 80  |
| 13-06-2022 01:43:00 | 71.7                           | 18.4                            | 82  |
| 13-06-2022 02:13:00 | 71.1                           | 18.4                            | 81  |
| 13-06-2022 02:43:00 | 70.9                           | 18.5                            | 81  |
| 13-06-2022 03:13:00 | 71.8                           | 18.6                            | 82  |
| 13-06-2022 03:43:00 | 71.2                           | 18.7                            | 81  |
| 13-06-2022 04:13:00 | 70.9                           | 18.6                            | 81  |
| 13-06-2022 04:43:00 | 71.6                           | 18.6                            | 83  |
| 13-06-2022 05:13:00 | 70.9                           | 18.6                            | 82  |

| ACTIVITY         | NAME | SIGNATURE AND DATE |
|------------------|------|--------------------|
| REVIEWED BY USER |      |                    |
| REVIEWED BY QA   |      |                    |



## SOMERSET THERAPEUTICS LIMITED

### DATA REPORT - SVP1 AND AMPOULE LINE EMS

#### AMPOULE WASHING AREA

| Date Time           | RH                             | Temperature                     | Differential Pressure   |
|---------------------|--------------------------------|---------------------------------|---|
| DD-MM-YYYY HH:MM:SS | Ampoule Washing Area (NMT 80%) | Ampoule Washing Area (NMT 30°C) | Ampoule Washing Area w.r.t Ampoule Decartoning Room (NLT 12 Pa) |
| 13-06-2022 05:43:00 | 71.1                           | 18.6                            | 81  |
| 13-06-2022 06:13:00 | 70.9                           | 18.6                            | 81  |
| 13-06-2022 06:43:00 | 74.4                           | 18.9                            | 79  |
| 13-06-2022 07:13:00 | 74.8                           | 18.9                            | 82  |
| 13-06-2022 07:43:00 | 73.9                           | 19.2                            | 80  |
| 13-06-2022 08:13:00 | 73.8                           | 19.2                            | 82  |
| 13-06-2022 08:43:00 | 73                             | 19.2                            | 82  |
| 13-06-2022 09:13:00 | 73.1                           | 19.2                            | 81  |
| 13-06-2022 09:43:00 | 71.8                           | 19.1                            | 82  |
| 13-06-2022 10:13:00 | 72                             | 19                              | 79  |
| 13-06-2022 10:43:00 | 71.2                           | 18.9                            | 81  |
| 13-06-2022 11:13:00 | 73.3                           | 18.9                            | 80  |
| 13-06-2022 11:43:00 | 71                             | 19                              | 81  |
| 13-06-2022 12:13:00 | 70.8                           | 18.8                            | 84  |
| 13-06-2022 12:43:00 | 71.1                           | 18.9                            | 82  |
| 13-06-2022 13:13:00 | 72                             | 19                              | 81  |
| 13-06-2022 13:43:00 | 73.3                           | 19.2                            | 83  |
| 13-06-2022 14:13:00 | 71.4                           | 19.2                            | 82  |
| 13-06-2022 14:43:00 | 70.2                           | 19                              | 78  |
| 13-06-2022 15:13:00 | 71.3                           | 19                              | 82  |
| 13-06-2022 15:43:00 | 75.4                           | 19.2                            | 79  |
| 13-06-2022 16:13:00 | 74.9                           | 19.7                            | 79  |
| 13-06-2022 16:43:00 | 75.7                           | 19.8                            | 81  |
| 13-06-2022 17:13:00 | 70.8                           | 19.5                            | 85  |

| ACTIVITY         | NAME | SIGNATURE AND DATE |
|------------------|------|--------------------|
| REVIEWED BY USER |      |                    |
| REVIEWED BY QA   |      |                    |



## SOMERSET THERAPEUTICS LIMITED

### DATA REPORT - SVP1 AND AMPOULE LINE EMS

#### AMPOULE WASHING AREA

| Date Time           | RH                             | Temperature                     | Differential Pressure   |
|---------------------|--------------------------------|---------------------------------|---|
| DD-MM-YYYY HH:MM:SS | Ampoule Washing Area (NMT 80%) | Ampoule Washing Area (NMT 30°C) | Ampoule Washing Area w.r.t Ampoule Decartoning Room (NLT 12 Pa) |
| 13-06-2022 17:43:00 | 70.8                           | 19.2                            | 80  |

End Of Report : From 10-06-2022 17:43:44 To 13-06-2022 17:43:44

| ACTIVITY         | NAME | SIGNATURE AND DATE |
|------------------|------|--------------------|
| REVIEWED BY USER |      |                    |
| REVIEWED BY QA   |      |                    |