



## SOMERSET THERAPEUTICS LIMITED

### DATA REPORT - SVP1 AND AMPOULE LINE EMS

#### AMPOULE WASHING AREA

Date Time	RH	Temperature	Differential Pressure
DD-MM-YYYY HH:MM:SS	Ampoule Washing Area (NMT 80%)	Ampoule Washing Area (NMT 30°C)	Ampoule Washing Area w.r.t Ampoule Decartoning Room (NLT 12 Pa)
10-06-2022 04:51:00	70.6	19.9	81
10-06-2022 05:21:00	71.7	20	80
10-06-2022 05:51:00	72.1	20	80
10-06-2022 06:21:00	71.6	20.1	81
10-06-2022 06:51:00	71.4	20	80
10-06-2022 07:21:00	71.4	20	80
10-06-2022 07:51:00	68.9	19.7	81
10-06-2022 08:21:00	68.7	19.4	79
10-06-2022 08:51:00	69.9	19.4	83
10-06-2022 09:21:00	70	19.4	81
10-06-2022 09:51:00	69.3	19.3	82
10-06-2022 10:21:00	71.6	19.4	81
10-06-2022 10:51:00	71.3	19.6	78
10-06-2022 11:21:00	69.9	19.3	82
10-06-2022 11:51:00	70.5	19.5	81
10-06-2022 12:21:00	70.3	19.3	80
10-06-2022 12:51:00	68.4	19.1	77
10-06-2022 13:21:00	68.3	19	82
10-06-2022 13:51:00	68.2	18.9	82
10-06-2022 14:21:00	68.3	18.9	81
10-06-2022 14:51:00	71.7	19.1	81
10-06-2022 15:21:00	73.7	19.5	79
10-06-2022 15:51:00	73.7	19.7	81
10-06-2022 16:21:00	71.5	19.6	80

ACTIVITY	NAME	SIGNATURE AND DATE
REVIEWED BY USER		
REVIEWED BY QA		



## SOMERSET THERAPEUTICS LIMITED

### DATA REPORT - SVP1 AND AMPOULE LINE EMS

#### AMPOULE WASHING AREA

Date Time	RH	Temperature	Differential Pressure
DD-MM-YYYY HH:MM:SS	Ampoule Washing Area (NMT 80%)	Ampoule Washing Area (NMT 30°C)	Ampoule Washing Area w.r.t Ampoule Decartoning Room (NLT 12 Pa)
10-06-2022 16:51:00	70.9	19.7	80
10-06-2022 17:21:00	70.4	19.6	79
10-06-2022 17:51:00	69.9	19.3	80
10-06-2022 18:21:00	68.3	19.2	79
10-06-2022 18:51:00	67.6	18.8	79
10-06-2022 19:21:00	67.8	18.8	78
10-06-2022 19:51:00	68	18.6	79
10-06-2022 20:21:00	67.9	18.6	80
10-06-2022 20:51:00	67.6	18.6	82
10-06-2022 21:21:00	69.9	18.6	80
10-06-2022 21:51:00	68.3	18.7	77
10-06-2022 22:21:00	68.5	18.6	79
10-06-2022 22:51:00	73.5	19	80
10-06-2022 23:21:00	71	19.3	81
10-06-2022 23:51:00	73.1	19.3	80
11-06-2022 00:21:00	71	19.4	81
11-06-2022 00:51:00	69.7	19.1	81
11-06-2022 01:21:00	70	19	81
11-06-2022 01:51:00	69.5	19	80
11-06-2022 02:21:00	69.3	18.9	81
11-06-2022 02:51:00	69.5	19	81
11-06-2022 03:21:00	68.9	18.9	81
11-06-2022 03:51:00	68.6	18.8	82
11-06-2022 04:21:00	69.6	18.8	83

ACTIVITY	NAME	SIGNATURE AND DATE
REVIEWED BY USER		
REVIEWED BY QA		



## SOMERSET THERAPEUTICS LIMITED

### DATA REPORT - SVP1 AND AMPOULE LINE EMS

#### AMPOULE WASHING AREA

Date Time	RH	Temperature	Differential Pressure
DD-MM-YYYY HH:MM:SS	Ampoule Washing Area (NMT 80%)	Ampoule Washing Area (NMT 30°C)	Ampoule Washing Area w.r.t Ampoule Decartoning Room (NLT 12 Pa)
11-06-2022 04:51:00	69	18.8	82

End Of Report : From 10-06-2022 04:51:03 To 11-06-2022 04:51:03

ACTIVITY	NAME	SIGNATURE AND DATE
REVIEWED BY USER		
REVIEWED BY QA		