




	10-07-2022 11:12:00	17.7	77.4	50	22	47
	10-07-2022 11:27:00	17.6	77.3	50	22	45
 SOMERSET THERAPEUTICS LIMITED DATA REPORT - SVPI AND AMPOULE LINE EMS WASHING AND STERILIZATION AREA	10-07-2022 11:42:00	17.6	79.4	48	21	45
	10-07-2022 11:57:00	17.6	77.7	50	22	45
	10-07-2022 12:12:00	17.5	77.6	50	22	46
	10-07-2022 12:27:00	17.3	78.9	51	0	0
	10-07-2022 12:42:00	17.4	79	51	0	0
	10-07-2022 13:57:00	17.5	79.8	51	0	0
	10-07-2022 14:12:00	17.5	79.4	51	0	0
<div> <div>Date Time</div> <div>DD-MM-YYYY HH:MM:SS</div> </div> <div> <div>Temperature</div> <div>Washing and Sterilization Area (NMT 30°C)</div> </div> <div> <div>RH</div> <div>Washing and Sterilization Area (NMT 80%)</div> </div> <div> <div>Diffrential Pressure</div> <div>Washing and Sterilization Area w.r.t Unit Preparation Room (NLT 6 Pa)</div> </div> <div> <div>Diffrential Pressure</div> <div>Washing and Sterilization Area w.r.t Ampoule Decartoning Room (NLT 12 Pa)</div> </div> <div> <div>Diffrential Pressure</div> <div>Washing and Sterilization Area w.r.t Injectable main corridor (NLT 12 Pa)</div> </div>	10-07-2022 14:27:00	17.5	79.7	50	0	0
	10-07-2022 14:42:00	17.6	79.4	51	1	0
	10-07-2022 14:57:00	17.7	79	50	0	0
	10-07-2022 15:12:00	19.4	78.3	0	0	0
	10-07-2022 15:27:00	20.3	76.7	0	0	0
	10-07-2022 15:42:00	20.8	75.1	0	0	0
	10-07-2022 15:57:00	21	74.3	0	0	1
	10-07-2022 16:12:00	21	75.4	0	0	1
	10-07-2022 16:27:00	21	84.6	0	0	1
	10-07-2022 16:42:00	21	94.7	0	0	0
	10-07-2022 16:57:00	21.4	96.4	0	0	0
	10-07-2022 17:12:00	21.9	96.7	0	0	0
	10-07-2022 17:27:00	22	95	0	0	0
	10-07-2022 17:42:00	21.8	94.7	0	0	0
	10-07-2022 17:57:00	21.7	94.4	0	0	0
	10-07-2022 18:12:00	21.7	94.2	0	0	0
	10-07-2022 18:27:00	21.7	94	0	0	0
	10-07-2022 18:42:00	21.2	83.2	44	22	45
	10-07-2022 18:57:00	19.5	78.9	46	21	44
	10-07-2022 19:12:00	18.7	77.3	45	21	43
	10-07-2022 19:27:00	18.2	77.1	46	21	44
	10-07-2022 19:42:00	17.9	77.1	47	21	44
ACTIVITY		NAME		SIGNATURE AND DATE		
REVIEWED BY USER						
REVIEWED BY QA						

	10-07-2022 19:57:00	17.8	77.5	38	19	45
	10-07-2022 20:12:00	17.7	77.2	38	21	43
<div>  <div> <div>SOMERSET THERAPEUTICS LIMITED</div> <div>DATA REPORT - SVPI AND AMPOULE LINE EMS</div> <div>WASHING AND STERILIZATION AREA</div> </div> </div>	10-07-2022 20:27:00	17.6	77.3	27	19	41
	10-07-2022 20:42:00	17.8	78	47	22	45
	10-07-2022 20:57:00	17.9	77.9	48	21	44
	10-07-2022 21:12:00	17.9	77.7	29	19	42
	10-07-2022 21:27:00	18.1	79.8	36	18	42
	10-07-2022 21:42:00	18	78.1	38	21	44
	10-07-2022 21:57:00	17.9	77.7	47	22	45
<div>  <div> <div>SOMERSET THERAPEUTICS LIMITED</div> <div>DATA REPORT - SVPI AND AMPOULE LINE EMS</div> <div>WASHING AND STERILIZATION AREA</div> </div> </div>	Date Time	Temperature	RH	Diffrential Pressure	Diffrential Pressure	Diffrential Pressure
	DD-MM-YYYY HH:MM:SS	Washing and Sterilization Area (NMT 30°C)	Washing and Sterilization Area (NMT 80%)	Washing and Sterilization Area w.r.t Unit Preparation Room (NLT 6 Pa)	Washing and Sterilization Area w.r.t Ampoule Decartoning Room (NLT 12 Pa)	Washing and Sterilization Area w.r.t Injectable main corridor (NLT 12 Pa)
	10-07-2022 22:42:00	17.7	76.6	29	21	44
	10-07-2022 22:57:00	17.6	76.6	47	21	45
	10-07-2022 23:12:00	17.6	77.3	46	19	40
	10-07-2022 23:27:00	17.6	77.4	45	19	40
	10-07-2022 23:42:00	18.2	75.7	47	20	42
	10-07-2022 23:57:00	17.9	75.7	47	19	40
	11-07-2022 00:12:00	17.7	77.7	47	26	47
	11-07-2022 00:27:00	17.9	77.4	45	18	38
	11-07-2022 00:42:00	17.9	77.8	47	19	39
	11-07-2022 00:57:00	17.8	76.9	47	18	36
	11-07-2022 01:12:00	17.6	76.2	45	15	37
	11-07-2022 01:27:00	17.4	76.5	46	20	41
	11-07-2022 01:42:00	17.3	77.1	46	20	40
	11-07-2022 01:57:00	17.2	77	47	20	41
	11-07-2022 02:12:00	17.2	76.9	48	20	41
	11-07-2022 02:27:00	17.2	76.4	46	19	39
	11-07-2022 02:42:00	17.2	77	48	20	42
	11-07-2022 02:57:00	17.3	76.7	48	20	41
	11-07-2022 03:12:00	17.3	76.5	47	19	39
	11-07-2022 03:27:00	17.6	75.8	47	18	38
	11-07-2022 03:42:00	17.4	77	47	19	37
	11-07-2022 03:57:00	17.7	79.8	45	19	38
	11-07-2022 04:12:00	18	76.7	47	18	38
	11-07-2022 04:27:00	17.8	76	47	18	39
	11-07-2022 04:42:00	17.7	77.7	47	26	47
	11-07-2022 04:57:00	17.9	77.4	45	18	38
	11-07-2022 05:12:00	17.9	77.8	47	19	39
	11-07-2022 05:27:00	17.8	76.9	47	18	36
	11-07-2022 05:42:00	17.6	76.2	45	15	37
	11-07-2022 05:57:00	17.4	76.5	46	20	41
	11-07-2022 06:12:00	17.3	77.1	46	20	40
	11-07-2022 06:27:00	17.2	77	47	20	41
	11-07-2022 06:42:00	17.2	76.9	48	20	41
	11-07-2022 06:57:00	17.2	76.4	46	19	39
	11-07-2022 07:12:00	17.2	77	48	20	42
	11-07-2022 07:27:00	17.3	76.7	48	20	41
	11-07-2022 07:42:00	17.3	76.5	47	19	39
	11-07-2022 07:57:00	17.6	75.8	47	18	38
	11-07-2022 08:12:00	17.4	77	47	19	37
	11-07-2022 08:27:00	17.7	79.8	45	19	38
	11-07-2022 08:42:00	18	76.7	47	18	38
	11-07-2022 08:57:00	17.8	76	47	18	39
ACTIVITY		NAME		SIGNATURE AND DATE		
REVIEWED BY USER						
REVIEWED BY QA						

11-07-2022 04:42:00	17.7	76.1	46	19	39
11-07-2022 04:57:00	17.6	75.9	47	18	39
11-07-2022 05:12:00	17.5	76	46	19	39
11-07-2022 05:27:00	17.4	76.5	45	18	38
11-07-2022 05:42:00	17.4	76.3	44	18	35
11-07-2022 05:57:00	17.4	76.4	46	20	40
11-07-2022 06:12:00	17.6	75.4	44	15	23
11-07-2022 06:27:00	17.6	75.1	47	20	42
Date Time	Temperature	RH	Diffrential Pressure	Diffrential Pressure	Diffrential Pressure
DD-MM-YYYY HH:MM:SS	Washing and Sterilization Area (NMT 30°C)	Washing and Sterilization Area (NMT 80%)	Washing and Sterilization Area w.r.t Unit Preparation Room (NLT 6 Pa)	Washing and Sterilization Area w.r.t Ampoule Decartoning Room (NLT 12 Pa)	Washing and Sterilization Area w.r.t Injectable main corridor (NLT 12 Pa)
11-07-2022 07:27:00	17.9	79.4	46	20	40
11-07-2022 07:42:00	17.9	77.5	45	19	42
11-07-2022 07:57:00	17.7	76.9	45	20	42
11-07-2022 08:12:00	17.6	77.8	46	18	40
11-07-2022 08:27:00	17.6	78.5	47	20	42
11-07-2022 08:42:00	17.6	79.1	36	17	38
11-07-2022 08:57:00	17.7	79.7	46	20	40
11-07-2022 09:12:00	17.8	81	46	20	40
11-07-2022 09:27:00	17.7	80.3	46	20	42
11-07-2022 09:42:00	17.8	80.6	45	19	40
11-07-2022 09:57:00	18	84.7	45	17	40
11-07-2022 10:12:00	17.8	81	45	18	38
11-07-2022 10:27:00	17.8	79.5	46	17	38
11-07-2022 10:42:00	18	78.7	45	18	37
11-07-2022 10:57:00	18.1	78.6	45	17	36
11-07-2022 11:12:00	18.2	77	45	17	37
Min Value	17.2	74.3	0	0	0
Max Value	22	96.7	52	26	47

End Of Report : From 10-07-2022 11:12:06 To 11-07-2022 11:12:06

ACTIVITY	NAME	SIGNATURE AND DATE
REVIEWED BY USER		
REVIEWED BY QA		