



# SOMERSET THERAPEUTICS LIMITED

## DATA REPORT - SVP1 AND AMPOULE LINE EMS

### WASHING AND STERILIZATION AREA

Date Time	Temperature	RH	Diffrential Pressure	Diffrential Pressure	Diffrential Pressure
DD-MM-YYYY HH:MM:SS	Washing and Sterilization Area (NMT 30°C)	Washing and Sterilization Area (NMT 80%)	Washing and Sterilization Area w.r.t Unit Preparation Room (NLT 6 Pa)	Washing and Sterilization Area w.r.t Ampoule Decartoning Room (NLT 12 Pa)	Washing and Sterilization Area w.r.t Injectable main corridor (NLT 12 Pa)
04/05/2022 12:00:00	18.1	77.1	21	13	38
04/05/2022 12:30:00	18.1	77.1	21	13	38
04/05/2022 13:00:00	18.1	77.1	21	13	38
04/05/2022 13:30:00	18.1	77.1	21	13	38
04/05/2022 14:00:00	18.1	77.1	21	13	38
04/05/2022 14:30:00	18.1	77.1	21	13	38
04/05/2022 15:00:00	18.1	77.1	21	13	38
04/05/2022 15:30:00	18.1	77.1	21	13	38
04/05/2022 16:00:00	18.1	77.1	21	13	38
04/05/2022 16:30:00	18.1	77.1	21	13	38
04/05/2022 17:00:00	18.1	77.1	21	13	38
04/05/2022 17:30:00	18.1	77.1	21	13	38
04/05/2022 18:00:00	18.1	77.1	21	13	38
04/05/2022 18:30:00	18.1	77.1	21	13	38
04/05/2022 19:00:00	18.1	77.1	21	13	38
04/05/2022 19:30:00	18.1	77.1	21	13	38
04/05/2022 20:00:00	18.1	77.1	21	13	38
04/05/2022 20:30:00	18.1	77.1	21	13	38
04/05/2022 21:00:00	18.1	77.1	21	13	38
04/05/2022 21:30:00	18.1	77.1	21	13	38
04/05/2022 22:00:00	18.1	77.1	21	13	38
04/05/2022 22:30:00	18.1	77.1	21	13	38
04/05/2022 23:00:00	18.1	77.1	21	13	38
04/05/2022 23:30:00	18.1	77.1	21	13	38

ACTIVITY	NAME	SIGNATURE AND DATE
REVIEWED BY USER		
REVIEWED BY QA		



# SOMERSET THERAPEUTICS LIMITED

## DATA REPORT - SVP1 AND AMPOULE LINE EMS

### WASHING AND STERILIZATION AREA

Date Time	Temperature	RH	Diffrential Pressure	Diffrential Pressure	Diffrential Pressure
DD-MM-YYYY HH:MM:SS	Washing and Sterilization Area (NMT 30°C)	Washing and Sterilization Area (NMT 80%)	Washing and Sterilization Area w.r.t Unit Preparation Room (NLT 6 Pa)	Washing and Sterilization Area w.r.t Ampoule Decartoning Room (NLT 12 Pa)	Washing and Sterilization Area w.r.t Injectable main corridor (NLT 12 Pa)
05/05/2022 00:00:00	18.1	77.1	21	13	38
05/05/2022 00:30:00	18.1	77.1	21	13	38
05/05/2022 01:00:00	18.1	77.1	21	13	38
05/05/2022 01:30:00	18.1	77.1	21	13	38
05/05/2022 02:00:00	18.1	77.1	21	13	38
05/05/2022 02:30:00	18.1	77.1	21	13	38
05/05/2022 03:00:00	18.1	77.1	21	13	38
05/05/2022 03:30:00	18.1	77.1	21	13	38
05/05/2022 04:00:00	18.1	77.1	21	13	38
05/05/2022 04:30:00	18.1	77.1	21	13	38
05/05/2022 05:00:00	18.1	77.1	21	13	38
05/05/2022 05:30:00	18.1	77.1	21	13	38
05/05/2022 06:00:00	18.1	77.1	21	13	38
05/05/2022 06:30:00	18.1	77.1	21	13	38
05/05/2022 07:00:00	18.1	77.1	21	13	38
05/05/2022 07:30:00	18.1	77.1	21	13	38
05/05/2022 08:00:00	18.1	77.1	21	13	38
05/05/2022 08:30:00	18.1	77.1	21	13	38
05/05/2022 09:00:00	18.1	77.1	21	13	38
05/05/2022 09:30:00	18.1	77.1	21	13	38
05/05/2022 10:00:00	18.1	77.1	21	13	38
05/05/2022 10:30:00	18.1	77.1	21	13	38
05/05/2022 11:00:00	18.1	77.1	21	13	38
05/05/2022 11:30:00	18.1	77.1	21	13	38

ACTIVITY	NAME	SIGNATURE AND DATE
REVIEWED BY USER		
REVIEWED BY QA		



## SOMERSET THERAPEUTICS LIMITED

### DATA REPORT - SVP1 AND AMPOULE LINE EMS

#### WASHING AND STERILIZATION AREA

Date Time	Temperature	RH	Diffrential Pressure	Diffrential Pressure	Diffrential Pressure
DD-MM-YYYY HH:MM:SS	Washing and Sterilization Area (NMT 30°C)	Washing and Sterilization Area (NMT 80%)	Washing and Sterilization Area w.r.t Unit Preparation Room (NLT 6 Pa)	Washing and Sterilization Area w.r.t Ampoule Decartoning Room (NLT 12 Pa)	Washing and Sterilization Area w.r.t Injectable main corridor (NLT 12 Pa)
05/05/2022 12:00:00	18.1	77.1	21	13	38
Min Value	18.1	77.1	21	13	38
Max Value	18.1	77.1	21	13	38

End Of Report : From 04-05-2022 12:00:37 To 05-05-2022 12:00:37

ACTIVITY	NAME	SIGNATURE AND DATE
REVIEWED BY USER		
REVIEWED BY QA		