



Environmental Monitoring System

fdfdffdfdfdf

DATA REPORT

STERILE EXIT CHANGE ROOMS (L4)

Date Time	STERILE PASSAGE (L4) wrt EXIT ROOM-1 (L4)	STERILE EXIT ROOM-1 (L4)	ASEPTIC EXIT ROOM-1 (L4) wrt EXIT ROOM-2 (L4)	STERILE EXIT ROOM-2 (L4)	ASEPTIC EXIT ROOM-2 (L4) wrt EXIT ROOM-3 (L4)	STERILE EXIT ROOM-3 (L4)
Date Time	DP Pa	°C TEMP	DP Pa	°C TEMP	DP Pa	°C TEMP
Alarm Low Limit	252	253.00	254	255.00	256	257.00
Set Value						
Alarm High Limit	379	380.00	381	382.00	383	384.00
24-05-2022 11:30	10	22.02	24	23.21	26	21.93
24-05-2022 11:40	9	21.97	23	23.18	26	21.83
24-05-2022 11:50	11	21.98	23	23.15	27	21.88
24-05-2022 12:00	12	21.98	23	23.13	27	21.86
24-05-2022 12:10	13	21.96	24	23.12	27	21.86
24-05-2022 12:20	11	21.92	25	23.05	21	21.83
24-05-2022 12:30	10	21.90	23	23.03	25	21.81
24-05-2022 12:40	8	21.93	22	22.97	27	21.92
24-05-2022 12:50	11	21.95	23	22.94	27	21.90
24-05-2022 13:00	10	21.95	25	22.95	22	21.90
24-05-2022 13:10	9	21.87	23	22.88	26	21.89
24-05-2022 13:20	11	21.77	23	22.88	25	21.86
24-05-2022 13:30	11	21.74	23	22.83	27	21.78
24-05-2022 13:40	9	21.71	23	22.81	25	21.71
24-05-2022 13:50	11	21.76	23	22.80	27	21.68
24-05-2022 14:00	10	21.81	23	22.80	27	21.67
24-05-2022 14:10	10	21.79	22	22.80	27	21.65
24-05-2022 14:20	10	21.77	23	22.80	23	21.61
24-05-2022 14:30	10	21.81	23	22.77	27	21.63
24-05-2022 14:40	8	21.86	20	22.79	24	21.62
24-05-2022 14:50	0	21.95	9	22.78	12	21.62
24-05-2022 15:00	9	21.93	23	22.77	28	21.59
24-05-2022 15:10	9	21.85	22	22.77	27	21.55



Environmental Monitoring System

fdfddfdfdffff

DATA REPORT

STERILE EXIT CHANGE ROOMS (L4)

Date Time	STERILE PASSAGE (L4) wrt EXIT ROOM-1 (L4)	STERILE EXIT ROOM-1 (L4)	ASEPTIC EXIT ROOM-1 (L4) wrt EXIT ROOM-2 (L4)	STERILE EXIT ROOM-2 (L4)	ASEPTIC EXIT ROOM-2 (L4) wrt EXIT ROOM-3 (L4)	STERILE EXIT ROOM-3 (L4)
Date Time	DP Pa	°C TEMP	DP Pa	°C TEMP	DP Pa	°C TEMP
24-05-2022 15:20	11	21.80	24	22.72	27	21.53
24-05-2022 15:30	8	21.80	24	22.64	24	21.53
24-05-2022 15:40	9	21.78	23	22.51	27	21.56
24-05-2022 15:50	7	21.77	23	22.59	27	21.48
24-05-2022 16:00	9	21.85	22	22.64	25	21.46
24-05-2022 16:10	9	21.83	23	22.62	24	21.43
24-05-2022 16:20	11	21.83	24	22.64	28	21.40
24-05-2022 16:30	9	21.86	24	22.61	27	21.35
24-05-2022 16:40	6	21.94	21	22.63	23	21.39
24-05-2022 16:50	6	22.01	21	22.67	22	21.41
24-05-2022 17:00	5	22.06	21	22.70	25	21.50
24-05-2022 17:10	6	22.11	20	22.74	24	21.54
24-05-2022 17:20	6	22.11	21	22.75	25	21.53
24-05-2022 17:30	4	22.08	21	22.75	24	21.52
24-05-2022 17:40	8	22.08	24	22.74	28	21.53
24-05-2022 17:50	7	22.09	23	22.74	27	21.50
24-05-2022 18:00	8	22.13	23	22.74	25	21.50
24-05-2022 18:10	9	22.13	23	22.76	26	21.54
24-05-2022 18:20	8	22.12	23	22.81	27	21.54
24-05-2022 18:30	7	22.08	24	22.80	27	21.52
24-05-2022 18:40	9	22.05	23	22.77	27	21.50
24-05-2022 18:50	8	22.09	23	22.77	28	21.50
24-05-2022 19:00	8	22.15	23	22.76	27	21.61
Min Value	9999	9999.00	9999	9999.00	9999	9999.00
Max Value	-9999	-9999.00	-9999	-9999.00	-9999	-9999.00



Environmental Monitoring System

fdfddfdfdffff

DATA REPORT

STERILE EXIT CHANGE ROOMS (L4)

Date Time	STERILE PASSAGE (L4) wrt EXIT ROOM-1 (L4)	STERILE EXIT ROOM-1 (L4)	ASEPTIC EXIT ROOM-1 (L4) wrt EXIT ROOM-2 (L4)	STERILE EXIT ROOM-2 (L4)	ASEPTIC EXIT ROOM-2 (L4) wrt EXIT ROOM-3 (L4)	STERILE EXIT ROOM-3 (L4)
Date Time	DP Pa	°C TEMP	DP Pa	°C TEMP	DP Pa	°C TEMP

End Of Report : From 24/05/2022 11:30:35 To 25/05/2022 11:30:35

ACTIVITY	NAME	SIGNATURE AND DATE
REVIEWED BY USER		
REVIEWED BY QA		