



SOMERSET THERAPEUTICS LIMITED

DATA REPORT - SVP1 AND AMPOULE LINE EMS

WASHING AND STERILIZATION AREA

Date Time	Temperature	RH	Diffrential Pressure	Diffrential Pressure	Diffrential Pressure
DD-MM-YYYY HH:MM:SS	Washing and Sterilization Area (NMT 30°C)	Washing and Sterilization Area (NMT 80%)	Washing and Sterilization Area w.r.t Unit Preparation Room (NLT 6 Pa)	Washing and Sterilization Area w.r.t Ampoule Decartoning Room (NLT 12 Pa)	Washing and Sterilization Area w.r.t Injectable main corridor (NLT 12 Pa)
12-07-2022 14:55:00	18.4	80	47	21	47
12-07-2022 14:56:00	18.4	79.9	47	21	42
12-07-2022 14:57:00	18.4	79.8	27	20	42
12-07-2022 14:58:00	18.4	79.7	47	23	45
12-07-2022 14:59:00	18.4	79.4	47	23	46
12-07-2022 15:00:00	18.4	79.3	3	13	27
12-07-2022 15:01:00	18.4	79.6	0	8	22
12-07-2022 15:02:00	18.5	79.4	0	8	21
12-07-2022 15:03:00	18.6	79	0	8	21
12-07-2022 15:04:00	18.7	78.5	0	8	22
12-07-2022 15:05:00	18.8	78.1	0	7	19
12-07-2022 15:06:00	18.9	77.7	0	8	21
12-07-2022 15:07:00	19	77.2	0	8	22
12-07-2022 15:08:00	19	76.8	0	8	21
12-07-2022 15:09:00	19.1	76.5	0	7	22
12-07-2022 15:10:00	19.2	76.1	0	7	20
12-07-2022 15:11:00	19.3	75.9	2	10	22
12-07-2022 15:12:00	19.3	74.9	47	20	37
12-07-2022 15:13:00	19.3	75.7	47	22	45
12-07-2022 15:14:00	19.3	76.1	47	23	45
12-07-2022 15:15:00	19.2	76.6	46	23	45
12-07-2022 15:16:00	19.1	77.1	38	22	46
12-07-2022 15:17:00	19	77.5	46	22	46
12-07-2022 15:18:00	19	78.1	48	23	45

ACTIVITY	NAME	SIGNATURE AND DATE
REVIEWED BY USER		
REVIEWED BY QA		



SOMERSET THERAPEUTICS LIMITED

DATA REPORT - SVP1 AND AMPOULE LINE EMS

WASHING AND STERILIZATION AREA

Date Time	Temperature	RH	Diffrential Pressure	Diffrential Pressure	Diffrential Pressure
DD-MM-YYYY HH:MM:SS	Washing and Sterilization Area (NMT 30°C)	Washing and Sterilization Area (NMT 80%)	Washing and Sterilization Area w.r.t Unit Preparation Room (NLT 6 Pa)	Washing and Sterilization Area w.r.t Ampoule Decartoning Room (NLT 12 Pa)	Washing and Sterilization Area w.r.t Injectable main corridor (NLT 12 Pa)
12-07-2022 15:19:00	19	78.4	46	22	47
12-07-2022 15:20:00	18.9	78.5	47	23	44
12-07-2022 15:21:00	18.9	78.5	46	23	46
12-07-2022 15:22:00	18.9	78.6	46	23	46
12-07-2022 15:23:00	18.9	78.6	47	22	46
12-07-2022 15:24:00	18.9	78.4	46	23	45
12-07-2022 15:25:00	19	78.2	46	23	46
12-07-2022 15:26:00	18.9	78.1	47	22	46
12-07-2022 15:27:00	18.9	78.1	47	20	43
12-07-2022 15:28:00	18.9	78.1	47	22	45
12-07-2022 15:29:00	18.9	78	46	22	46
12-07-2022 15:30:00	18.9	78	47	20	45
Min Value	18.4	74.9	0	7	19
Max Value	19.3	80	48	23	47

End Of Report : From 12-07-2022 14:55:00 To 12-07-2022 15:30:00

ACTIVITY	NAME	SIGNATURE AND DATE
REVIEWED BY USER		
REVIEWED BY QA		