



SOMERSET THERAPEUTICS LIMITED

DATA REPORT - SVP1 AND AMPOULE LINE EMS

WASHING AND STERILIZATION AREA

Date Time	Temperature	RH	Diffrential Pressure	Diffrential Pressure	Diffrential Pressure
DD-MM-YYYY HH:MM:SS	Washing and Sterilization Area (NMT 30°C)	Washing and Sterilization Area (NMT 80%)	Washing and Sterilization Area w.r.t Unit Preparation Room (NLT 6 Pa)	Washing and Sterilization Area w.r.t Ampoule Decartoning Room (NLT 12 Pa)	Washing and Sterilization Area w.r.t Injectable main corridor (NLT 12 Pa)
10-07-2022 10:03:00	17.9	78.9	49	22	46
10-07-2022 10:18:00	17.8	78.4	49	21	44
10-07-2022 10:33:00	18.1	77.6	48	21	45
10-07-2022 10:48:00	17.9	77.7	49	22	48
10-07-2022 11:03:00	17.8	77.5	49	22	46
10-07-2022 11:18:00	17.6	77.4	48	22	46
10-07-2022 11:33:00	17.5	77.7	50	22	47
10-07-2022 11:48:00	17.6	78.7	19	19	43
10-07-2022 12:03:00	17.6	77.5	48	22	46
10-07-2022 12:18:00	17.5	77.7	50	5	11
10-07-2022 12:33:00	17.3	78.7	50	0	0
10-07-2022 12:48:00	17.3	79.3	51	0	0
10-07-2022 13:03:00	17.4	81.2	51	0	0
10-07-2022 13:18:00	17.7	81.4	49	0	0
10-07-2022 13:33:00	17.5	80	50	0	0
10-07-2022 13:48:00	17.6	79.8	51	0	0
10-07-2022 14:03:00	17.5	79.9	50	0	0
10-07-2022 14:18:00	17.5	79.7	50	0	0
10-07-2022 14:33:00	17.6	79.5	50	0	0
10-07-2022 14:48:00	17.6	79.4	48	1	0
10-07-2022 15:03:00	18.3	78.4	0	0	0
10-07-2022 15:18:00	19.9	77.7	0	0	0
10-07-2022 15:33:00	20.5	75.4	0	0	1
10-07-2022 15:48:00	20.8	74.2	0	0	0

ACTIVITY	NAME	SIGNATURE AND DATE
REVIEWED BY USER		
REVIEWED BY QA		



SOMERSET THERAPEUTICS LIMITED

DATA REPORT - SVP1 AND AMPOULE LINE EMS

WASHING AND STERILIZATION AREA

Date Time	Temperature	RH	Diffrential Pressure	Diffrential Pressure	Diffrential Pressure
DD-MM-YYYY HH:MM:SS	Washing and Sterilization Area (NMT 30°C)	Washing and Sterilization Area (NMT 80%)	Washing and Sterilization Area w.r.t Unit Preparation Room (NLT 6 Pa)	Washing and Sterilization Area w.r.t Ampoule Decartoning Room (NLT 12 Pa)	Washing and Sterilization Area w.r.t Injectable main corridor (NLT 12 Pa)
10-07-2022 16:03:00	20.9	74.1	0	0	0
10-07-2022 16:18:00	21	76.1	0	0	0
10-07-2022 16:33:00	20.9	90.5	0	0	0
10-07-2022 16:48:00	21	95.7	0	0	0
10-07-2022 17:03:00	21.6	96.7	0	0	0
10-07-2022 17:18:00	22	96.1	0	0	0
10-07-2022 17:33:00	21.9	94.7	0	0	0
10-07-2022 17:48:00	21.7	94.5	0	0	0
10-07-2022 18:03:00	21.7	94.3	0	0	1
10-07-2022 18:18:00	21.7	94.1	0	0	0
10-07-2022 18:33:00	21.7	94	0	0	0
10-07-2022 18:48:00	20.4	80.4	45	21	44
10-07-2022 19:03:00	19.2	78	46	21	44
10-07-2022 19:18:00	18.5	76.9	45	21	44
10-07-2022 19:33:00	18.1	76.9	45	21	44
10-07-2022 19:48:00	17.9	77.1	38	20	45
10-07-2022 20:03:00	17.8	77.7	48	22	45
10-07-2022 20:18:00	17.7	77	47	20	44
10-07-2022 20:33:00	17.7	78	36	19	32
10-07-2022 20:48:00	17.8	77.3	47	21	45
10-07-2022 21:03:00	17.9	78.6	47	21	44
10-07-2022 21:18:00	17.9	79.3	47	21	45
10-07-2022 21:33:00	18.1	78.7	48	18	44
10-07-2022 21:48:00	18.1	79.6	46	23	45

ACTIVITY	NAME	SIGNATURE AND DATE
REVIEWED BY USER		
REVIEWED BY QA		



SOMERSET THERAPEUTICS LIMITED

DATA REPORT - SVP1 AND AMPOULE LINE EMS

WASHING AND STERILIZATION AREA

Date Time	Temperature	RH	Diffrential Pressure	Diffrential Pressure	Diffrential Pressure
DD-MM-YYYY HH:MM:SS	Washing and Sterilization Area (NMT 30°C)	Washing and Sterilization Area (NMT 80%)	Washing and Sterilization Area w.r.t Unit Preparation Room (NLT 6 Pa)	Washing and Sterilization Area w.r.t Ampoule Decartoning Room (NLT 12 Pa)	Washing and Sterilization Area w.r.t Injectable main corridor (NLT 12 Pa)
10-07-2022 22:03:00	18	79.2	37	20	44
10-07-2022 22:18:00	17.9	77.3	46	21	46
10-07-2022 22:33:00	17.7	77.3	46	21	44
10-07-2022 22:48:00	17.6	76.9	47	20	45
10-07-2022 23:03:00	17.6	76.5	33	20	43
10-07-2022 23:18:00	17.6	76.8	46	18	39
10-07-2022 23:33:00	17.8	77.6	47	20	42
10-07-2022 23:48:00	18	75.6	10	14	36
11-07-2022 00:03:00	17.8	75.9	47	20	41
11-07-2022 00:18:00	17.9	77.7	46	20	38
11-07-2022 00:33:00	17.9	77.9	47	20	41
11-07-2022 00:48:00	17.8	77.2	46	19	41
11-07-2022 01:03:00	17.7	76.4	46	18	37
11-07-2022 01:18:00	17.5	76.3	46	19	38
11-07-2022 01:33:00	17.4	77.5	47	19	40
11-07-2022 01:48:00	17.2	76.8	47	19	42
11-07-2022 02:03:00	17.2	76.8	48	20	42
11-07-2022 02:18:00	17.2	76.8	47	20	40
11-07-2022 02:33:00	17.2	76.8	46	18	37
11-07-2022 02:48:00	17.3	76.7	47	20	41
11-07-2022 03:03:00	17.2	76.7	47	20	41
11-07-2022 03:18:00	17.3	76.8	46	19	39
11-07-2022 03:33:00	17.4	76.5	45	17	38
11-07-2022 03:48:00	17.5	77.5	46	18	38

ACTIVITY	NAME	SIGNATURE AND DATE
REVIEWED BY USER		
REVIEWED BY QA		



SOMERSET THERAPEUTICS LIMITED

DATA REPORT - SVP1 AND AMPOULE LINE EMS

WASHING AND STERILIZATION AREA

Date Time	Temperature	RH	Diffrential Pressure	Diffrential Pressure	Diffrential Pressure
DD-MM-YYYY HH:MM:SS	Washing and Sterilization Area (NMT 30°C)	Washing and Sterilization Area (NMT 80%)	Washing and Sterilization Area w.r.t Unit Preparation Room (NLT 6 Pa)	Washing and Sterilization Area w.r.t Ampoule Decartoning Room (NLT 12 Pa)	Washing and Sterilization Area w.r.t Injectable main corridor (NLT 12 Pa)
11-07-2022 04:03:00	17.9	78.8	47	19	38
11-07-2022 04:18:00	17.9	76.3	46	19	37
11-07-2022 04:33:00	17.8	75.8	46	18	39
11-07-2022 04:48:00	17.6	75.9	46	19	39
11-07-2022 05:03:00	17.5	76.2	46	19	38
11-07-2022 05:18:00	17.5	76.2	47	19	38
11-07-2022 05:33:00	17.4	76.3	46	19	39
11-07-2022 05:48:00	17.3	76.3	47	18	38
11-07-2022 06:03:00	17.6	75.8	47	20	42
11-07-2022 06:18:00	17.6	76	48	18	42
11-07-2022 06:33:00	17.7	78	47	20	41
11-07-2022 06:48:00	17.9	78	55	20	38
11-07-2022 07:03:00	18	77.6	46	19	42
11-07-2022 07:18:00	17.9	78.7	46	20	42
11-07-2022 07:33:00	18	78.9	45	19	42
11-07-2022 07:48:00	17.8	77	46	20	41
11-07-2022 08:03:00	17.6	76.6	37	19	38
11-07-2022 08:18:00	17.7	78.1	46	18	40
11-07-2022 08:33:00	17.6	78.6	37	20	41
11-07-2022 08:48:00	17.6	78.3	46	20	42
11-07-2022 09:03:00	17.7	81.6	46	20	42
11-07-2022 09:18:00	17.7	80.5	46	19	36
11-07-2022 09:33:00	17.7	80	46	19	40
11-07-2022 09:48:00	17.9	79.9	46	19	41

ACTIVITY	NAME	SIGNATURE AND DATE
REVIEWED BY USER		
REVIEWED BY QA		



SOMERSET THERAPEUTICS LIMITED

DATA REPORT - SVP1 AND AMPOULE LINE EMS

WASHING AND STERILIZATION AREA

Date Time	Temperature	RH	Diffrential Pressure	Diffrential Pressure	Diffrential Pressure
DD-MM-YYYY HH:MM:SS	Washing and Sterilization Area (NMT 30°C)	Washing and Sterilization Area (NMT 80%)	Washing and Sterilization Area w.r.t Unit Preparation Room (NLT 6 Pa)	Washing and Sterilization Area w.r.t Ampoule Decartoning Room (NLT 12 Pa)	Washing and Sterilization Area w.r.t Injectable main corridor (NLT 12 Pa)
11-07-2022 10:03:00	17.9	80.8	45	18	38
Min Value	17.2	74.1	0	0	0
Max Value	22	96.7	55	23	48

End Of Report : From 10-07-2022 10:03:51 To 11-07-2022 10:03:51

ACTIVITY	NAME	SIGNATURE AND DATE
REVIEWED BY USER		
REVIEWED BY QA		