



SOMERSET THERAPEUTICS LIMITED

DATA REPORT - SVP1 AND AMPOULE LINE EMS

WASHING AND STERILIZATION AREA

Date Time	Temperature	RH	Diffrential Pressure	Diffrential Pressure	Diffrential Pressure
DD-MM-YYYY HH:MM:SS	Washing and Sterilization Area (NMT 30°C)	Washing and Sterilization Area (NMT 80%)	Washing and Sterilization Area w.r.t Unit Preparation Room (NLT 6 Pa)	Washing and Sterilization Area w.r.t Ampoule Decartoning Room (NLT 12 Pa)	Washing and Sterilization Area w.r.t Injectable main corridor (NLT 12 Pa)
25-05-2022 18:45:00	17.8	76.4	21	16	37
25-05-2022 18:46:00	17.8	76.4	22	16	37
25-05-2022 18:47:00	17.8	76.4	21	16	37
25-05-2022 18:48:00	17.8	76.4	22	16	37
25-05-2022 18:49:00	17.8	76.3	21	16	37
25-05-2022 18:50:00	17.8	76.3	22	16	36
25-05-2022 18:51:00	17.8	76.2	22	16	38
25-05-2022 18:52:00	17.8	76.3	22	16	37
25-05-2022 18:53:00	17.8	76.2	22	16	37
25-05-2022 18:54:00	17.8	76.2	22	16	36
25-05-2022 18:55:00	17.8	76.3	21	16	37
25-05-2022 18:56:00	17.8	76.3	21	14	32
25-05-2022 18:57:00	17.8	76.3	21	16	37
25-05-2022 18:58:00	17.8	76.4	22	16	37
25-05-2022 18:59:00	17.8	76.4	22	15	36
25-05-2022 19:00:00	17.8	76.4	22	16	38
25-05-2022 19:01:00	17.8	76.3	22	16	38
25-05-2022 19:02:00	17.8	76.3	22	15	34
25-05-2022 19:03:00	17.8	76.4	22	15	34
25-05-2022 19:04:00	17.8	76.4	22	16	37
25-05-2022 19:05:00	17.8	76.4	22	16	38
25-05-2022 19:06:00	17.8	76.4	21	16	37
25-05-2022 19:07:00	17.8	76.4	21	16	37
25-05-2022 19:08:00	17.8	76.4	22	16	37

ACTIVITY	NAME	SIGNATURE AND DATE
REVIEWED BY USER		
REVIEWED BY QA		



SOMERSET THERAPEUTICS LIMITED

DATA REPORT - SVP1 AND AMPOULE LINE EMS

WASHING AND STERILIZATION AREA

Date Time	Temperature	RH	Diffrential Pressure	Diffrential Pressure	Diffrential Pressure
DD-MM-YYYY HH:MM:SS	Washing and Sterilization Area (NMT 30°C)	Washing and Sterilization Area (NMT 80%)	Washing and Sterilization Area w.r.t Unit Preparation Room (NLT 6 Pa)	Washing and Sterilization Area w.r.t Ampoule Decartoning Room (NLT 12 Pa)	Washing and Sterilization Area w.r.t Injectable main corridor (NLT 12 Pa)
25-05-2022 19:09:00	17.8	76.4	22	16	38
25-05-2022 19:10:00	17.8	76.4	22	16	37
25-05-2022 19:11:00	17.8	76.4	22	16	37
25-05-2022 19:12:00	17.8	76.5	22	16	37
25-05-2022 19:13:00	17.8	76.5	21	15	33
25-05-2022 19:14:00	17.8	76.6	22	16	37
25-05-2022 19:15:00	17.8	76.5	21	13	30
25-05-2022 19:16:00	17.8	76.5	21	16	37
25-05-2022 19:17:00	17.8	76.5	21	16	37
25-05-2022 19:18:00	17.8	76.6	22	16	36
25-05-2022 19:19:00	17.8	76.5	21	16	37
25-05-2022 19:20:00	17.8	76.5	22	16	37
25-05-2022 19:21:00	17.8	76.5	22	16	38
25-05-2022 19:22:00	17.8	76.6	22	16	37
25-05-2022 19:23:00	17.8	76.6	22	16	36
25-05-2022 19:24:00	17.9	76.6	21	16	37
25-05-2022 19:25:00	17.9	76.6	21	16	37
25-05-2022 19:26:00	17.9	76.5	21	16	38
25-05-2022 19:27:00	17.9	76.6	21	16	36
25-05-2022 19:28:00	17.9	76.6	21	16	37
25-05-2022 19:29:00	17.9	76.6	22	16	37
25-05-2022 19:30:00	17.9	76.6	21	16	37
25-05-2022 19:31:00	17.9	76.5	21	16	37
25-05-2022 19:32:00	17.9	76.5	21	16	37

ACTIVITY	NAME	SIGNATURE AND DATE
REVIEWED BY USER		
REVIEWED BY QA		



SOMERSET THERAPEUTICS LIMITED

DATA REPORT - SVP1 AND AMPOULE LINE EMS

WASHING AND STERILIZATION AREA

Date Time	Temperature	RH	Diffrential Pressure	Diffrential Pressure	Diffrential Pressure
DD-MM-YYYY HH:MM:SS	Washing and Sterilization Area (NMT 30°C)	Washing and Sterilization Area (NMT 80%)	Washing and Sterilization Area w.r.t Unit Preparation Room (NLT 6 Pa)	Washing and Sterilization Area w.r.t Ampoule Decartoning Room (NLT 12 Pa)	Washing and Sterilization Area w.r.t Injectable main corridor (NLT 12 Pa)
25-05-2022 19:33:00	17.9	76.4	21	16	36
25-05-2022 19:34:00	17.9	76.4	21	16	37
25-05-2022 19:35:00	17.8	76.4	21	15	35
25-05-2022 19:36:00	17.9	76.4	21	15	36
25-05-2022 19:37:00	17.8	76.4	21	16	36
25-05-2022 19:38:00	17.8	76.4	21	16	37
25-05-2022 19:39:00	17.8	76.5	21	14	34
25-05-2022 19:40:00	17.8	76.5	21	16	36
25-05-2022 19:41:00	17.8	76.3	22	16	38
25-05-2022 19:42:00	17.8	76.3	22	16	38
25-05-2022 19:43:00	17.8	76.3	20	15	36
25-05-2022 19:44:00	17.8	76.4	21	16	40
25-05-2022 19:45:00	17.8	76.5	20	16	38
25-05-2022 19:46:00	17.8	76.7	21	16	38
25-05-2022 19:47:00	17.9	76.8	19	15	35
25-05-2022 19:48:00	17.8	77	16	16	37
25-05-2022 19:49:00	17.8	77.1	19	15	37
25-05-2022 19:50:00	17.8	77.1	19	13	30
25-05-2022 19:51:00	17.8	77.2	20	16	37
25-05-2022 19:52:00	17.8	77.3	19	14	34
25-05-2022 19:53:00	17.8	77.3	21	14	35
25-05-2022 19:54:00	17.9	77.4	15	16	37
25-05-2022 19:55:00	17.9	77.5	19	16	39
25-05-2022 19:56:00	17.9	78.5	19	16	37

ACTIVITY	NAME	SIGNATURE AND DATE
REVIEWED BY USER		
REVIEWED BY QA		



SOMERSET THERAPEUTICS LIMITED

DATA REPORT - SVP1 AND AMPOULE LINE EMS

WASHING AND STERILIZATION AREA

Date Time	Temperature	RH	Diffrential Pressure	Diffrential Pressure	Diffrential Pressure
DD-MM-YYYY HH:MM:SS	Washing and Sterilization Area (NMT 30°C)	Washing and Sterilization Area (NMT 80%)	Washing and Sterilization Area w.r.t Unit Preparation Room (NLT 6 Pa)	Washing and Sterilization Area w.r.t Ampoule Decartoning Room (NLT 12 Pa)	Washing and Sterilization Area w.r.t Injectable main corridor (NLT 12 Pa)
25-05-2022 19:57:00	17.9	79.9	19	17	38
25-05-2022 19:58:00	18	81	20	14	34
25-05-2022 19:59:00	18.1	81.5	19	16	39
25-05-2022 20:00:00	18.1	82.2	19	16	38
25-05-2022 20:01:00	18.2	82.1	19	16	39
25-05-2022 20:02:00	18.2	81.9	19	17	40
25-05-2022 20:03:00	18.3	81.4	19	17	40
25-05-2022 20:04:00	18.3	81	18	17	39
25-05-2022 20:05:00	18.3	80.6	18	16	38
25-05-2022 20:06:00	18.4	80.1	20	16	38
25-05-2022 20:07:00	18.4	79.8	20	16	38
25-05-2022 20:08:00	18.4	79.5	20	15	35
25-05-2022 20:09:00	18.4	79.2	18	16	38
25-05-2022 20:10:00	18.4	78.9	19	16	37
25-05-2022 20:11:00	18.4	78.7	19	17	37
25-05-2022 20:12:00	18.3	78.5	19	16	38
25-05-2022 20:13:00	18.3	78.4	19	16	38
25-05-2022 20:14:00	18.3	78.2	19	16	38
25-05-2022 20:15:00	18.3	78.1	19	16	38
25-05-2022 20:16:00	18.3	78	19	16	37
25-05-2022 20:17:00	18.3	77.9	19	15	36
25-05-2022 20:18:00	18.3	77.8	20	16	37
25-05-2022 20:19:00	18.3	77.8	19	16	38
25-05-2022 20:20:00	18.3	77.7	18	16	38

ACTIVITY	NAME	SIGNATURE AND DATE
REVIEWED BY USER		
REVIEWED BY QA		



SOMERSET THERAPEUTICS LIMITED

DATA REPORT - SVP1 AND AMPOULE LINE EMS

WASHING AND STERILIZATION AREA

Date Time	Temperature	RH	Diffrential Pressure	Diffrential Pressure	Diffrential Pressure
DD-MM-YYYY HH:MM:SS	Washing and Sterilization Area (NMT 30°C)	Washing and Sterilization Area (NMT 80%)	Washing and Sterilization Area w.r.t Unit Preparation Room (NLT 6 Pa)	Washing and Sterilization Area w.r.t Ampoule Decartoning Room (NLT 12 Pa)	Washing and Sterilization Area w.r.t Injectable main corridor (NLT 12 Pa)
25-05-2022 20:21:00	18.2	77.7	18	16	38
25-05-2022 20:22:00	18.3	77.5	20	16	37
25-05-2022 20:23:00	18.2	77.5	19	16	38
25-05-2022 20:24:00	18.2	77.4	19	16	38
25-05-2022 20:25:00	18.2	77.5	20	16	38
25-05-2022 20:26:00	18.2	77.5	19	16	38
25-05-2022 20:27:00	18.2	77.6	20	16	38
25-05-2022 20:28:00	18.2	77.6	21	16	37
25-05-2022 20:29:00	18.2	77.7	20	16	39
25-05-2022 20:30:00	18.1	77.6	20	16	38
25-05-2022 20:31:00	18.1	77.6	19	16	38
25-05-2022 20:32:00	18.2	77.6	20	16	37
25-05-2022 20:33:00	18.2	77.5	19	15	36
25-05-2022 20:34:00	18.2	77.4	20	16	37
25-05-2022 20:35:00	18.2	77.3	19	16	37
25-05-2022 20:36:00	18.2	77.3	19	15	38
25-05-2022 20:37:00	18.1	77.3	19	16	38
25-05-2022 20:38:00	18.1	77.3	19	15	38
25-05-2022 20:39:00	18.1	77.4	19	16	37
25-05-2022 20:40:00	18.1	77.3	20	16	38
25-05-2022 20:41:00	18.1	77.3	19	16	37
25-05-2022 20:42:00	18.1	77.3	19	16	38
25-05-2022 20:43:00	18.1	77.3	19	15	36
25-05-2022 20:44:00	18.1	77.3	20	15	37

ACTIVITY	NAME	SIGNATURE AND DATE
REVIEWED BY USER		
REVIEWED BY QA		



SOMERSET THERAPEUTICS LIMITED

DATA REPORT - SVP1 AND AMPOULE LINE EMS

WASHING AND STERILIZATION AREA

Date Time	Temperature	RH	Diffrential Pressure	Diffrential Pressure	Diffrential Pressure
DD-MM-YYYY HH:MM:SS	Washing and Sterilization Area (NMT 30°C)	Washing and Sterilization Area (NMT 80%)	Washing and Sterilization Area w.r.t Unit Preparation Room (NLT 6 Pa)	Washing and Sterilization Area w.r.t Ampoule Decartoning Room (NLT 12 Pa)	Washing and Sterilization Area w.r.t Injectable main corridor (NLT 12 Pa)
25-05-2022 20:45:00	18.1	77.3	20	16	36
25-05-2022 20:46:00	18.1	77.4	19	16	37
25-05-2022 20:47:00	18.1	77.3	20	16	37
25-05-2022 20:48:00	18.1	77.4	19	16	37
25-05-2022 20:49:00	18.1	77.3	20	16	38
25-05-2022 20:50:00	18.1	77.3	19	16	38
25-05-2022 20:51:00	18.1	77.3	19	16	38
25-05-2022 20:52:00	18.1	77.4	15	15	37
25-05-2022 20:53:00	18.1	77.4	7	14	36
25-05-2022 20:54:00	18.1	77.5	0	14	35
25-05-2022 20:55:00	18.1	77.4	0	13	35
25-05-2022 20:56:00	18.1	77.4	0	13	34
25-05-2022 20:57:00	18.1	77.3	0	13	35
25-05-2022 20:58:00	18.1	77.2	0	13	34
25-05-2022 20:59:00	18.1	77.1	0	13	35
25-05-2022 21:00:00	18.1	77.1	17	15	36
25-05-2022 21:01:00	18.1	77.1	19	14	35
25-05-2022 21:02:00	18.1	77.1	18	15	36
25-05-2022 21:03:00	18.1	77	19	16	38
25-05-2022 21:04:00	18.1	76.9	20	16	38
25-05-2022 21:05:00	18.1	76.9	19	16	40
25-05-2022 21:06:00	18.1	76.9	19	17	41
25-05-2022 21:07:00	18.2	76.6	20	17	40
25-05-2022 21:08:00	18.2	76.3	20	17	40

ACTIVITY	NAME	SIGNATURE AND DATE
REVIEWED BY USER		
REVIEWED BY QA		



SOMERSET THERAPEUTICS LIMITED

DATA REPORT - SVP1 AND AMPOULE LINE EMS

WASHING AND STERILIZATION AREA

Date Time	Temperature	RH	Diffrential Pressure	Diffrential Pressure	Diffrential Pressure
DD-MM-YYYY HH:MM:SS	Washing and Sterilization Area (NMT 30°C)	Washing and Sterilization Area (NMT 80%)	Washing and Sterilization Area w.r.t Unit Preparation Room (NLT 6 Pa)	Washing and Sterilization Area w.r.t Ampoule Decartoning Room (NLT 12 Pa)	Washing and Sterilization Area w.r.t Injectable main corridor (NLT 12 Pa)
25-05-2022 21:09:00	18.3	76.1	19	16	40
25-05-2022 21:10:00	18.4	76	19	16	38
25-05-2022 21:11:00	18.5	75.9	19	17	37
25-05-2022 21:12:00	18.5	76	19	17	40
25-05-2022 21:13:00	18.5	76	20	16	39
25-05-2022 21:14:00	18.5	76	19	16	40
25-05-2022 21:15:00	18.4	76.1	20	16	39
25-05-2022 21:16:00	18.3	76.3	20	16	39
25-05-2022 21:17:00	18.3	76.5	19	15	38
25-05-2022 21:18:00	18.3	76.6	19	18	39
25-05-2022 21:19:00	18.3	76.7	0	15	38
25-05-2022 21:20:00	18.3	77.5	0	15	38
25-05-2022 21:21:00	18.3	78.2	0	15	37
25-05-2022 21:22:00	18.3	78.2	0	15	37
25-05-2022 21:23:00	18.3	78	0	14	37
25-05-2022 21:24:00	18.3	77.8	0	15	37
25-05-2022 21:25:00	18.3	77.6	0	15	37
25-05-2022 21:26:00	18.3	77.4	0	15	37
25-05-2022 21:27:00	18.3	77.3	0	15	38
25-05-2022 21:28:00	18.3	77.3	0	15	39
25-05-2022 21:29:00	18.3	77.2	0	15	38
25-05-2022 21:30:00	18.3	77.1	0	14	37
25-05-2022 21:31:00	18.3	77.1	0	14	37
25-05-2022 21:32:00	18.3	77	0	14	37

ACTIVITY	NAME	SIGNATURE AND DATE
REVIEWED BY USER		
REVIEWED BY QA		



SOMERSET THERAPEUTICS LIMITED

DATA REPORT - SVP1 AND AMPOULE LINE EMS

WASHING AND STERILIZATION AREA

Date Time	Temperature	RH	Diffrential Pressure	Diffrential Pressure	Diffrential Pressure
DD-MM-YYYY HH:MM:SS	Washing and Sterilization Area (NMT 30°C)	Washing and Sterilization Area (NMT 80%)	Washing and Sterilization Area w.r.t Unit Preparation Room (NLT 6 Pa)	Washing and Sterilization Area w.r.t Ampoule Decartoning Room (NLT 12 Pa)	Washing and Sterilization Area w.r.t Injectable main corridor (NLT 12 Pa)
25-05-2022 21:33:00	18.3	77	0	15	37
25-05-2022 21:34:00	18.3	76.9	0	15	38
25-05-2022 21:35:00	18.3	76.8	0	15	38
25-05-2022 21:36:00	18.3	76.8	0	15	37
25-05-2022 21:37:00	18.3	76.8	0	15	37
25-05-2022 21:38:00	18.3	76.7	0	15	37
25-05-2022 21:39:00	18.3	76.5	7	15	38
25-05-2022 21:40:00	18.3	76.4	18	15	39
25-05-2022 21:41:00	18.3	76.4	18	15	39
25-05-2022 21:42:00	18.3	76.4	19	15	39
25-05-2022 21:43:00	18.3	76.4	17	16	39
25-05-2022 21:44:00	18.2	76.4	18	16	38
25-05-2022 21:45:00	18.2	76.4	18	15	38
25-05-2022 21:46:00	18.3	76.4	19	16	37
25-05-2022 21:47:00	18.3	76.3	19	16	39
25-05-2022 21:48:00	18.2	76.4	19	16	39
25-05-2022 21:49:00	18.2	76.4	18	16	40
25-05-2022 21:50:00	18.2	76.3	19	14	37
25-05-2022 21:51:00	18.2	76.3	18	16	39
25-05-2022 21:52:00	18.3	76.4	19	17	40
25-05-2022 21:53:00	18.3	76.3	19	16	40
25-05-2022 21:54:00	18.3	76.3	18	16	40
25-05-2022 21:55:00	18.3	76.3	19	16	39
25-05-2022 21:56:00	18.3	76.3	19	16	38

ACTIVITY	NAME	SIGNATURE AND DATE
REVIEWED BY USER		
REVIEWED BY QA		



SOMERSET THERAPEUTICS LIMITED

DATA REPORT - SVP1 AND AMPOULE LINE EMS

WASHING AND STERILIZATION AREA

Date Time	Temperature	RH	Diffrential Pressure	Diffrential Pressure	Diffrential Pressure
DD-MM-YYYY HH:MM:SS	Washing and Sterilization Area (NMT 30°C)	Washing and Sterilization Area (NMT 80%)	Washing and Sterilization Area w.r.t Unit Preparation Room (NLT 6 Pa)	Washing and Sterilization Area w.r.t Ampoule Decartoning Room (NLT 12 Pa)	Washing and Sterilization Area w.r.t Injectable main corridor (NLT 12 Pa)
25-05-2022 21:57:00	18.3	76.3	19	16	39
25-05-2022 21:58:00	18.3	76.3	19	16	39
25-05-2022 21:59:00	18.3	76.2	19	17	39
25-05-2022 22:00:00	18.3	76.2	19	16	39
25-05-2022 22:01:00	18.3	76.3	19	16	39
25-05-2022 22:02:00	18.4	76.2	20	16	39
25-05-2022 22:03:00	18.4	76.2	19	16	37
25-05-2022 22:04:00	18.4	76.2	19	16	39
25-05-2022 22:05:00	18.4	76.1	18	16	39
25-05-2022 22:06:00	18.4	76.1	18	16	40
25-05-2022 22:07:00	18.4	76.1	19	16	37
25-05-2022 22:08:00	18.4	76.1	19	15	36
25-05-2022 22:09:00	18.4	76	19	16	39
25-05-2022 22:10:00	18.4	76	19	15	38
25-05-2022 22:11:00	18.4	76	19	16	39
25-05-2022 22:12:00	18.4	76	19	16	38
25-05-2022 22:13:00	18.4	75.9	19	16	38
25-05-2022 22:14:00	18.4	75.9	19	16	40
25-05-2022 22:15:00	18.4	75.9	20	16	39
25-05-2022 22:16:00	18.4	76	19	15	38
25-05-2022 22:17:00	18.4	76	20	16	39
25-05-2022 22:18:00	18.4	76	18	16	39
25-05-2022 22:19:00	18.4	75.9	19	14	35
25-05-2022 22:20:00	18.4	75.9	18	14	30

ACTIVITY	NAME	SIGNATURE AND DATE
REVIEWED BY USER		
REVIEWED BY QA		



SOMERSET THERAPEUTICS LIMITED

DATA REPORT - SVP1 AND AMPOULE LINE EMS

WASHING AND STERILIZATION AREA

Date Time	Temperature	RH	Diffrential Pressure	Diffrential Pressure	Diffrential Pressure
DD-MM-YYYY HH:MM:SS	Washing and Sterilization Area (NMT 30°C)	Washing and Sterilization Area (NMT 80%)	Washing and Sterilization Area w.r.t Unit Preparation Room (NLT 6 Pa)	Washing and Sterilization Area w.r.t Ampoule Decartoning Room (NLT 12 Pa)	Washing and Sterilization Area w.r.t Injectable main corridor (NLT 12 Pa)
25-05-2022 22:21:00	18.4	75.9	19	16	38
25-05-2022 22:22:00	18.4	75.8	18	16	39
25-05-2022 22:23:00	18.4	75.8	18	16	37
25-05-2022 22:24:00	18.4	75.8	19	15	38
25-05-2022 22:25:00	18.4	75.7	19	14	35
25-05-2022 22:26:00	18.4	75.8	19	16	39
25-05-2022 22:27:00	18.5	75.8	19	16	39
25-05-2022 22:28:00	18.5	75.7	18	16	39
25-05-2022 22:29:00	18.5	75.6	18	15	41
25-05-2022 22:30:00	18.5	75.7	18	16	39
25-05-2022 22:31:00	18.5	75.7	20	15	38
25-05-2022 22:32:00	18.5	75.9	18	16	39
25-05-2022 22:33:00	18.4	75.9	20	16	39
25-05-2022 22:34:00	18.4	75.9	19	16	38
25-05-2022 22:35:00	18.4	75.8	18	15	37
25-05-2022 22:36:00	18.4	75.8	19	16	39
25-05-2022 22:37:00	18.4	75.8	19	16	38
25-05-2022 22:38:00	18.4	75.8	19	16	39
25-05-2022 22:39:00	18.4	75.8	14	16	38
25-05-2022 22:40:00	18.4	75.8	20	16	40
25-05-2022 22:41:00	18.4	75.9	19	16	38
25-05-2022 22:42:00	18.4	76	19	18	41
25-05-2022 22:43:00	18.3	76.2	20	18	41
25-05-2022 22:44:00	18.3	76.4	19	17	39

ACTIVITY	NAME	SIGNATURE AND DATE
REVIEWED BY USER		
REVIEWED BY QA		



SOMERSET THERAPEUTICS LIMITED

DATA REPORT - SVP1 AND AMPOULE LINE EMS

WASHING AND STERILIZATION AREA

Date Time	Temperature	RH	Diffrential Pressure	Diffrential Pressure	Diffrential Pressure
DD-MM-YYYY HH:MM:SS	Washing and Sterilization Area (NMT 30°C)	Washing and Sterilization Area (NMT 80%)	Washing and Sterilization Area w.r.t Unit Preparation Room (NLT 6 Pa)	Washing and Sterilization Area w.r.t Ampoule Decartoning Room (NLT 12 Pa)	Washing and Sterilization Area w.r.t Injectable main corridor (NLT 12 Pa)
25-05-2022 22:45:00	18.3	76.5	20	16	38
Min Value	17.8	75.6	0	13	30
Max Value	18.5	82.2	22	18	41

End Of Report : From 25-05-2022 18:45:31 To 25-05-2022 22:45:31

ACTIVITY	NAME	SIGNATURE AND DATE
REVIEWED BY USER		
REVIEWED BY QA		