



SOMERSET THERAPEUTICS LIMITED

DATA REPORT - SVP1 AND AMPOULE LINE EMS

WASHING AND STERILIZATION AREA

Date Time	Temperature	RH	Diffrential Pressure	Diffrential Pressure	Diffrential Pressure
DD-MM-YYYY HH:MM:SS	Washing and Sterilization Area (NMT 30°C)	Washing and Sterilization Area (NMT 80%)	Washing and Sterilization Area w.r.t Unit Preparation Room (NLT 6 Pa)	Washing and Sterilization Area w.r.t Ampoule Decartoning Room (NLT 12 Pa)	Washing and Sterilization Area w.r.t Injectable main corridor (NLT 12 Pa)
15-05-2022 13:06:00	17.1	76.4	0	12	34
15-05-2022 13:07:00	17.1	76.4	0	12	33
15-05-2022 13:08:00	17.1	76.4	0	12	33
15-05-2022 13:09:00	17.1	76.5	0	12	33
15-05-2022 13:10:00	17.1	76.5	0	12	33
15-05-2022 13:11:00	17.1	76.5	0	13	33
15-05-2022 13:12:00	17	76.6	0	12	33
15-05-2022 13:13:00	17	76.6	0	12	33
15-05-2022 13:14:00	17	76.6	0	12	33
15-05-2022 13:15:00	17	76.6	0	13	33
15-05-2022 13:16:00	17	76.6	0	12	33
15-05-2022 13:17:00	17	76.7	0	12	33
15-05-2022 13:18:00	17	76.7	0	12	33
15-05-2022 13:19:00	17	76.7	0	13	33
15-05-2022 13:20:00	17	76.6	0	13	34
15-05-2022 13:21:00	17	76.6	0	12	33
15-05-2022 13:22:00	17	76.6	0	12	33
15-05-2022 13:23:00	17	76.6	0	12	33
15-05-2022 13:24:00	17	76.6	0	12	33
15-05-2022 13:25:00	17	76.6	0	13	34
15-05-2022 13:26:00	17	76.6	0	12	33
15-05-2022 13:27:00	17	76.6	0	12	33
15-05-2022 13:28:00	17	76.6	0	12	33
15-05-2022 13:29:00	17	76.7	0	12	33

ACTIVITY	NAME	SIGNATURE AND DATE
REVIEWED BY USER		
REVIEWED BY QA		



SOMERSET THERAPEUTICS LIMITED

DATA REPORT - SVP1 AND AMPOULE LINE EMS

WASHING AND STERILIZATION AREA

Date Time	Temperature	RH	Diffrential Pressure	Diffrential Pressure	Diffrential Pressure
DD-MM-YYYY HH:MM:SS	Washing and Sterilization Area (NMT 30°C)	Washing and Sterilization Area (NMT 80%)	Washing and Sterilization Area w.r.t Unit Preparation Room (NLT 6 Pa)	Washing and Sterilization Area w.r.t Ampoule Decartoning Room (NLT 12 Pa)	Washing and Sterilization Area w.r.t Injectable main corridor (NLT 12 Pa)
15-05-2022 13:30:00	17	76.7	0	12	34
15-05-2022 13:31:00	17	76.6	0	12	33
15-05-2022 13:32:00	17	76.6	0	12	33
15-05-2022 13:33:00	17	76.7	0	12	33
15-05-2022 13:34:00	17	76.7	0	12	33
15-05-2022 13:35:00	16.9	76.7	0	12	33
15-05-2022 13:36:00	16.9	76.7	0	12	33
15-05-2022 13:37:00	16.9	76.7	0	12	33
15-05-2022 13:38:00	16.9	76.8	0	12	33
15-05-2022 13:39:00	16.9	76.7	0	12	34
15-05-2022 13:40:00	16.9	76.7	0	12	33
15-05-2022 13:41:00	16.9	76.7	0	12	33
15-05-2022 13:42:00	16.9	76.7	0	13	33
15-05-2022 13:43:00	16.9	76.7	0	12	33
15-05-2022 13:44:00	16.9	76.6	0	13	33
15-05-2022 13:45:00	16.9	76.6	0	12	33
15-05-2022 13:46:00	16.9	76.6	0	12	34
15-05-2022 13:47:00	16.9	76.6	0	13	33
15-05-2022 13:48:00	16.9	76.8	0	12	32
15-05-2022 13:49:00	16.9	76.8	0	12	33
15-05-2022 13:50:00	16.9	76.8	0	12	34
15-05-2022 13:51:00	16.9	76.7	0	12	33
15-05-2022 13:52:00	16.9	76.7	0	12	33
15-05-2022 13:53:00	16.9	76.7	0	13	34

ACTIVITY	NAME	SIGNATURE AND DATE
REVIEWED BY USER		
REVIEWED BY QA		



SOMERSET THERAPEUTICS LIMITED

DATA REPORT - SVP1 AND AMPOULE LINE EMS

WASHING AND STERILIZATION AREA

Date Time	Temperature	RH	Diffrential Pressure	Diffrential Pressure	Diffrential Pressure
DD-MM-YYYY HH:MM:SS	Washing and Sterilization Area (NMT 30°C)	Washing and Sterilization Area (NMT 80%)	Washing and Sterilization Area w.r.t Unit Preparation Room (NLT 6 Pa)	Washing and Sterilization Area w.r.t Ampoule Decartoning Room (NLT 12 Pa)	Washing and Sterilization Area w.r.t Injectable main corridor (NLT 12 Pa)
15-05-2022 13:54:00	16.9	76.7	0	12	33
15-05-2022 13:55:00	16.9	76.7	0	12	33
15-05-2022 13:56:00	16.9	76.6	0	12	33
15-05-2022 13:57:00	16.9	76.7	0	12	33
15-05-2022 13:58:00	16.9	76.7	0	12	33
15-05-2022 13:59:00	16.9	76.8	0	12	33
15-05-2022 14:00:00	16.9	76.8	0	12	33
15-05-2022 14:01:00	16.9	76.8	0	12	33
15-05-2022 14:02:00	16.9	76.9	0	13	34
15-05-2022 14:03:00	16.9	76.9	0	12	33
15-05-2022 14:04:00	16.9	77	0	13	33
15-05-2022 14:05:00	16.9	77	0	13	33
15-05-2022 14:06:00	16.9	77	0	12	33
Min Value	16.9	76.4	0	12	32
Max Value	17.1	77	0	13	34

End Of Report : From 15-05-2022 13:06:29 To 15-05-2022 14:06:29

ACTIVITY	NAME	SIGNATURE AND DATE
REVIEWED BY USER		
REVIEWED BY QA		