



SOMERSET THERAPEUTICS LIMITED

DATA REPORT - SVP1 AND AMPOULE LINE EMS

STERILE CORRIDOR

Date Time	Temperature	RH	Temperature	RH	Temperature	RH	Temperature	RH	Differential Pressure	Differential Pressure	Differential Pressure	Differential Pressure
DD-MM-YYYY HH:MM:SS	Injectable sterile corridor (217) (NMT 25°C)	Injectable sterile corridor (217) (NMT 65%)	Ampoule 4 head manual filling (222) (NMT 25°C)	Ampoule 4 head manual filling (222) (NMT 65%)	SVP filtration 02 (223) (NMT 25°C)	SVP filtration 02 (223) (NMT 65%)	SVP filtration 01 (221) (NMT 25°C)	SVP filtration 01 (221) (NMT 65%)	SVP filtration 02 w.r.t Sterile Corridor (NLT 6 Pa)	Ampoule 4 Head Manual Filling w.r.t Sterile Corridor (NLT 6 Pa)	SVP Filtration-01 w.r.t Sterile corridor (NLT 6 Pa)	Sterile Corridor w.r.t Change Room-03 (NLT 6 Pa)
10-07-2022 11:23:00	21.5	67.1	22.4	60.8	22.7	59.3	18.5	62.6	81	94	43	29
10-07-2022 11:24:00	21.5	67.3	22.4	60.7	22.7	59.3	18.5	62.8	78	95	33	29
10-07-2022 11:25:00	21.5	67.1	22.4	60.7	22.7	59.2	18.5	62.7	79	91	40	29
10-07-2022 11:26:00	21.5	66.8	22.4	60.8	22.7	59.2	18.5	62.7	79	94	42	30
10-07-2022 11:27:00	21.5	67.2	22.4	60.7	22.7	59.2	18.5	62.6	80	94	40	29
10-07-2022 11:28:00	21.5	67.4	22.4	60.8	22.7	59.2	18.5	62.6	81	97	41	29
10-07-2022 11:29:00	21.5	66.8	22.4	60.8	22.7	59.2	18.5	62.6	84	95	41	30
10-07-2022 11:30:00	21.5	66.9	22.4	60.8	22.7	59.2	18.5	62.6	76	93	39	30
10-07-2022 11:31:00	21.4	67.2	22.4	60.7	22.7	59.2	18.5	62.4	79	95	41	29
10-07-2022 11:32:00	21.4	67.1	22.4	60.7	22.7	59.1	18.4	62.4	80	91	42	29
10-07-2022 11:33:00	21.5	66.9	22.4	60.7	22.7	59.1	18.4	62.4	83	94	40	29
10-07-2022 11:34:00	21.4	67.3	22.4	60.7	22.7	59.1	18.5	62.4	82	91	41	28
10-07-2022 11:35:00	21.4	67.1	22.4	60.7	22.7	59.1	18.4	62.4	83	94	40	31

ACTIVITY	NAME	SIGNATURE AND DATE
REVIEWED BY USER		
REVIEWED BY QA		



SOMERSET THERAPEUTICS LIMITED

DATA REPORT - SVP1 AND AMPOULE LINE EMS

STERILE CORRIDOR

Date Time	Temperature	RH	Temperature	RH	Temperature	RH	Temperature	RH	Differential Pressure	Differential Pressure	Differential Pressure	Differential Pressure
DD-MM-YYYY HH:MM:SS	Injectable sterile corridor (217) (NMT 25°C)	Injectable sterile corridor (217) (NMT 65%)	Ampoule 4 head manual filling (222) (NMT 25°C)	Ampoule 4 head manual filling (222) (NMT 65%)	SVP filtration 02 (223) (NMT 25°C)	SVP filtration 02 (223) (NMT 65%)	SVP filtration 01 (221) (NMT 25°C)	SVP filtration 01 (221) (NMT 65%)	SVP filtration 02 w.r.t Sterile Corridor (NLT 6 Pa)	Ampoule 4 Head Manual Filling w.r.t Sterile Corridor (NLT 6 Pa)	SVP Filtration-01 w.r.t Sterile corridor (NLT 6 Pa)	Sterile Corridor w.r.t Change Room-03 (NLT 6 Pa)
10-07-2022 11:36:00	21.4	66.8	22.4	60.7	22.7	59.1	18.5	62.3	82	92	41	29
10-07-2022 11:37:00	21.4	67.3	22.4	60.7	22.7	59.1	18.5	62.2	80	93	41	30
10-07-2022 11:38:00	21.4	67.1	22.4	60.7	22.7	59.1	18.5	62.1	84	93	41	29
10-07-2022 11:39:00	21.4	66.8	22.4	60.7	22.7	59.1	18.6	62	79	96	41	28
10-07-2022 11:40:00	21.5	68.2	22.4	60.6	22.7	59.1	18.6	61.9	83	100	43	23
10-07-2022 11:41:00	21.5	67.4	22.4	60.6	22.7	59.1	18.6	61.8	82	97	40	29
10-07-2022 11:42:00	21.5	66.8	22.4	60.6	22.7	59	18.6	61.8	82	93	41	29
10-07-2022 11:43:00	21.5	66.9	22.4	60.5	22.7	59	18.6	61.8	85	100	43	31
10-07-2022 11:44:00	21.5	67	22.4	60.6	22.7	58.9	18.6	61.8	79	95	41	28
10-07-2022 11:45:00	21.5	66.6	22.4	60.5	22.7	59	18.6	61.8	82	94	41	29
10-07-2022 11:46:00	21.5	66.7	22.4	60.5	22.7	58.9	18.6	61.8	82	93	41	29
10-07-2022 11:47:00	21.5	66.9	22.4	60.6	22.7	58.9	18.6	61.7	82	94	41	27
10-07-2022 11:48:00	21.4	66.6	22.4	60.6	22.7	59	18.6	61.7	80	93	41	28

ACTIVITY	NAME	SIGNATURE AND DATE
REVIEWED BY USER		
REVIEWED BY QA		



SOMERSET THERAPEUTICS LIMITED

DATA REPORT - SVP1 AND AMPOULE LINE EMS

STERILE CORRIDOR

Date Time	Temperature	RH	Temperature	RH	Temperature	RH	Temperature	RH	Differential Pressure	Differential Pressure	Differential Pressure	Differential Pressure
DD-MM-YYYY HH:MM:SS	Injectable sterile corridor (217) (NMT 25°C)	Injectable sterile corridor (217) (NMT 65%)	Ampoule 4 head manual filling (222) (NMT 25°C)	Ampoule 4 head manual filling (222) (NMT 65%)	SVP filtration 02 (223) (NMT 25°C)	SVP filtration 02 (223) (NMT 65%)	SVP filtration 01 (221) (NMT 25°C)	SVP filtration 01 (221) (NMT 65%)	SVP filtration 02 w.r.t Sterile Corridor (NLT 6 Pa)	Ampoule 4 Head Manual Filling w.r.t Sterile Corridor (NLT 6 Pa)	SVP Filtration-01 w.r.t Sterile corridor (NLT 6 Pa)	Sterile Corridor w.r.t Change Room-03 (NLT 6 Pa)
10-07-2022 11:49:00	21.4	66.5	22.4	60.6	22.7	59	18.6	61.8	81	97	39	30
10-07-2022 11:50:00	21.4	66.8	22.3	60.7	22.7	59	18.6	61.9	80	94	40	28
10-07-2022 11:51:00	21.4	66.8	22.4	60.7	22.7	59	18.5	62	80	96	40	28
10-07-2022 11:52:00	21.4	66.5	22.3	60.7	22.7	59.1	18.6	62	81	95	41	29
10-07-2022 11:53:00	21.4	66.8	22.3	60.7	22.7	59	18.6	62.1	80	98	40	28
10-07-2022 11:54:00	21.4	67	22.3	60.7	22.7	59	18.6	62	80	97	41	28
10-07-2022 11:55:00	21.4	66.6	22.4	60.7	22.7	59	18.6	61.9	82	98	40	30
10-07-2022 11:56:00	21.4	66.8	22.3	60.8	22.7	59	18.6	61.9	82	96	41	29
10-07-2022 11:57:00	21.4	67.1	22.3	60.7	22.7	59	18.6	61.8	82	95	41	29
10-07-2022 11:58:00	21.4	66.8	22.4	60.7	22.7	59	18.6	61.9	82	96	40	29
10-07-2022 11:59:00	21.4	66.7	22.4	60.7	22.7	59.1	18.6	61.8	82	94	41	29
10-07-2022 12:00:00	21.4	67.1	22.4	60.8	22.7	59.1	18.6	61.8	82	94	41	29
10-07-2022 12:01:00	21.4	67.1	22.4	60.8	22.7	59.1	18.7	61.8	82	93	41	28

ACTIVITY	NAME	SIGNATURE AND DATE
REVIEWED BY USER		
REVIEWED BY QA		



SOMERSET THERAPEUTICS LIMITED

DATA REPORT - SVP1 AND AMPOULE LINE EMS

STERILE CORRIDOR

Date Time	Temperature	RH	Temperature	RH	Temperature	RH	Temperature	RH	Differential Pressure	Differential Pressure	Differential Pressure	Differential Pressure
DD-MM-YYYY HH:MM:SS	Injectable sterile corridor (217) (NMT 25°C)	Injectable sterile corridor (217) (NMT 65%)	Ampoule 4 head manual filling (222) (NMT 25°C)	Ampoule 4 head manual filling (222) (NMT 65%)	SVP filtration 02 (223) (NMT 25°C)	SVP filtration 02 (223) (NMT 65%)	SVP filtration 01 (221) (NMT 25°C)	SVP filtration 01 (221) (NMT 65%)	SVP filtration 02 w.r.t Sterile Corridor (NLT 6 Pa)	Ampoule 4 Head Manual Filling w.r.t Sterile Corridor (NLT 6 Pa)	SVP Filtration-01 w.r.t Sterile corridor (NLT 6 Pa)	Sterile Corridor w.r.t Change Room-03 (NLT 6 Pa)
10-07-2022 12:02:00	21.4	66.8	22.4	60.8	22.7	59.1	18.7	61.8	81	93	41	29
10-07-2022 12:03:00	21.4	67	22.4	60.8	22.7	59.1	18.7	61.9	81	96	40	29
10-07-2022 12:04:00	21.4	67.2	22.4	60.8	22.7	59.1	18.7	61.8	83	94	41	29
10-07-2022 12:05:00	21.4	66.8	22.4	60.8	22.7	59.1	18.7	61.8	81	94	40	29
10-07-2022 12:06:00	21.4	67	22.3	60.8	22.7	59.1	18.7	61.8	81	93	42	27
10-07-2022 12:07:00	21.4	67.3	22.4	60.8	22.7	59.1	18.7	61.8	80	94	40	29
10-07-2022 12:08:00	21.4	67	22.4	60.8	22.7	59.1	18.7	61.8	81	94	41	29
10-07-2022 12:09:00	21.4	66.6	22.4	60.8	22.7	59.2	18.7	61.8	82	94	41	29
10-07-2022 12:10:00	21.4	66.9	22.4	60.8	22.7	59.1	18.7	61.8	82	97	41	28
10-07-2022 12:11:00	21.4	67.1	22.3	60.8	22.7	59.1	18.7	61.7	82	95	41	28
10-07-2022 12:12:00	21.4	66.8	22.3	60.8	22.7	59.1	18.7	61.7	81	96	40	29
10-07-2022 12:13:00	21.4	66.8	22.4	60.8	22.7	59.1	18.7	61.7	81	95	41	28
10-07-2022 12:14:00	21.4	67.2	22.3	60.9	22.7	59.2	18.7	61.7	82	95	41	28

ACTIVITY	NAME	SIGNATURE AND DATE
REVIEWED BY USER		
REVIEWED BY QA		



SOMERSET THERAPEUTICS LIMITED

DATA REPORT - SVP1 AND AMPOULE LINE EMS

STERILE CORRIDOR

Date Time	Temperature	RH	Temperature	RH	Temperature	RH	Temperature	RH	Differential Pressure	Differential Pressure	Differential Pressure	Differential Pressure
DD-MM-YYYY HH:MM:SS	Injectable sterile corridor (217) (NMT 25°C)	Injectable sterile corridor (217) (NMT 65%)	Ampoule 4 head manual filling (222) (NMT 25°C)	Ampoule 4 head manual filling (222) (NMT 65%)	SVP filtration 02 (223) (NMT 25°C)	SVP filtration 02 (223) (NMT 65%)	SVP filtration 01 (221) (NMT 25°C)	SVP filtration 01 (221) (NMT 65%)	SVP filtration 02 w.r.t Sterile Corridor (NLT 6 Pa)	Ampoule 4 Head Manual Filling w.r.t Sterile Corridor (NLT 6 Pa)	SVP Filtration-01 w.r.t Sterile corridor (NLT 6 Pa)	Sterile Corridor w.r.t Change Room-03 (NLT 6 Pa)
10-07-2022 12:15:00	21.4	66.9	22.3	61	22.7	59.2	18.7	61.8	79	95	41	29
10-07-2022 12:16:00	21.4	66.6	22.4	61	22.7	59.3	18.7	61.8	79	95	42	29
10-07-2022 12:17:00	21.4	67.4	22.4	60.9	22.7	59.2	18.7	63	10	-4	1	6
10-07-2022 12:18:00	21.4	68.7	22.4	60.9	22.7	59.2	18.8	67.1	-4	-7	-2	0
10-07-2022 12:19:00	21.4	68.2	22.5	60.7	22.7	59.5	18.9	64.7	0	0	0	0
10-07-2022 12:20:00	21.5	68	22.6	60.6	22.8	59.5	19	64.4	0	0	0	0
10-07-2022 12:21:00	21.6	67.6	22.7	60.5	22.8	59.6	19.1	64.1	0	0	0	0
10-07-2022 12:22:00	21.6	67.1	22.8	60.3	22.8	59.6	19.2	64	0	0	0	0
10-07-2022 12:23:00	21.7	66.6	22.8	60.2	22.8	59.6	19.2	63.8	0	-1	0	0
10-07-2022 12:24:00	21.8	66.5	22.9	60	22.8	59.7	19.3	63.6	0	0	0	0
10-07-2022 12:25:00	21.8	66.4	23	59.8	22.8	59.6	19.3	63.6	0	0	0	0
10-07-2022 12:26:00	21.8	66.2	23	59.7	22.8	59.6	19.4	63.5	0	0	0	0
10-07-2022 12:27:00	21.8	66.1	23.1	59.6	22.8	59.6	19.4	63.6	0	0	0	0

ACTIVITY	NAME	SIGNATURE AND DATE
REVIEWED BY USER		
REVIEWED BY QA		



SOMERSET THERAPEUTICS LIMITED

DATA REPORT - SVP1 AND AMPOULE LINE EMS

STERILE CORRIDOR

Date Time	Temperature	RH	Temperature	RH	Temperature	RH	Temperature	RH	Differential Pressure	Differential Pressure	Differential Pressure	Differential Pressure
DD-MM-YYYY HH:MM:SS	Injectable sterile corridor (217) (NMT 25°C)	Injectable sterile corridor (217) (NMT 65%)	Ampoule 4 head manual filling (222) (NMT 25°C)	Ampoule 4 head manual filling (222) (NMT 65%)	SVP filtration 02 (223) (NMT 25°C)	SVP filtration 02 (223) (NMT 65%)	SVP filtration 01 (221) (NMT 25°C)	SVP filtration 01 (221) (NMT 65%)	SVP filtration 02 w.r.t Sterile Corridor (NLT 6 Pa)	Ampoule 4 Head Manual Filling w.r.t Sterile Corridor (NLT 6 Pa)	SVP Filtration-01 w.r.t Sterile corridor (NLT 6 Pa)	Sterile Corridor w.r.t Change Room-03 (NLT 6 Pa)
10-07-2022 12:28:00	21.8	65.9	23.2	59.5	22.9	59.6	19.4	63.4	0	0	0	0
10-07-2022 12:29:00	21.8	65.8	23.2	59.4	22.8	59.6	19.5	63.4	0	0	0	0
10-07-2022 12:30:00	21.9	65.7	23.3	59.2	22.9	59.6	19.5	63.4	0	0	0	0
10-07-2022 12:31:00	21.9	65.6	23.3	59.1	22.9	59.6	19.6	63.4	0	0	0	0
10-07-2022 12:32:00	21.9	65.4	23.4	59	22.9	59.6	19.6	63.4	0	0	0	0
10-07-2022 12:33:00	21.9	65.3	23.4	58.7	22.9	59.6	19.6	63.3	0	0	0	0
10-07-2022 12:34:00	21.9	65.2	23.5	58.5	22.9	59.6	19.7	63.3	0	0	0	0
10-07-2022 12:35:00	21.9	65.1	23.6	58.4	22.9	59.6	19.7	63.4	0	0	0	0
10-07-2022 12:36:00	22	65	23.7	58.2	23	59.6	19.7	63.4	0	0	0	0
10-07-2022 12:37:00	22	64.9	23.7	58.1	23	59.5	19.8	63.3	0	0	0	0
10-07-2022 12:38:00	22	64.6	23.8	57.9	23	59.6	19.8	63.4	0	0	0	0
10-07-2022 12:39:00	22	64.6	23.9	57.7	23	59.6	19.8	63.4	0	0	0	0
10-07-2022 12:40:00	22.1	64.6	23.9	57.5	23	59.5	19.8	63.5	0	0	0	0

ACTIVITY	NAME	SIGNATURE AND DATE
REVIEWED BY USER		
REVIEWED BY QA		



SOMERSET THERAPEUTICS LIMITED

DATA REPORT - SVP1 AND AMPOULE LINE EMS

STERILE CORRIDOR

Date Time	Temperature	RH	Temperature	RH	Temperature	RH	Temperature	RH	Differential Pressure	Differential Pressure	Differential Pressure	Differential Pressure
DD-MM-YYYY HH:MM:SS	Injectable sterile corridor (217) (NMT 25°C)	Injectable sterile corridor (217) (NMT 65%)	Ampoule 4 head manual filling (222) (NMT 25°C)	Ampoule 4 head manual filling (222) (NMT 65%)	SVP filtration 02 (223) (NMT 25°C)	SVP filtration 02 (223) (NMT 65%)	SVP filtration 01 (221) (NMT 25°C)	SVP filtration 01 (221) (NMT 65%)	SVP filtration 02 w.r.t Sterile Corridor (NLT 6 Pa)	Ampoule 4 Head Manual Filling w.r.t Sterile Corridor (NLT 6 Pa)	SVP Filtration-01 w.r.t Sterile corridor (NLT 6 Pa)	Sterile Corridor w.r.t Change Room-03 (NLT 6 Pa)
10-07-2022 12:41:00	22.1	64.5	24	57.3	23	59.5	19.8	63.5	0	0	0	0
10-07-2022 12:42:00	22.1	64.4	24	57.3	23	59.5	19.9	63.5	0	0	0	0
10-07-2022 12:43:00	22.1	64.3	24.1	57.2	23	59.5	19.9	63.5	0	0	0	0
10-07-2022 12:44:00	22.1	64.2	24.2	57	23	59.5	19.9	63.5	0	0	0	0
10-07-2022 12:45:00	22.1	64.1	24.2	56.9	23.1	59.5	19.9	63.5	0	0	0	0
10-07-2022 12:46:00	22.1	63.9	24.2	56.8	23.1	59.5	20	63.5	0	0	0	0
10-07-2022 12:47:00	22.2	63.8	24.2	56.8	23.1	59.5	20	63.6	0	0	0	0
10-07-2022 12:48:00	22.2	63.8	24.2	56.7	23.1	59.5	20	63.6	0	0	0	0
10-07-2022 12:49:00	22.2	63.8	24.3	56.6	23.1	59.5	20.1	63.5	0	0	0	0
10-07-2022 12:50:00	22.2	63.7	24.3	56.6	23.1	59.5	20.1	63.5	0	0	0	0
10-07-2022 12:51:00	22.2	63.5	24.3	56.5	23.1	59.4	20.1	63.6	0	0	0	0
10-07-2022 12:52:00	22.3	63.5	24.4	56.4	23.1	59.4	20.1	63.5	0	0	0	0
10-07-2022 12:53:00	22.3	63.2	24.4	56.3	23.1	59.4	20.1	63.6	0	0	0	0

ACTIVITY	NAME	SIGNATURE AND DATE
REVIEWED BY USER		
REVIEWED BY QA		



SOMERSET THERAPEUTICS LIMITED

DATA REPORT - SVP1 AND AMPOULE LINE EMS

STERILE CORRIDOR

Date Time	Temperature	RH	Temperature	RH	Temperature	RH	Temperature	RH	Differential Pressure	Differential Pressure	Differential Pressure	Differential Pressure
DD-MM-YYYY HH:MM:SS	Injectable sterile corridor (217) (NMT 25°C)	Injectable sterile corridor (217) (NMT 65%)	Ampoule 4 head manual filling (222) (NMT 25°C)	Ampoule 4 head manual filling (222) (NMT 65%)	SVP filtration 02 (223) (NMT 25°C)	SVP filtration 02 (223) (NMT 65%)	SVP filtration 01 (221) (NMT 25°C)	SVP filtration 01 (221) (NMT 65%)	SVP filtration 02 w.r.t Sterile Corridor (NLT 6 Pa)	Ampoule 4 Head Manual Filling w.r.t Sterile Corridor (NLT 6 Pa)	SVP Filtration-01 w.r.t Sterile corridor (NLT 6 Pa)	Sterile Corridor w.r.t Change Room-03 (NLT 6 Pa)
10-07-2022 12:54:00	22.3	63.1	24.4	56.3	23.2	59.4	20.2	63.6	0	0	0	0
10-07-2022 12:55:00	22.3	63.1	24.5	56	23.2	59.4	20.2	63.6	0	0	0	0
10-07-2022 12:56:00	22.3	63	24.5	56	23.2	59.4	20.2	63.6	0	0	0	0
10-07-2022 12:57:00	22.4	62.9	24.5	56	23.2	59.3	20.2	63.6	0	0	0	0
10-07-2022 12:58:00	22.4	62.8	24.6	55.9	23.2	59.4	20.2	63.7	0	0	0	0
10-07-2022 12:59:00	22.4	63	24.6	55.8	23.2	59.3	20.3	63.7	0	0	0	0
10-07-2022 13:00:00	22.4	62.6	24.6	55.8	23.2	59.3	20.3	63.7	0	0	0	0
10-07-2022 13:01:00	22.4	62.6	24.6	55.7	23.2	59.2	20.3	63.6	0	0	0	0
10-07-2022 13:02:00	22.5	62.5	24.6	55.7	23.2	59.3	20.3	63.7	0	0	0	0
10-07-2022 13:03:00	22.6	62.5	24.6	55.7	23.2	59.2	20.3	63.7	0	0	0	0
10-07-2022 13:04:00	22.7	62.2	24.6	55.7	23.3	59.3	20.3	64.5	0	0	0	0
10-07-2022 13:05:00	22.7	62.2	24.7	56	23.3	59.3	20.4	64.9	0	0	0	0
10-07-2022 13:06:00	22.8	58.1	24.7	55.7	23.3	59.6	20.4	64.5	0	0	0	0

ACTIVITY	NAME	SIGNATURE AND DATE
REVIEWED BY USER		
REVIEWED BY QA		



SOMERSET THERAPEUTICS LIMITED

DATA REPORT - SVP1 AND AMPOULE LINE EMS

STERILE CORRIDOR

Date Time	Temperature	RH	Temperature	RH	Temperature	RH	Temperature	RH	Differential Pressure	Differential Pressure	Differential Pressure	Differential Pressure
DD-MM-YYYY HH:MM:SS	Injectable sterile corridor (217) (NMT 25°C)	Injectable sterile corridor (217) (NMT 65%)	Ampoule 4 head manual filling (222) (NMT 25°C)	Ampoule 4 head manual filling (222) (NMT 65%)	SVP filtration 02 (223) (NMT 25°C)	SVP filtration 02 (223) (NMT 65%)	SVP filtration 01 (221) (NMT 25°C)	SVP filtration 01 (221) (NMT 65%)	SVP filtration 02 w.r.t Sterile Corridor (NLT 6 Pa)	Ampoule 4 Head Manual Filling w.r.t Sterile Corridor (NLT 6 Pa)	SVP Filtration-01 w.r.t Sterile corridor (NLT 6 Pa)	Sterile Corridor w.r.t Change Room-03 (NLT 6 Pa)
10-07-2022 13:07:00	22.9	58	24.8	55.6	23.3	60.1	20.4	64.5	-1	0	0	0
10-07-2022 13:08:00	23	57.9	24.8	55.6	23.4	59.5	20.4	64.5	0	0	0	0
10-07-2022 13:09:00	23	58	24.8	55.6	23.4	59.3	20.4	64.5	0	0	0	0
10-07-2022 13:10:00	23.1	58.1	24.8	55.4	23.4	59.5	20.5	64.6	-3	0	0	0
10-07-2022 13:11:00	23.1	58.1	24.9	55.3	23.4	59.4	20.5	65.6	0	0	0	0
10-07-2022 13:12:00	23.1	58.8	24.9	55.2	23.4	59.3	20.5	66	0	0	0	0
10-07-2022 13:13:00	23.1	59	24.9	55.1	23.4	59.3	20.5	66.1	0	0	0	0
10-07-2022 13:14:00	23.1	57.1	24.9	55.1	23.4	59.3	20.6	66.2	0	0	0	0
10-07-2022 13:15:00	23.2	56.9	25	54.9	23.4	59.3	20.6	66.4	0	0	0	0
10-07-2022 13:16:00	23.2	56.8	24.9	55	23.4	59.3	20.6	66.5	0	0	0	0
10-07-2022 13:17:00	23.3	57.2	25	55	23.4	59.3	20.6	66.5	0	0	0	0
10-07-2022 13:18:00	23.3	56.4	25	54.9	23.4	59.3	20.7	66.6	0	0	0	0
10-07-2022 13:19:00	23.3	57.1	25	54.9	23.5	59.3	20.7	66.6	0	0	0	0

ACTIVITY	NAME	SIGNATURE AND DATE
REVIEWED BY USER		
REVIEWED BY QA		



SOMERSET THERAPEUTICS LIMITED

DATA REPORT - SVP1 AND AMPOULE LINE EMS

STERILE CORRIDOR

Date Time	Temperature	RH	Temperature	RH	Temperature	RH	Temperature	RH	Differential Pressure	Differential Pressure	Differential Pressure	Differential Pressure
DD-MM-YYYY HH:MM:SS	Injectable sterile corridor (217) (NMT 25°C)	Injectable sterile corridor (217) (NMT 65%)	Ampoule 4 head manual filling (222) (NMT 25°C)	Ampoule 4 head manual filling (222) (NMT 65%)	SVP filtration 02 (223) (NMT 25°C)	SVP filtration 02 (223) (NMT 65%)	SVP filtration 01 (221) (NMT 25°C)	SVP filtration 01 (221) (NMT 65%)	SVP filtration 02 w.r.t Sterile Corridor (NLT 6 Pa)	Ampoule 4 Head Manual Filling w.r.t Sterile Corridor (NLT 6 Pa)	SVP Filtration-01 w.r.t Sterile corridor (NLT 6 Pa)	Sterile Corridor w.r.t Change Room-03 (NLT 6 Pa)
10-07-2022 13:20:00	23.3	57.2	25	54.8	23.5	59.3	20.7	66.7	0	0	0	0
10-07-2022 13:21:00	23.3	57.3	25.1	54.8	23.5	59.3	20.7	66.8	0	0	0	0
10-07-2022 13:22:00	23.3	56.6	25.1	54.8	23.5	59.3	20.7	66.8	0	0	0	0
10-07-2022 13:23:00	23.3	56.3	25.1	54.7	23.5	59.3	20.7	66.8	0	0	0	0
Min Value	21.4	56.3	22.3	54.7	22.7	58.9	18.4	61.7	-4	-7	-2	0
Max Value	23.3	68.7	25.1	61	23.5	60.1	20.7	67.1	85	100	43	31

End Of Report : From 10-07-2022 11:23:22 To 10-07-2022 13:23:22

ACTIVITY	NAME	SIGNATURE AND DATE
REVIEWED BY USER		
REVIEWED BY QA		