



SOMERSET THERAPEUTICS LIMITED

DATA REPORT - SVP1 AND AMPOULE LINE EMS

LINEN AREA

Date Time	Temperature	RH	Diffrential Pressure	Diffrential Pressure	Diffrential Pressure
DD-MM-YYYY HH:MM:SS	Linen Preparation and Storage Room	Linen Preparation and Storage Room	Linen Preparation and Storage Room w.r.t Linen Washing Change Room (NLT 6 Pa)	Linen Washing Change Room w.r.t Injectable main corridor (NLT 12 Pa)	Linen Preparation and Storage Room w.r.t Linen Washing and Drying Room (NLT 6 Pa)
05-05-2022 17:52:00	18.7	75.9	15	35	91
05-05-2022 18:22:00	17.8	77.5	15	28	105
05-05-2022 18:52:00	17	77.9	17	38	89
05-05-2022 19:22:00	16.7	78.7	15	37	90
05-05-2022 19:52:00	16.5	78	24	50	72
05-05-2022 20:22:00	16.4	77.9	17	25	103
05-05-2022 20:52:00	16.7	76.6	16	26	106
05-05-2022 21:22:00	17.1	75.4	8	28	73
05-05-2022 21:52:00	17.1	75.5	12	40	91
05-05-2022 22:22:00	16.6	77.5	25	30	91
05-05-2022 22:52:00	16.3	79.9	17	36	92
05-05-2022 23:22:00	16.5	80.8	13	38	90
05-05-2022 23:52:00	16.5	80.7	15	29	90
06-05-2022 00:22:00	16.4	81.5	19	38	91
06-05-2022 00:52:00	16.6	81.4	18	34	90
06-05-2022 01:22:00	16.6	81.3	14	34	90
06-05-2022 01:52:00	16.5	81.3	16	34	91
06-05-2022 02:22:00	16.4	81.3	18	35	90
06-05-2022 02:52:00	16.4	81.5	16	38	90
06-05-2022 03:22:00	16.4	81.8	18	35	91
06-05-2022 03:52:00	16.3	81.7	15	37	92
06-05-2022 04:22:00	16.3	81.6	14	36	91
06-05-2022 04:52:00	16.3	81.9	18	36	91
06-05-2022 05:22:00	16.2	81.7	17	35	93

ACTIVITY	NAME	SIGNATURE AND DATE
REVIEWED BY USER		
REVIEWED BY QA		



SOMERSET THERAPEUTICS LIMITED

DATA REPORT - SVP1 AND AMPOULE LINE EMS

LINEN AREA

Date Time	Temperature	RH	Diffrential Pressure	Diffrential Pressure	Diffrential Pressure
DD-MM-YYYY HH:MM:SS	Linen Preparation and Storage Room	Linen Preparation and Storage Room	Linen Preparation and Storage Room w.r.t Linen Washing Change Room (NLT 6 Pa)	Linen Washing Change Room w.r.t Injectable main corridor (NLT 12 Pa)	Linen Preparation and Storage Room w.r.t Linen Washing and Drying Room (NLT 6 Pa)
06-05-2022 05:52:00	16.2	81.6	16	35	91
06-05-2022 06:22:00	16.2	82.6	18	39	90
06-05-2022 06:52:00	16.4	82.5	6	42	88
06-05-2022 07:22:00	16.7	82.6	18	28	104
06-05-2022 07:52:00	17	81.2	20	19	101
06-05-2022 08:22:00	17.2	81.6	13	24	106
06-05-2022 08:52:00	17.8	80	23	23	103
06-05-2022 09:22:00	18.3	80.3	29	22	87
06-05-2022 09:52:00	18.7	79.9	15	30	103
06-05-2022 10:22:00	19.1	80.4	16	28	105
06-05-2022 10:52:00	19.4	78.6	18	37	91
06-05-2022 11:22:00	19.6	78.3	6	31	105
06-05-2022 11:52:00	19.7	78.3	14	29	105
06-05-2022 12:22:00	19.7	79.3	12	30	106
06-05-2022 12:52:00	19.8	78.1	15	30	90
06-05-2022 13:22:00	20.1	77	15	36	91
06-05-2022 13:52:00	19.8	78.9	21	30	86
06-05-2022 14:22:00	19.8	78.9	23	37	90
06-05-2022 14:52:00	19.7	78.7	-7	23	37
06-05-2022 15:22:00	19.8	79.3	13	21	82
06-05-2022 15:52:00	20.1	79.3	12	27	104
06-05-2022 16:22:00	20	79.1	8	31	74
06-05-2022 16:52:00	20.5	78.9	11	28	104
06-05-2022 17:22:00	20.9	75.7	15	28	104

ACTIVITY	NAME	SIGNATURE AND DATE
REVIEWED BY USER		
REVIEWED BY QA		



SOMERSET THERAPEUTICS LIMITED

DATA REPORT - SVP1 AND AMPOULE LINE EMS

LINEN AREA

Date Time	Temperature	RH	Diffrential Pressure	Diffrential Pressure	Diffrential Pressure
DD-MM-YYYY HH:MM:SS	Linen Preparation and Storage Room	Linen Preparation and Storage Room	Linen Preparation and Storage Room w.r.t Linen Washing Change Room (NLT 6 Pa)	Linen Washing Change Room w.r.t Injectable main corridor (NLT 12 Pa)	Linen Preparation and Storage Room w.r.t Linen Washing and Drying Room (NLT 6 Pa)
06-05-2022 17:52:00	20.4	73.9	-15	14	18
06-05-2022 18:22:00	20	73.1	15	36	91
06-05-2022 18:52:00	18.5	76.4	14	37	91
06-05-2022 19:22:00	17.9	77.8	15	36	90
06-05-2022 19:52:00	17.7	78	17	52	70
06-05-2022 20:22:00	17.6	78.6	13	28	105
06-05-2022 20:52:00	18.2	77.2	14	26	105
06-05-2022 21:22:00	18.7	74	14	25	105
06-05-2022 21:52:00	19.1	72.9	12	35	90
06-05-2022 22:22:00	17.9	77.5	16	36	91
06-05-2022 22:52:00	17.5	79.2	14	20	89
06-05-2022 23:22:00	17.3	79.7	16	36	89
06-05-2022 23:52:00	17.2	80.4	16	36	90
07-05-2022 00:22:00	17.1	81	16	38	90
07-05-2022 00:52:00	17.2	81.4	16	37	91
07-05-2022 01:22:00	17.1	81.1	18	37	93
07-05-2022 01:52:00	17.1	81.4	16	37	90
07-05-2022 02:22:00	17.1	81.7	16	34	90
07-05-2022 02:52:00	17	81.1	16	37	91
07-05-2022 03:22:00	16.9	81.1	13	37	90
07-05-2022 03:52:00	16.7	81.5	13	37	91
07-05-2022 04:22:00	16.7	81.4	17	33	92
07-05-2022 04:52:00	16.7	81.9	15	34	91
07-05-2022 05:22:00	16.7	82.6	15	36	92

ACTIVITY	NAME	SIGNATURE AND DATE
REVIEWED BY USER		
REVIEWED BY QA		



SOMERSET THERAPEUTICS LIMITED

DATA REPORT - SVP1 AND AMPOULE LINE EMS

LINEN AREA

Date Time	Temperature	RH	Diffrential Pressure	Diffrential Pressure	Diffrential Pressure
DD-MM-YYYY HH:MM:SS	Linen Preparation and Storage Room	Linen Preparation and Storage Room	Linen Preparation and Storage Room w.r.t Linen Washing Change Room (NLT 6 Pa)	Linen Washing Change Room w.r.t Injectable main corridor (NLT 12 Pa)	Linen Preparation and Storage Room w.r.t Linen Washing and Drying Room (NLT 6 Pa)
07-05-2022 05:52:00	16.8	82	15	34	90
07-05-2022 06:22:00	17.1	80.6	18	35	90
07-05-2022 06:52:00	17.1	80	15	34	90
07-05-2022 07:22:00	17	81.6	17	38	86
07-05-2022 07:52:00	19.4	97.2	12	38	92
07-05-2022 08:22:00	21.2	97.9	17	39	89
07-05-2022 08:52:00	22.9	87.6	15	40	91
07-05-2022 09:22:00	24.3	80.8	16	35	89
07-05-2022 09:52:00	****	****	****	****	****
07-05-2022 10:22:00	****	****	****	****	****
07-05-2022 10:52:00	****	****	****	****	****
07-05-2022 11:22:00	****	****	****	****	****
07-05-2022 11:52:00	****	****	****	****	****
07-05-2022 12:22:00	****	****	****	****	****
07-05-2022 12:52:00	****	****	****	****	****
07-05-2022 13:22:00	****	****	****	****	****
07-05-2022 13:52:00	****	****	****	****	****
07-05-2022 14:22:00	****	****	****	****	****
07-05-2022 14:52:00	****	****	****	****	****
07-05-2022 15:22:00	****	****	****	****	****
07-05-2022 15:52:00	****	****	****	****	****
07-05-2022 16:22:00	****	****	****	****	****
07-05-2022 16:52:00	****	****	****	****	****
07-05-2022 17:22:00	****	****	****	****	****

ACTIVITY	NAME	SIGNATURE AND DATE
REVIEWED BY USER		
REVIEWED BY QA		



SOMERSET THERAPEUTICS LIMITED

DATA REPORT - SVP1 AND AMPOULE LINE EMS

LINEN AREA

Date Time	Temperature	RH	Diffrential Pressure	Diffrential Pressure	Diffrential Pressure
DD-MM-YYYY HH:MM:SS	Linen Preparation and Storage Room	Linen Preparation and Storage Room	Linen Preparation and Storage Room w.r.t Linen Washing Change Room (NLT 6 Pa)	Linen Washing Change Room w.r.t Injectable main corridor (NLT 12 Pa)	Linen Preparation and Storage Room w.r.t Linen Washing and Drying Room (NLT 6 Pa)
07-05-2022 17:52:00	****	****	****	****	****

End Of Report : From 05-05-2022 17:52:33 To 07-05-2022 17:52:33

ACTIVITY	NAME	SIGNATURE AND DATE
REVIEWED BY USER		
REVIEWED BY QA		